

This information was generated by the HP KEYMARK database on 22 Jun 2022

[Login](#)

| | | | |
|---------------------|--------------------------------|----------|--------------------|
| Summary of | AURIGA 12M 16M | Reg. No. | ICIM-PDC-000070-00 |
| Certificate Holder | | | |
| Name | BAXI S.p.A. | | |
| Address | Via Trozzetti, 20 | Zip | |
| City | Bassano del Grappa (VI) | Country | Italy |
| Certification Body | ICIM S.p.A. | | |
| Subtype title | AURIGA 12M 16M | | |
| Heat Pump Type | Outdoor Air/Water | | |
| Refrigerant | R32 | | |
| Mass of Refrigerant | 2.8 kg | | |
| Certification Date | 25.05.2020 | | |
| Testing basis | HP Keymark Scheme Rules rev. 7 | | |

Model: AURIGA 12M

Configure model

| | |
|-------------------------------------|-----------------------|
| Model name | AURIGA 12M |
| Application | Heating (medium temp) |
| Units | Outdoor |
| Climate Zone | n/a |
| Reversibility | No |
| Cooling mode application (optional) | n/a |

General Data

| | |
|--------------|-------------|
| Power supply | 1x230V 50Hz |
|--------------|-------------|

Heating

EN 14511-2

| | Low temperature | Medium temperature |
|-------------|-----------------|--------------------|
| Heat output | 12.30 kW | 11.90 kW |
| El input | 2.56 kW | 4.28 kW |
| COP | 4.81 | 2.78 |

EN 14511-4

| Shutting off the heat transfer medium flow | passed |
|--|--------|
| Complete power supply failure | passed |
| Defrost test | passed |

Average Climate

This information was generated by the HP KEYMARK database on 22 Jun 2022

EN 12102-1

| | Low temperature | Medium temperature |
|---------------------------|-----------------|--------------------|
| Sound power level indoor | dB(A) | dB(A) |
| Sound power level outdoor | 68 dB(A) | 68 dB(A) |

EN 14825

| | Low temperature | Medium temperature |
|----------------|-----------------|--------------------|
| η_s | 169 % | 126 % |
| Prated | 12.00 kW | 13.00 kW |
| SCOP | 4.29 | 3.23 |
| Tbiv | -7 °C | -7 °C |
| TOL | -10 °C | -10 °C |
| Pdh Tj = -7°C | 10.52 kW | 11.29 kW |
| COP Tj = -7°C | 2.88 | 2.05 |
| Cdh Tj = -7 °C | 0.90 | 0.90 |
| Pdh Tj = +2°C | 6.50 kW | 7.31 kW |
| COP Tj = +2°C | 4.15 | 3.14 |
| Cdh Tj = +2 °C | 0.90 | 0.90 |
| Pdh Tj = +7°C | 4.12 kW | 4.96 kW |
| COP Tj = +7°C | 5.74 | 4.25 |
| Cdh Tj = +7 °C | 0.90 | 0.90 |

This information was generated by the HP KEYMARK database on 22 Jun 2022

| | | |
|---|-------------|-------------|
| Pdh Tj = 12°C | 2.23 kW | 2.37 kW |
| COP Tj = 12°C | 5.40 | 4.94 |
| Cdh Tj = +12 °C | 0.90 | 0.90 |
| Pdh Tj = Tbiv | 10.52 kW | 11.29 kW |
| COP Tj = Tbiv | 2.88 | 2.05 |
| Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 12.01 kW | 11.88 kW |
| COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh | 2.60 | 1.79 |
| Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 0.90 | 0.90 |
| WTOL | 60 °C | 60 °C |
| Poff | 9 W | 9 W |
| PTO | 15 W | 15 W |
| PSB | 9 W | 9 W |
| PCK | 0 W | 0 W |
| Supplementary Heater: Type of energy input | Electricity | Electricity |
| Supplementary Heater: PSUP | 0.00 kW | 0.90 kW |
| Annual energy consumption Qhe | 5726 kWh | 8164 kWh |

Model: AURIGA 16M

Configure model

| | |
|-------------------------------------|-----------------------|
| Model name | AURIGA 16M |
| Application | Heating (medium temp) |
| Units | Outdoor |
| Climate Zone | n/a |
| Reversibility | No |
| Cooling mode application (optional) | n/a |

General Data

| | |
|--------------|-------------|
| Power supply | 1x230V 50Hz |
|--------------|-------------|

Heating

EN 14511-2

| | Low temperature | Medium temperature |
|-------------|-----------------|--------------------|
| Heat output | 16.30 kW | 16.10 kW |
| El input | 3.66 kW | 5.90 kW |
| COP | 4.45 | 2.73 |

EN 14511-4

| Shutting off the heat transfer medium flow | passed |
|--|--------|
| Complete power supply failure | passed |
| Defrost test | passed |

Average Climate

EN 12102-1

| | Low temperature | Medium temperature |
|---------------------------|-----------------|--------------------|
| Sound power level indoor | dB(A) | dB(A) |
| Sound power level outdoor | 71 dB(A) | 71 dB(A) |

EN 14825

| | Low temperature | Medium temperature |
|----------------|-----------------|--------------------|
| η_s | 169 % | 128 % |
| Prated | 16.00 kW | 15.00 kW |
| SCOP | 4.30 | 3.27 |
| Tbiv | -7 °C | -7 °C |
| TOL | -10 °C | -10 °C |
| Pdh Tj = -7°C | 14.15 kW | 12.90 kW |
| COP Tj = -7°C | 2.72 | 2.04 |
| Cdh Tj = -7 °C | 0.90 | 0.90 |
| Pdh Tj = +2°C | 8.92 kW | 8.25 kW |
| COP Tj = +2°C | 4.17 | 3.21 |
| Cdh Tj = +2 °C | 0.90 | 0.90 |
| Pdh Tj = +7°C | 5.64 kW | 5.45 kW |
| COP Tj = +7°C | 5.86 | 4.32 |
| Cdh Tj = +7 °C | 0.90 | 0.90 |

This information was generated by the HP KEYMARK database on 22 Jun 2022

| | | |
|---|-------------|-------------|
| Pdh Tj = 12°C | 2.47 kW | 2.57 kW |
| COP Tj = 12°C | 6.28 | 5.12 |
| Cdh Tj = +12 °C | 0.90 | 0.90 |
| Pdh Tj = Tbiv | 14.15 kW | 12.90 kW |
| COP Tj = Tbiv | 2.72 | 2.04 |
| Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 12.93 kW | 11.16 kW |
| COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh | 2.41 | 1.65 |
| Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 0.90 | 0.90 |
| WTOL | 60 °C | 60 °C |
| Poff | 9 W | 9 W |
| PTO | 41 W | 41 W |
| PSB | 9 W | 9 W |
| PCK | 0 W | 0 W |
| Supplementary Heater: Type of energy input | Electricity | Electricity |
| Supplementary Heater: PSUP | 3.10 kW | 3.40 kW |
| Annual energy consumption Qhe | 7687 kWh | 9216 kWh |