

Page 1 of 7

#### This information was generated by the HP KEYMARK database on 18 Mar 2022

#### Login

Summary of	WPF 20	Reg. No.	011-1W0275		
Certificate Holder	Certificate Holder				
Name	STIEBEL ELTRON GmbH & Co	STIEBEL ELTRON GmbH & Co KG			
Address	Dr. Stiebel Straße 33	Zip	37603		
City	Holzminden	Country	Germany		
Certification Body	DIN CERTCO Gesellschaft für	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH			
Subtype title	WPF 20				
Heat Pump Type	Brine/Water				
Refrigerant	R410A				
Mass of Refrigerant	5.99 kg	5.99 kg			
Certification Date	24.01.2019				



# Model: WPF 20

Configure model		
Model name	WPF 20	
Application	Heating (medium temp)	
Units	Indoor + Outdoor	
Climate Zone	Colder Climate + Warmer Climate	
Reversibility	No	
Cooling mode application (optional)	n/a	

General Data		
Power supply	3x400V 50Hz	

# Heating

EN 14511-2			
	Low temperature	Medium temperature	
Heat output	21.50 kW	20.10 kW	
El input	4.61 kW	7.08 kW	
СОР	4.66	3.16	

EN 14511-4		
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	
Defrost test	passed	
Starting and operating test	passed	

# Average Climate



 $$\operatorname{\textit{Page}}\xspace$  3 of 7 This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 12102-1			
	Low temperature	Medium temperature	
Sound power level indoor	59 dB(A)	59 dB(A)	
Sound power level outdoor	59 dB(A)	59 dB(A)	

EN 14825			
	Low temperature	Medium temperature	
$\eta_{s}$	192 %	131 %	
Prated	22.00 kW	20.00 kW	
SCOP	5.00	3.48	
Tbiv	-10 °C	-10 °C	
TOL	-10 °C	-10 °C	
Pdh Tj = -7°C	21.50 kW	20.20 kW	
COP Tj = -7°C	4.72	2.96	
Pdh Tj = $+2$ °C	21.70 kW	20.70 kW	
COP Tj = +2°C	5.06	3.48	
Pdh Tj = $+7^{\circ}$ C	21.80 kW	21.00 kW	
COP Tj = +7°C	5.41	3.88	
Pdh Tj = 12°C	22.00 kW	21.30 kW	
COP Tj = 12°C	5.80	4.36	
Pdh Tj = Tbiv	21.50 kW	20.10 kW	

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com





## This information was generated by the HP KEYMARK database on 18 Mar 2022

COP Tj = Tbiv	4.66	2.84
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	21.50 kW	20.10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.66	2.84
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	o w	o w
РТО	7 W	7 W
PSB	7 W	7 W
PCK	74 W	74 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	8904 kWh	11988 kWh

## Warmer Climate

EN 12102-1			
	Low temperature	Medium temperature	
Sound power level indoor	59 dB(A)	59 dB(A)	
Sound power level outdoor	59 dB(A)	59 dB(A)	

EN 14825		
	Low temperature	Medium temperature



Page 5 of 7 This information was generated by the HP KEYMARK database on 18 Mar 2022

		TR database on 10 Mai 202.
$\eta_s$	188 %	128 %
Prated	22.00 kW	20.00 kW
SCOP	4.90	3.40
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	21.50 kW	20.10 kW
$COPTj = +2^{\circ}C$	4.66	2.84
Pdh Tj = $+7^{\circ}$ C	21.70 kW	20.50 kW
$COPTj = +7^{\circ}C$	4.99	3.24
Pdh Tj = 12°C	21.90 kW	21.10 kW
COP Tj = 12°C	5.54	4.03
Pdh Tj = Tbiv	21.50 kW	20.10 kW
COP Tj = Tbiv	4.66	2.84
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	21.50 kW	20.10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.66	2.84
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	0 W	0 W
РТО	7 W	7 W
PSB	7 W	7 W
PCK	74 W	74 W
1		

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com





#### This information was generated by the HP KEYMARK database on 18 Mar 2022

Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	5871 kWh	7884 kWh

### Colder Climate

EN 12102-1				
	Low temperature	Medium temperature		
Sound power level indoor	59 dB(A)	59 dB(A)		
Sound power level outdoor	59 dB(A)	59 dB(A)		

EN 14825			
	Low temperature	Medium temperature	
$\eta_{S}$	201 %	137 %	
Prated	27.00 kW	25.00 kW	
SCOP	5.23	3.62	
Tbiv	-15 °C	-15 °C	
TOL	-22 °C	-22 °C	
Pdh Tj = -7°C	21.80 kW	20.70 kW	
COP Tj = -7°C	5.24	3.46	
Pdh Tj = +2°C	21.90 kW	21.00 kW	
COP Tj = +2°C	5.51	3.87	



Page 7 of 7 This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = +7°C	21.90 kW	21.30 kW
$COP Tj = +7^{\circ}C$	5.74	4.26
Pdh Tj = 12°C	22.00 kW	21.50 kW
COP Tj = 12°C	5.78	4.60
Pdh Tj = Tbiv	21.70 kW	20.50 kW
COP Tj = Tbiv	5.12	3.24
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	21.50 kW	21.10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.66	2.84
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	0 W	o w
PTO	7 W	7 W
PSB	7 W	7 W
PCK	74 W	74 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	5.11 kW	5.05 kW
Annual energy consumption Qhe	12535 kWh	17067 kWh