Login

Summary of	VWL 55/6 A 230V	Reg. No.	40050984
Certificate Holder			
Name	Vaillant Deutschland GmbH & Co KG		
Address	Berghauser Straße 40	Zip	42859
City	Remscheid	Country	Germany
Certification Body	VDE Prüf- und Zertifizierungsinstitut GmbH		
Subtype title	VWL 55/6 A 230V		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R290		
Mass of Refrigerant	0.6 kg		
Certification Date	12.11.2021		
Testing basis	DIN EN 14511-1:2019-07; EN 14511-1:2018; DIN EN 14511-2:2019-07; EN 14511-2:2018; DIN EN 14511-3:2019-07; EN 14511-3:2018; DIN EN 14511-4:2019-07; EN 14511-4:2018; DIN EN 14825:2019-07; EN 14825:2018; DIN EN 12102-1:2018-02; EN 12102-1:2017		

Model: VWL 55/6 A 230V

Configure model	
Model name	VWL 55/6 A 230V
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	3.36 kW	4.83 kW
El input	0.69 kW	1.71 kW
COP	4.80	2.80

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Warmer Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level outdoor	51 dB(A)	54 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	233 %	157 %
Prated	4.96 kW	5.07 kW
SCOP	5.89	3.99
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	4.96 kW	5.07 kW
COP Tj = +2°C	3.35	2.30
Cdh Tj = +2 °C	0.99	0.99
Pdh Tj = +7°C	3.42 kW	3.08 kW
COP Tj = +7°C	5.45	3.43
Cdh Tj = +7 °C	0.97	0.98
Pdh Tj = 12°C	2.59 kW	2.42 kW
COP Tj = 12°C	7.25	5.17
Cdh Tj = +12 °C	0.96	0.97
Pdh Tj = Tbiv	4.96 kW	5.07 kW

COP Tj = Tbiv	3.35	2.30
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.96 kW	5.07 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.35	2.30
WTOL	70 °C	70 °C
Poff	8 W	8 W
PTO	17 W	17 W
PSB	17 W	17 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1125 kWh	1697 kWh

Colder Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level outdoor	51 dB(A)	54 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	158 %	116 %
Prated	5.01 kW	4.76 kW

SCOP	4.02	2.98
Tbiv	-15 °C	-15 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	3.22 kW	2.89 kW
COP Tj = -7°C	3.36	2.45
Cdh Tj = -7 °C	0.980	0.990
Pdh Tj = +2°C	1.92 kW	1.85 kW
COP Tj = +2°C	5.04	3.65
Cdh Tj = +2 °C	0.960	0.970
Pdh Tj = +7°C	2.33 kW	2.21 kW
COP Tj = +7°C	6.82	5.01
Cdh Tj = +7 °C	0.960	0.960
Pdh Tj = 12°C	2.62 kW	2.56 kW
COP Tj = 12°C	7.24	6.46
Cdh Tj = +12 °C	0.960	0.960
Pdh Tj = Tbiv	4.09 kW	3.88 kW
COP Tj = Tbiv	2.13	1.67
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.04 kW	3.40 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.00	1.50
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		
WTOL	70 °C	70 °C

Poff	8 W	8 W
PTO	17 W	17 W
PSB	17 W	17 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	5.01 kW	4.76 kW
Annual energy consumption Qhe	3076 kWh	3930 kWh
Pdh Tj = -15°C (if TOL<-20°C)	4.09	3.88
COP Tj = -15°C (if TOL<-20°C)	2.13	1.67
Cdh Tj = -15 °C	0.990	0.990

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level outdoor	51 dB(A)	54 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	183 %	130 %
Prated	4.81 kW	4.88 kW
SCOP	4.66	3.33

Tbiv	-7 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	4.26 kW	4.32 kW
COP Tj = -7°C	2.78	2.11
Cdh Tj = -7 °C	0.990	0.990
Pdh Tj = +2°C	2.70 kW	2.46 kW
COP Tj = +2°C	4.62	3.19
Cdh Tj = +2 °C	0.970	0.980
Pdh Tj = +7°C	2.29 kW	2.12 kW
COP Tj = +7°C	6.41	4.40
Cdh Tj = +7 °C	0.960	0.970
Pdh Tj = 12°C	2.61 kW	2.52 kW
COP Tj = 12°C	7.61	6.03
Cdh Tj = +12 °C	0.960	0.960
Pdh Tj = Tbiv	4.26 kW	4.63 kW
COP Tj = Tbiv	2.78	1.86
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.13 kW	4.63 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.43	1.86
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		
WTOL	70 °C	70 °C
Poff	8 W	8 W

PTO	17 W	17 W
PSB	17 W	17 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.68 kW	0.25 kW
Annual energy consumption Qhe	2135 kWh	3029 kWh

Model: VWL 55/6 A 230V S2

Configure model	
Model name	VWL 55/6 A 230V S2
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	3.36 kW	4.83 kW
El input	0.69 kW	1.71 kW
COP	4.80	2.80

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Warmer Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level outdoor	51 dB(A)	54 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	225 %	153 %
Prated	4.96 kW	5.07 kW
SCOP	5.71	3.91
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	4.96 kW	5.07 kW
COP Tj = +2°C	3.35	2.30
Cdh Tj = +2 °C	0.99	0.99
Pdh Tj = +7°C	3.42 kW	3.08 kW
COP Tj = +7°C	5.45	3.43
Cdh Tj = +7 °C	0.97	0.98
Pdh Tj = 12°C	2.59 kW	2.42 kW
COP Tj = 12°C	7.25	5.17
Cdh Tj = +12 °C	0.96	0.97
Pdh Tj = Tbiv	4.96 kW	5.07 kW

COP Tj = Tbiv	3.35	2.30
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.96 kW	5.07 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.35	2.30
WTOL	70 °C	70 °C
Poff	8 W	8 W
PTO	17 W	17 W
PSB	17 W	17 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1161 kWh	1733 kWh

Colder Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level outdoor	51 dB(A)	54 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	157 %	116 %
Prated	5.01 kW	4.76 kW

SCOP	3.99	2.97
Tbiv	-15 °C	-15 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	3.22 kW	2.89 kW
COP Tj = -7°C	3.36	2.45
Cdh Tj = -7 °C	0.980	0.990
Pdh Tj = +2°C	1.92 kW	1.85 kW
COP Tj = +2°C	5.04	3.65
Cdh Tj = +2 °C	0.960	0.970
Pdh Tj = +7°C	2.33 kW	2.21 kW
COP Tj = +7°C	6.82	5.01
Cdh Tj = +7 °C	0.960	0.960
Pdh Tj = 12°C	2.62 kW	2.56 kW
COP Tj = 12°C	7.24	6.46
Cdh Tj = +12 °C	0.960	0.960
Pdh Tj = Tbiv	4.09 kW	3.88 kW
COP Tj = Tbiv	2.13	1.67
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.04 kW	3.40 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.00	1.50
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		
WTOL	70 °C	70 °C

Poff	8 W	8 W
PTO	17 W	17 W
PSB	17 W	17 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	5.01 kW	4.76 kW
Annual energy consumption Qhe	3094 kWh	3948 kWh
Pdh Tj = -15°C (if TOL<-20°C)	4.09	3.88
COP Tj = -15°C (if TOL<-20°C)	2.13	1.67
Cdh Tj = -15 °C	0.990	0.990

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level outdoor	51 dB(A)	54 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	181 %	129 %
Prated	4.81 kW	4.88 kW
SCOP	4.59	3.30

Tbiv	-7 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	4.26 kW	4.32 kW
COP Tj = -7°C	2.78	2.11
Cdh Tj = -7 °C	0.990	0.990
Pdh Tj = +2°C	2.70 kW	2.46 kW
COP Tj = +2°C	4.62	3.19
Cdh Tj = +2 °C	0.970	0.980
Pdh Tj = +7°C	2.29 kW	2.12 kW
COP Tj = +7°C	6.41	4.40
Cdh Tj = +7 °C	0.960	0.970
Pdh Tj = 12°C	2.61 kW	2.52 kW
COP Tj = 12°C	7.61	6.03
Cdh Tj = +12 °C	0.960	0.960
Pdh Tj = Tbiv	4.26 kW	4.63 kW
COP Tj = Tbiv	2.78	1.86
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.13 kW	4.63 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.43	1.86
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		
WTOL	70 °C	70 °C
Poff	8 W	8 W

PTO	17 W	17 W
PSB	17 W	17 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.69 kW	0.25 kW
Annual energy consumption Qhe	2165 kWh	3059 kWh

Model: VWL 55/6 A 230V S3

Configure model	
Model name	VWL 55/6 A 230V S3
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	4.21 kW	4.83 kW
El input	0.95 kW	1.71 kW
COP	4.39	2.80

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Warmer Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level outdoor	52 dB(A)	54 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	215 %	157 %
Prated	4.75 kW	5.07 kW
SCOP	5.44	3.99
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	4.75 kW	5.07 kW
COP Tj = +2°C	3.22	2.30
Cdh Tj = +2 °C	0.99	0.99
Pdh Tj = +7°C	3.33 kW	3.08 kW
COP Tj = +7°C	5.07	3.43
Cdh Tj = +7 °C	0.98	0.98
Pdh Tj = 12°C	2.48 kW	2.42 kW
COP Tj = 12°C	6.61	5.17
Cdh Tj = +12 °C	0.96	0.97
Pdh Tj = Tbiv	4.75 kW	5.07 kW

COP Tj = Tbiv	3.22	2.30
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.75 kW	5.07 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.22	2.30
WTOL	55 °C	55 °C
Poff	8 W	8 W
PTO	17 W	17 W
PSB	17 W	17 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1166 kWh	1697 kWh

Colder Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level outdoor	52 dB(A)	54 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	148 %	116 %
Prated	4.68 kW	4.76 kW

SCOP	3.77	2.98
Tbiv	-15 °C	-15 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	2.69 kW	2.89 kW
COP Tj = -7°C	3.26	2.45
Cdh Tj = -7 °C	0.980	0.990
Pdh Tj = +2°C	1.90 kW	1.85 kW
COP Tj = +2°C	4.66	3.65
Cdh Tj = +2 °C	0.960	0.970
Pdh Tj = +7°C	2.22 kW	2.21 kW
COP Tj = +7°C	6.04	5.01
Cdh Tj = +7 °C	0.960	0.960
Pdh Tj = 12°C	2.49 kW	2.56 kW
COP Tj = 12°C	6.79	6.46
Cdh Tj = +12 °C	0.960	0.960
Pdh Tj = Tbiv	3.82 kW	3.88 kW
COP Tj = Tbiv	2.01	1.67
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.70 kW	3.40 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	1.88	1.50
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		
WTOL	55 °C	55 °C

Poff	8 W	8 W
PTO	17 W	17 W
PSB	17 W	17 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	4.68 kW	4.76 kW
Annual energy consumption Qhe	3064 kWh	3930 kWh
Pdh Tj = -15°C (if TOL<-20°C)	3.82	3.88
COP Tj = -15°C (if TOL<-20°C)	2.01	1.67
Cdh Tj = -15 °C	0.990	0.990

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level outdoor	52 dB(A)	54 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	177 %	130 %
Prated	4.45 kW	4.88 kW
SCOP	4.50	3.33

Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	3.93 kW	4.32 kW
COP Tj = -7°C	2.79	2.11
Cdh Tj = -7 °C	0.990	0.990
Pdh Tj = +2°C	2.17 kW	2.46 kW
COP Tj = +2°C	4.46	3.19
Cdh Tj = +2 °C	0.970	0.980
Pdh Tj = +7°C	2.26 kW	2.12 kW
COP Tj = +7°C	5.99	4.40
Cdh Tj = +7 °C	0.960	0.960
Pdh Tj = 12°C	2.54 kW	2.52 kW
COP Tj = 12°C	7.16	6.03
Cdh Tj = +12 °C	0.960	0.960
Pdh Tj = Tbiv	4.42 kW	4.63 kW
COP Tj = Tbiv	2.21	1.86
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.42 kW	4.63 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.21	1.86
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		
WTOL	55 °C	55 °C
Poff	8 W	8 W

PTO	17 W	17 W
PSB	17 W	17 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.03 kW	0.25 kW
Annual energy consumption Qhe	2045 kWh	3029 kWh

Model: VWL 35/6 A 230V

Configure model	
Model name	VWL 35/6 A 230V
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	3.32 kW	4.79 kW
El input	0.69 kW	1.71 kW
COP	4.80	2.80

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Warmer Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level outdoor	51 dB(A)	54 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	208 %	153 %
Prated	3.53 kW	3.55 kW
SCOP	5.29	3.89
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	3.53 kW	3.55 kW
COP Tj = +2°C	3.42	2.31
Cdh Tj = +2 °C	0.98	0.99
Pdh Tj = +7°C	2.18 kW	2.44 kW
COP Tj = +7°C	4.97	3.37
Cdh Tj = +7 °C	0.97	0.98
Pdh Tj = 12°C	2.40 kW	2.37 kW
COP Tj = 12°C	6.45	5.11
Cdh Tj = +12 °C	0.96	0.97
Pdh Tj = Tbiv	3.53 kW	3.55 kW

COP Tj = Tbiv	3.42	2.31
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.53 kW	3.55 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.42	2.31
WTOL	55 °C	55 °C
Poff	8 W	8 W
PTO	17 W	17 W
PSB	17 W	17 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	892 kWh	1219 kWh

Colder Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level outdoor	51 dB(A)	54 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	147 %	108 %
Prated	3.34 kW	3.15 kW

SCOP	3.75	2.78
Tbiv	-15 °C	-15 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	2.11 kW	1.92 kW
COP Tj = -7°C	3.34	2.25
Cdh Tj = -7 °C	0.980	0.980
Pdh Tj = +2°C	1.78 kW	1.71 kW
COP Tj = +2°C	4.45	3.46
Cdh Tj = +2 °C	0.960	0.970
Pdh Tj = +7°C	2.16 kW	2.09 kW
COP Tj = +7°C	6.23	4.71
Cdh Tj = +7 °C	0.960	0.970
Pdh Tj = 12°C	2.49 kW	2.44 kW
COP Tj = 12°C	7.22	6.17
Cdh Tj = +12 °C	0.960	0.960
Pdh Tj = Tbiv	2.72 kW	2.57 kW
COP Tj = Tbiv	2.16	1.61
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	2.69 kW	2.43 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.06	1.46
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		
WTOL	55 °C	55 °C

Poff	8 W	8 W
PTO	17 W	17 W
PSB	17 W	17 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	3.34 kW	3.15 kW
Annual energy consumption Qhe	2192 kWh	2787 kWh
Pdh Tj = -15°C (if TOL<-20°C)		
COP Tj = -15°C (if TOL<-20°C)		
Cdh Tj = -15 °C		

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level outdoor	51 dB(A)	54 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	177 %	124 %
Prated	4.19 kW	4.18 kW
SCOP	4.50	3.18

Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	3.71 kW	3.69 kW
COP Tj = -7°C	3.04	2.08
Cdh Tj = -7 °C	0.990	0.990
Pdh Tj = +2°C	2.18 kW	2.32 kW
COP Tj = +2°C	4.40	3.01
Cdh Tj = +2 °C	0.970	0.980
Pdh Tj = +7°C	2.15 kW	2.03 kW
COP Tj = +7°C	5.96	4.28
Cdh Tj = +7 °C	0.960	0.970
Pdh Tj = 12°C	2.41 kW	2.42 kW
COP Tj = 12°C	7.04	5.84
Cdh Tj = +12 °C	0.960	0.960
Pdh Tj = Tbiv	3.71 kW	3.69 kW
COP Tj = Tbiv	3.04	2.08
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.34 kW	3.31 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.51	1.81
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		
WTOL	55 °C	55 °C
Poff	8 W	8 W

PTO	17 W	17 W
PSB	17 W	17 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.85 kW	0.87 kW
Annual energy consumption Qhe	1923 kWh	2715 kWh

Model: VWL 35/6 A 230V S2

Configure model	
Model name	VWL 35/6 A 230V S2
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	3.32 kW	4.79 kW
El input	0.69 kW	1.71 kW
COP	4.80	2.80

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Warmer Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level outdoor	51 dB(A)	54 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	200 %	148 %
Prated	3.53 kW	3.55 kW
SCOP	5.08	3.78
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	3.53 kW	3.55 kW
COP Tj = +2°C	3.42	2.31
Cdh Tj = +2 °C	0.98	0.99
Pdh Tj = +7°C	2.18 kW	2.44 kW
COP Tj = +7°C	4.97	3.37
Cdh Tj = +7 °C	0.97	0.98
Pdh Tj = 12°C	2.40 kW	2.37 kW
COP Tj = 12°C	6.45	5.11
Cdh Tj = +12 °C	0.96	0.97
Pdh Tj = Tbiv	3.53 kW	3.55 kW

COP Tj = Tbiv	3.42	2.31
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.53 kW	3.55 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.42	2.31
WTOL	55 °C	55 °C
Poff	8 W	8 W
PTO	17 W	17 W
PSB	17 W	17 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	928 kWh	1255 kWh

Colder Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level outdoor	51 dB(A)	54 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	146 %	108 %
Prated	3.34 kW	3.15 kW

SCOP	3.72	2.77
Tbiv	-15 °C	-15 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	2.11 kW	1.92 kW
COP Tj = -7°C	3.34	2.25
Cdh Tj = -7 °C	0.980	0.980
Pdh Tj = +2°C	1.78 kW	1.71 kW
COP Tj = +2°C	4.45	3.46
Cdh Tj = +2 °C	0.960	0.970
Pdh Tj = +7°C	2.16 kW	2.09 kW
COP Tj = +7°C	6.23	4.71
Cdh Tj = +7 °C	0.960	0.970
Pdh Tj = 12°C	2.49 kW	2.44 kW
COP Tj = 12°C	7.22	6.17
Cdh Tj = +12 °C	0.960	0.960
Pdh Tj = Tbiv	2.72 kW	2.57 kW
COP Tj = Tbiv	2.16	1.61
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	2.69 kW	2.43 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.06	1.46
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		
WTOL	55 °C	55 °C

Poff	8 W	8 W
PTO	17 W	17 W
PSB	17 W	17 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	3.34 kW	3.15 kW
Annual energy consumption Qhe	2210 kWh	2805 kWh
Pdh Tj = -15°C (if TOL<-20°C)		
COP Tj = -15°C (if TOL<-20°C)		
Cdh Tj = -15 °C		

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level outdoor	51 dB(A)	54 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	174 %	123 %
Prated	4.19 kW	4.18 kW
SCOP	4.43	3.14

Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	3.71 kW	3.69 kW
COP Tj = -7°C	3.04	2.08
Cdh Tj = -7 °C	0.990	0.990
Pdh Tj = +2°C	2.18 kW	2.32 kW
COP Tj = +2°C	4.40	3.01
Cdh Tj = +2 °C	0.970	0.980
Pdh Tj = +7°C	2.15 kW	2.03 kW
COP Tj = +7°C	5.96	4.28
Cdh Tj = +7 °C	0.960	0.970
Pdh Tj = 12°C	2.41 kW	2.42 kW
COP Tj = 12°C	7.04	5.84
Cdh Tj = +12 °C	0.960	0.960
Pdh Tj = Tbiv	3.71 kW	3.69 kW
COP Tj = Tbiv	3.04	2.08
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.34 kW	3.31 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.51	1.81
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		
WTOL	55 °C	55 °C
Poff	8 W	8 W

PTO	17 W	17 W
PSB	17 W	17 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.85 kW	0.87 kW
Annual energy consumption Qhe	1953 kWh	2745 kWh

Model: VWL 45/6 A 230V S3

Configure model	
Model name	VWL 45/6 A 230V S3
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	4.07 kW	3.64 kW
El input	0.89 kW	1.28 kW
COP	4.59	2.83

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Warmer Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level outdoor	50 dB(A)	52 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	220 %	155 %
Prated	3.40 kW	3.43 kW
SCOP	5.57	3.94
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	3.44 kW	3.43 kW
COP Tj = +2°C	3.36	2.28
Cdh Tj = +2 °C	0.98	0.99
Pdh Tj = +7°C	2.33 kW	2.16 kW
COP Tj = +7°C	5.21	3.39
Cdh Tj = +7 °C	0.97	0.98
Pdh Tj = 12°C	2.57 kW	2.45 kW
COP Tj = 12°C	7.00	5.25
Cdh Tj = +12 °C	0.96	0.97
Pdh Tj = Tbiv	3.44 kW	3.43 kW

COP Tj = Tbiv	3.36	2.28
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.44 kW	3.43 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.36	2.28
WTOL	75 °C	75 °C
Poff	8 W	8 W
PTO	17 W	17 W
PSB	17 W	17 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	815 kWh	1164 kWh

Colder Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level outdoor	50 dB(A)	52 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	152 %	113 %
Prated	4.00 kW	3.48 kW

SCOP	3.87	2.90
Tbiv	-15 °C	-15 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	2.42 kW	2.12 kW
COP Tj = -7°C	3.26	2.40
Cdh Tj = -7 °C	0.980	0.980
Pdh Tj = +2°C	1.92 kW	1.76 kW
COP Tj = +2°C	4.80	3.53
Cdh Tj = +2 °C	0.960	0.970
Pdh Tj = +7°C	2.26 kW	2.14 kW
COP Tj = +7°C	6.27	4.81
Cdh Tj = +7 °C	0.960	0.970
Pdh Tj = 12°C	2.59 kW	2.57 kW
COP Tj = 12°C	7.39	6.27
Cdh Tj = +12 °C	0.960	0.960
Pdh Tj = Tbiv	3.11 kW	2.84 kW
COP Tj = Tbiv	2.37	1.76
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	2.66 kW	2.41 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.02	1.47
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		
WTOL	75 °C	75 °C

Poff	8 W	8 W
PTO	17 W	17 W
PSB	17 W	17 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	4.00 kW	3.48 kW
Annual energy consumption Qhe	2543 kWh	2959 kWh
Pdh Tj = -15°C (if TOL<-20°C)		
COP Tj = -15°C (if TOL<-20°C)		
Cdh Tj = -15 °C		

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level outdoor	50 dB(A)	52 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	180 %	131 %
Prated	4.13 kW	4.22 kW
SCOP	4.56	3.34

Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	3.65 kW	3.73 kW
COP Tj = -7°C	2.97	2.12
Cdh Tj = -7 °C	0.990	0.990
Pdh Tj = +2°C	2.20 kW	2.28 kW
COP Tj = +2°C	4.48	3.24
Cdh Tj = +2 °C	0.970	0.980
Pdh Tj = +7°C	2.23 kW	2.11 kW
COP Tj = +7°C	6.02	4.45
Cdh Tj = +7 °C	0.960	0.970
Pdh Tj = 12°C	2.59 kW	2.54 kW
COP Tj = 12°C	7.39	5.97
Cdh Tj = +12 °C	0.960	0.960
Pdh Tj = Tbiv	3.65 kW	3.73 kW
COP Tj = Tbiv	2.97	2.12
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.65 kW	3.35 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.65	1.86
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		
WTOL	75 °C	75 °C
Poff	8 W	8 W

PTO	17 W	17 W
PSB	17 W	17 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.48 kW	0.87 kW
Annual energy consumption Qhe	1870 kWh	2606 kWh