

| Summary of | CTC GSi 612 | Reg. No. | 012-C700087 | |
|----------------------------|-----------------------|-------------|-------------|--|
| Certificate Holder | - | | | |
| Name | Enertech CTC AB | | | |
| Address | Box 309, Näsvägen | Zip | SE-381 26 | |
| City | Ljungby | Country | Sweden | |
| Certification Body | RISE CERT | · | · | |
| Name of testing laboratory | RISE | | | |
| Subtype title | CTC GSi 612 | CTC GSi 612 | | |
| Heat Pump Type | Brine/Water | Brine/Water | | |
| Refrigerant | R407c | R407c | | |
| Mass Of Refrigerant | 2.4 kg | 2.4 kg | | |
| Certification Date | 30.11.2020 | | | |
| Testing basis | HP Keymark Scheme 201 | L 7 | | |

Model: CTC GSi 612

| General Data | | |
|------------------|-------------|--|
| Power supply | 3x400V 50Hz | |
| Off-peak product | No | |

Heating

| EN 14511-2 | | |
|------------------------|-----------------|--------------------|
| | Low temperature | Medium temperature |
| Heat output | 6.08 kW | 5.24 kW |
| El input | 1.27 kW | 1.78 kW |
| СОР | 4.78 | 2.95 |
| Indoor water flow rate | 1.05 m³/h | 0.57 m³/h |

| EN 14511-4 | |
|--|--------|
| Shutting off the heat transfer medium flow | passed |
| Complete power supply failure | passed |

Average Climate

| EN 12102-1 | | |
|--------------------------|-----------------|--------------------|
| | Low temperature | Medium temperature |
| Sound power level indoor | 39 dB(A) | 39 dB(A) |





EN 14825

| | Low temperature | Medium temperature |
|---------------|-----------------|--------------------|
| η_{s} | 208 % | 155 % |
| Prated | 9.81 kW | 6.80 kW |
| SCOP | 5.40 | 4.10 |
| Tbiv | -10 °C | -10 °C |
| TOL | -10 °C | -10 °C |
| Pdh Tj = -7°C | 8.80 kW | 6.00 kW |
| COP Tj = -7°C | 4.59 | 3.25 |
| Pdh Tj = +2°C | 5.40 kW | 3.70 kW |
| COP Tj = +2°C | 5.60 | 4.18 |
| Pdh Tj = +7°C | 3.50 kW | 2.40 kW |
| COP Tj = +7°C | 6.05 | 4.70 |
| Pdh Tj = 12°C | 2.40 kW | 2.40 kW |
| COP Tj = 12°C | 6.03 | 5.34 |
| Pdh Tj = Tbiv | 9.80 kW | 6.70 kW |
| COP Tj = Tbiv | 4.30 | 3.00 |
| Pdh Tj = TOL | 9.94 kW | 6.66 kW |
| COP Tj = TOL | 4.28 | 2.99 |
| Cdh | 0.97 | 0.98 |
| WTOL | 65 °C | 65 °C |

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com





| Poff | 23 W | 23 W |
|--|-------------|-------------|
| РТО | o w | 6 W |
| PSB | o w | o w |
| PCK | o w | o w |
| Supplementary Heater: Type of energy input | electricity | electricity |
| Supplementary Heater: PSUP | 0.10 kW | 0.10 kW |
| Annual energy consumption Qhe | 3800 kWh | 3444 kWh |

Colder Climate

| EN 12102-1 | | |
|--------------------------|-----------------|--------------------|
| | Low temperature | Medium temperature |
| Sound power level indoor | 39 dB(A) | 39 dB(A) |

| EN 14825 | | |
|---------------|-----------------|--------------------|
| | Low temperature | Medium temperature |
| η_{s} | 208 % | 155 % |
| Prated | 11.40 kW | 7.20 kW |
| SCOP | 5.50 | 4.30 |
| Tbiv | -22 °C | -22 °C |
| TOL | -22 °C | -22 °C |
| Pdh Tj = -7°C | 7.00 kW | 4.46 kW |





| <u>, </u> | |
|--|---|
| 5.33 | 4.01 |
| 4.20 kW | 2.70 kW |
| 5.90 | 4.66 |
| 2.80 kW | 2.40 kW |
| 5.95 | 5.17 |
| 2.40 kW | 2.40 kW |
| 5.74 | 5.51 |
| 11.50 kW | 7.50 kW |
| 3.93 | 2.86 |
| 11.45 kW | 7.54 kW |
| 3.93 | 2.86 |
| 0.96 | 0.98 |
| 65 °C | 65 °C |
| 13 W | 23 W |
| 34 W | o w |
| 0 W | o w |
| 0 W | o w |
| electricity | electricity |
| 0.00 kW | 0.00 kW |
| 3800 kWh | 3444 kWh |
| | 4.20 kW 5.90 2.80 kW 5.95 2.40 kW 5.74 11.50 kW 3.93 11.45 kW 3.93 0.96 65 °C 13 W 34 W 0 W electricity 0.00 kW |

Domestic Hot Water (DHW)



Average Climate

| EN 16147 | | |
|---------------------------------|------------|--|
| Declared load profile | XL | |
| Efficiency ηDHW | 100 % | |
| СОР | 2.50 | |
| Heating up time | 1:45 h:min | |
| Standby power input | 59.0 W | |
| Reference hot water temperature | 49.5 °C | |
| Mixed water at 40°C | 235 I | |

Colder Climate

| EN 16147 | | |
|---------------------------------|------------|--|
| Declared load profile | XL | |
| Efficiency ηDHW | 100 % | |
| COP | 2.50 | |
| | | |
| Heating up time | 1:45 h:min | |
| Standby power input | 59.0 W | |
| Reference hot water temperature | 49.5 °C | |
| Mixed water at 40°C | 235 I | |



Model: CTC EcoPart 612M

| General Data | | |
|--------------|-------------|--|
| Power supply | 3x400V 50Hz | |

Heating

| EN 14511-2 | | | |
|------------------------|-----------------|--------------------|--|
| | Low temperature | Medium temperature | |
| Heat output | 6.08 kW | 5.24 kW | |
| El input | 1.27 kW | 1.78 kW | |
| СОР | 4.78 | 2.95 | |
| Indoor water flow rate | 1.05 m³/h | 0.57 m³/h | |

| EN 14511-4 | | |
|--|--------|--|
| Shutting off the heat transfer medium flow | passed | |
| Complete power supply failure | passed | |

Average Climate

| EN 12102-1 | | | |
|--------------------------|-----------------|--------------------|--|
| | Low temperature | Medium temperature | |
| Sound power level indoor | 39 dB(A) | 39 dB(A) | |





EN 14825

| | Low temperature | Medium temperature |
|---------------|-----------------|--------------------|
| η_{s} | 208 % | 155 % |
| Prated | 9.81 kW | 6.80 kW |
| SCOP | 5.40 | 4.10 |
| Tbiv | -10 °C | -10 °C |
| TOL | -10 °C | -10 °C |
| Pdh Tj = -7°C | 8.80 kW | 6.00 kW |
| COP Tj = -7°C | 4.59 | 3.25 |
| Pdh Tj = +2°C | 5.40 kW | 3.70 kW |
| COP Tj = +2°C | 5.60 | 4.18 |
| Pdh Tj = +7°C | 3.50 kW | 2.40 kW |
| COP Tj = +7°C | 6.05 | 4.70 |
| Pdh Tj = 12°C | 2.40 kW | 2.40 kW |
| COP Tj = 12°C | 6.03 | 5.34 |
| Pdh Tj = Tbiv | 9.80 kW | 6.70 kW |
| COP Tj = Tbiv | 4.30 | 3.00 |
| Pdh Tj = TOL | 9.94 kW | 6.66 kW |
| COP Tj = TOL | 4.28 | 2.99 |
| Cdh | 0.97 | 0.98 |
| WTOL | 65 °C | 65 °C |





| Poff | 23 W | 23 W |
|--|-------------|-------------|
| РТО | o w | 6 W |
| PSB | o w | o w |
| PCK | 0 W | 0 W |
| Supplementary Heater: Type of energy input | electricity | electricity |
| Supplementary Heater: PSUP | 0.10 kW | 0.10 kW |
| Annual energy consumption Qhe | 3800 kWh | 3444 kWh |

Colder Climate

| EN 12102-1 | | |
|--------------------------|-----------------|--------------------|
| | Low temperature | Medium temperature |
| Sound power level indoor | 39 dB(A) | 39 dB(A) |

| EN 14825 | | | |
|---------------|-----------------|--------------------|--|
| | Low temperature | Medium temperature | |
| η_{s} | 208 % | 155 % | |
| Prated | 11.40 kW | 7.20 kW | |
| SCOP | 5.50 | 4.30 | |
| Tbiv | -22 °C | -22 °C | |
| TOL | -22 °C | -22 °C | |
| Pdh Tj = -7°C | 7.00 kW | 4.46 kW | |

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



| This information was generated by the Hill RETMARK database on 17 Dec 2020 | | | |
|--|-------------|-------------|--|
| COP Tj = -7°C | 5.33 | 4.01 | |
| Pdh Tj = +2°C | 4.20 kW | 2.70 kW | |
| COP Tj = +2°C | 5.90 | 4.66 | |
| Pdh Tj = +7°C | 2.80 kW | 2.40 kW | |
| $COPTj = +7^{\circ}C$ | 5.95 | 5.17 | |
| Pdh Tj = 12°C | 2.40 kW | 2.40 kW | |
| COP Tj = 12°C | 5.74 | 5.51 | |
| Pdh Tj = Tbiv | 11.50 kW | 7.50 kW | |
| COP Tj = Tbiv | 3.93 | 2.86 | |
| Pdh Tj = TOL | 11.45 kW | 7.54 kW | |
| COP Tj = TOL | 3.93 | 2.86 | |
| Cdh | 0.96 | 0.98 | |
| WTOL | 65 °C | 65 °C | |
| Poff | 13 W | 23 W | |
| РТО | 34 W | o w | |
| PSB | 0 W | o w | |
| PCK | o w | o w | |
| Supplementary Heater: Type of energy input | electricity | electricity | |
| Supplementary Heater: PSUP | 0.00 kW | 0.00 kW | |
| Annual energy consumption Qhe | 3800 kWh | 3444 kWh | |
| | | | |