

Page 1 of 6

This information was generated by the HP KEYMARK database on 7 Jul 2022

Login

Summary of	VWL 85/3 A 230V	Reg. No.	40045831	
Certificate Holder				
Name	Vaillant Deutschland GmbH &	Vaillant Deutschland GmbH & Co KG		
Address	Berghauser Straße 40	Zip	42859	
City	Remscheid	Country	Germany	
Certification Body	VDE Testing and Certification I	VDE Testing and Certification Institute GmbH		
Subtype title	VWL 85/3 A 230V	VWL 85/3 A 230V		
Heat Pump Type	Outdoor Air/Water			
Refrigerant	R410A			
Mass of Refrigerant	1.95 kg			
Certification Date	22.02.2017			

This information was generated by the HP KEYMARK database on 7 Jul 2022

Model: VWL 85/3 A 230V

Configure model		
Model name	VWL 85/3 A 230V	
Application	Heating (medium temp)	
Units	Outdoor	
Climate Zone	Warmer Climate	
Reversibility	Yes	
Cooling mode application (optional)	n/a	

General Data		
Power supply	1x230V 50Hz	

Heating

EN 14511-4		
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed	
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed	
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	
Defrost test	passed	

EN 14511-2		
	Low temperature	Medium temperature
Heat output	7.07 kW	6.34 kW
El input	1.74 kW	2.38 kW
СОР	4.07	2.66

Warmer Climate

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



EN 12102-1			
	Low temperature	Medium temperature	
Sound power level indoor	60 dB(A)	60 dB(A)	
Sound power level outdoor	60 dB(A)	60 dB(A)	

EN 14825		
	Low temperature	Medium temperature
η_{s}	208 %	152 %
Prated	6.94 kW	5.49 kW
SCOP	5.27	3.87
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	6.94 kW	5.49 kW
COP Tj = +2°C	2.75	2.08
Cdh Tj = +2 °C	0.99	0.99
Pdh Tj = +7°C	4.58 kW	3.65 kW
COP Tj = +7°C	4.84	3.29
Cdh Tj = +7 °C	0.99	0.99
Pdh Tj = 12°C	3.49 kW	3.27 kW
COP Tj = 12°C	6.35	5.03
Cdh Tj = +12 °C	0.99	0.99

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com






This information was generated by the HP KEYMARK database on 7 Jul 2022

Pdh Tj = Tbiv	6.94 kW	5.49 kW
COP Tj = Tbiv	2.75	2.08
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.94 kW	5.49 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.75	2.08
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.99	0.99
WTOL	63 °C	63 °C
Poff	4 W	4 W
РТО	4 W	4 W
PSB	5 W	5 W
PCK	6 W	6 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1760 kWh	1894 kWh

Average Climate

EN 12102-1			
	Low temperature	Medium temperature	
Sound power level indoor	60 dB(A)	60 dB(A)	
Sound power level outdoor	60 dB(A)	60 dB(A)	

EN 14825





	Low temperature	Medium temperature
η_{s}	153 %	120 %
Prated	6.45 kW	3.73 kW
SCOP	3.90	3.07
Tbiv	-7 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.71 kW	3.25 kW
$COP Tj = -7^{\circ}C$	2.34	1.99
Cdh Tj = -7 °C	1.000	1.000
Pdh Tj = $+2$ °C	3.57 kW	2.22 kW
COP Tj = +2°C	3.83	2.91
Cdh Tj = $+2$ °C	0.990	0.990
Pdh Tj = $+7^{\circ}$ C	2.98 kW	2.81 kW
$COP Tj = +7^{\circ}C$	5.10	4.02
Cdh Tj = $+7$ °C	0.990	0.990
Pdh Tj = 12°C	3.54 kW	3.49 kW
COP Tj = 12°C	6.70	5.69
Cdh Tj = +12 °C	0.990	0.990
Pdh Tj = Tbiv	5.71 kW	3.73 kW
COP Tj = Tbiv	2.34	1.76
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.51 kW	3.73 kW



Page 6 of 6 This information was generated by the HP KEYMARK database on 7 Jul 2022

COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.25	1.76
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.000	1.000
WTOL	63 °C	63 °C
Poff	4 W	4 W
PTO	4 W	4 W
PSB	5 W	5 W
PCK	6 W	6 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.94 kW	0.00 kW
Annual energy consumption Qhe	3420 kWh	2508 kWh