

This information was generated by the HP KEYMARK database on 18 Mar 2022

[Login](#)

Summary of	FDCW60VNX-W	Reg. No.	012-C700109
Certificate Holder			
Name	Mitsubishi Heavy Industries Air Conditioning Europe		
Address	5 The Square	Zip	UB11 1ET
City	Uxbridge, Middlesex	Country	United Kingdom
Certification Body	RISE CERT		
Subtype title	FDCW60VNX-W		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R32		
Mass of Refrigerant	1.3 kg		
Certification Date	13.09.2021		
Testing basis	EN 14511:2018, EN 14825:2018, EN 12102:2017		

Model: FDCW60VNX-W + HSB60-W

Configure model	
Model name	FDCW60VNX-W + HSB60-W
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	5.08 kW	4.16 kW
El input	0.99 kW	1.36 kW
COP	5.16	3.06

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	33 dB(A)	33 dB(A)
Sound power level outdoor	52 dB(A)	52 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	190 %	137 %
Prated	4.80 kW	5.30 kW
SCOP	4.75	3.44
Tbiv	-10 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	4.20 kW	4.80 kW
COP Tj = -7°C	3.06	1.95
Cdh Tj = -7 °C	0.980	0.990
Pdh Tj = +2°C	2.60 kW	2.90 kW
COP Tj = +2°C	4.61	3.37
Cdh Tj = +2 °C	0.980	0.990
Pdh Tj = +7°C	1.70 kW	1.90 kW
COP Tj = +7°C	6.18	4.63
Cdh Tj = +7 °C	0.980	0.990

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = 12°C	2.70 kW	2.60 kW
COP Tj = 12°C	7.96	6.14
Cdh Tj = +12 °C	0.980	0.990
Pdh Tj = Tbiv	4.80 kW	4.80 kW
COP Tj = Tbiv	2.24	1.95
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.80 kW	4.60 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.24	1.94
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.980	0.990
WTOL	58 °C	58 °C
Poff	7 W	7 W
PTO	12 W	12 W
PSB	12 W	12 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.70 kW
Annual energy consumption Qhe	2089 kWh	3193 kWh