

Page 1 of 8

This information was generated by the HP KEYMARK database on 13 Apr 2022

<u>Login</u>

Summary of	S08L-M-CC	Reg. No.	011-1W0477
Certificate Holder			
Name	Heliotherm GmbH	Heliotherm GmbH	
Address	Sportplatzweg 18	Zip	A-6336
City	Langkampfen	Country	Austria
Certification Body	DIN CERTCO Gesellschaft	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH	
Subtype title	S08L-M-CC	S08L-M-CC	
Heat Pump Type	Outdoor Air/Water	Outdoor Air/Water	
Refrigerant	R410A	R410A	
Mass of Refrigerant	4.9 kg	4.9 kg	
Certification Date	14.12.2017	14.12.2017	
Testing basis	HP KEYMARK certification	HP KEYMARK certification scheme rules rev. 8	



Model: HELIOTHERM - Luft/Wasserwärmepumpe modulierend Baureihe Sensor Comfort Compact

Configure model		
Model name	HELIOTHERM - Luft/Wasserwärmepumpe modulierend Baureihe Sensor Comfort Compact	
Application	Heating (low temp)	
Units	Outdoor	
Climate Zone	Colder Climate + Warmer Climate	
Reversibility	No	
Cooling mode application (optional)	n/a	

General Data		
Power supply	3x400V 50Hz	

Heating

EN 14511-2		
Low temperature		
Heat output	6.87 kW	
El input	1.36 kW	
СОР	5.05	

EN 14511-4		
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	
Defrost test	passed	
Starting and operating test	passed	



Average Climate

EN 12102-1	
	Low temperature
Sound power level outdoor	48 dB(A)

EN 14825	
	Low temperature
η_{s}	177 %
Prated	10.00 kW
SCOP	4.49
Tbiv	-10 °C
TOL	-10 °C
Pdh Tj = -7°C	8.80 kW
COP Tj = -7°C	2.70
Cdh Tj = -7 °C	0.990
Pdh Tj = +2°C	5.47 kW
COP Tj = +2°C	4.55
Cdh Tj = +2 °C	0.990
Pdh Tj = +7°C	5.94 kW
COP Tj = +7°C	5.65
Cdh Tj = +7 °C	0.990

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com





	<u>'</u>
Pdh Tj = 12°C	6.71 kW
COP Tj = 12°C	7.03
Cdh Tj = +12 °C	0.990
Pdh Tj = Tbiv	10.15 kW
COP Tj = Tbiv	2.20
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.15 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.20
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.990
WTOL	62 °C
Poff	1 W
РТО	7 W
PSB	7 W
PCK	6 W
Supplementary Heater: Type of energy input	Electricity
Supplementary Heater: PSUP	0.00 kW
Annual energy consumption Qhe	4600 kWh

Warmer Climate

EN 12102-1	
	Low temperature
Sound power level outdoor	48 dB(A)





EN 14825

	Low temperature
η_{s}	230 %
Prated	10.00 kW
SCOP	5.82
Tbiv	2 °C
TOL	2 °C
Pdh Tj = +2°C	9.98 kW
COP Tj = +2°C	4.15
Cdh Tj = +2 °C	0.990
Pdh Tj = $+7^{\circ}$ C	6.42 kW
$COP Tj = +7^{\circ}C$	5.68
Cdh Tj = +7 °C	0.990
Pdh Tj = 12°C	4.61 kW
COP Tj = 12°C	6.30
Cdh Tj = +12 °C	0.990
Pdh Tj = Tbiv	9.98 kW
COP Tj = Tbiv	4.15
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.98 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.15
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.990

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com





WTOL	62 °C
Poff	1 W
РТО	7 W
PSB	7 W
PCK	6 W
Supplementary Heater: Type of energy input	Electricity
Supplementary Heater: PSUP	0.02 kW
Annual energy consumption Qhe	2405 kWh

Colder Climate

EN 12102-1	
	Low temperature
Sound power level outdoor	48 dB(A)

EN 14825	
	Low temperature
η_{S}	159 %
Prated	10.00 kW
SCOP	4.05
Tbiv	-18 °C
TOL	-22 °C
	,





This information was generated by the HF KLTV	TANK database on 15 Apr 2022
Pdh Tj = -7°C	6.17 kW
$COPTj = -7^{\circ}C$	3.65
Cdh Tj = -7 °C	0.990
Pdh Tj = +2°C	3.75 kW
COP Tj = +2°C	4.81
Cdh Tj = +2 °C	0.990
Pdh Tj = +7°C	3.88 kW
$COP Tj = +7^{\circ}C$	5.32
Cdh Tj = +7 °C	0.990
Pdh Tj = 12°C	4.67 kW
COP Tj = 12°C	6.36
Cdh Tj = +12 °C	0.990
Pdh Tj = Tbiv	8.87 kW
COP Tj = Tbiv	2.12
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.80 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	1.31
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.990
WTOL	62 °C
Poff	1 W
РТО	7 W
PSB	7 W



$$\operatorname{\textit{Page}}\xspace$ 8 of 8 This information was generated by the HP KEYMARK database on 13 Apr 2022

PCK	6 W
Supplementary Heater: Type of energy input	Electricity
Supplementary Heater: PSUP	2.20 kW
Annual energy consumption Qhe	5185 kWh
Pdh Tj = -15°C (if TOL<-20°C)	8.18
COP Tj = -15°C (if TOL $<$ -20°C)	2.37
Cdh Tj = -15 °C	0.990