

This information was generated by the HP KEYMARK database on 22 Jun 2022

[Login](#)

Summary of	LWD 70A/SX	Reg. No.	041-K001-44
Certificate Holder			
Name	ait-deutschland GmbH		
Address	Industriestr. 3	Zip	95359
City	Kasendorf	Country	Germany
Certification Body	BRE Global Limited		
Subtype title	LWD 70A/SX		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R290		
Mass of Refrigerant	1.1 kg		
Certification Date	24.11.2020		
Testing basis	HP Keymark Scheme Rules Rev 08		

Model: LWD 70A/SX-HMD

Configure model	
Model name	LWD 70A/SX-HMD
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	9.33 kW	8.49 kW
El input	2.20 kW	2.85 kW
COP	4.24	2.97

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Warmer Climate

This information was generated by the HP KEYMARK database on 22 Jun 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level outdoor	58 dB(A)	58 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	175 %	148 %
Prated	9.63 kW	8.87 kW
SCOP	4.44	3.76
Tbiv	4 °C	4 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	7.44 kW	6.80 kW
COP Tj = +2°C	3.51	2.42
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	9.43 kW	8.87 kW
COP Tj = +7°C	4.42	3.46
Cdh Tj = +7 °C	1.00	1.00
Pdh Tj = 12°C	10.89 kW	10.64 kW
COP Tj = 12°C	4.91	4.59
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	8.25 kW	7.61 kW

This information was generated by the HP KEYMARK database on 22 Jun 2022

COP $T_j = T_{biv}$	3.93	2.81
P _{dh} $T_j = TOL$ or P _{dh} $T_j = T_{designh}$ if $TOL < T_{designh}$	7.44 kW	6.80 kW
COP $T_j = TOL$ or COP $T_j = T_{designh}$ if $TOL < T_{designh}$	3.51	2.42
WTOL	62 °C	62 °C
P _{off}	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.19 kW	2.07 kW
Annual energy consumption Q _{he}	2896 kWh	3152 kWh

Colder Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level outdoor	58 dB(A)	58 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	128 %	110 %
Prated	5.99 kW	5.61 kW

This information was generated by the HP KEYMARK database on 22 Jun 2022

SCOP	3.28	2.83
Tbiv	-20 °C	-20 °C
TOL	-16 °C	-16 °C
Pdh Tj = -7°C	6.24 kW	5.97 kW
COP Tj = -7°C	2.84	2.38
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	7.60 kW	7.37 kW
COP Tj = +2°C	3.86	3.33
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	9.57 kW	9.46 kW
COP Tj = +7°C	4.61	4.37
Cdh Tj = +7 °C	1.00	1.00
Pdh Tj = 12°C	10.95 kW	11.05 kW
COP Tj = 12°C	4.70	4.80
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	5.18 kW	4.73 kW
COP Tj = Tbiv	2.33	1.85
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.05 kW	4.18 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.27	1.64
WTOL	62 °C	62 °C
Poff	10 W	10 W

This information was generated by the HP KEYMARK database on 22 Jun 2022

PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	5.99 kW	5.61 kW
Annual energy consumption Q _{he}	4508 kWh	4893 kWh
P _{dh} T _j = -15°C (if TOL<-20°C)	5.18	4.86
COP T _j = -15°C (if TOL<-20°C)	2.33	1.91
C _{dh} T _j = -15 °C	1.00	1.00

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level outdoor	58 dB(A)	58 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	144 %	121 %
Prated	8.84 kW	8.13 kW
SCOP	3.67	3.09
T _{biv}	-10 °C	-10 °C

This information was generated by the HP KEYMARK database on 22 Jun 2022

TOL	-4 °C	-4 °C
Pdh Tj = -7°C	6.18 kW	5.81 kW
COP Tj = -7°C	2.74	2.15
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	7.55 kW	7.22 kW
COP Tj = +2°C	3.76	3.05
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	9.52 kW	9.29 kW
COP Tj = +7°C	4.59	4.12
Cdh Tj = +7 °C	1.00	1.00
Pdh Tj = 12°C	10.97 kW	10.91 kW
COP Tj = 12°C	4.92	4.84
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	6.64 kW	6.25 kW
COP Tj = Tbiv	3.07	2.40
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.78 kW	5.38 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.54	1.97
WTOL	62 °C	62 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W

This information was generated by the HP KEYMARK database on 22 Jun 2022

PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.86 kW	2.75 kW
Annual energy consumption Q _{he}	4867 kWh	5440 kWh

Model: LWD 70A/SX-HTD S

Configure model	
Model name	LWD 70A/SX-HTD S
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	9.33 kW	8.49 kW
El input	2.20 kW	2.85 kW
COP	4.24	2.97

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Warmer Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level outdoor	58 dB(A)	58 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	175 %	148 %
Prated	9.63 kW	8.87 kW
SCOP	4.44	3.76
Tbiv	4 °C	4 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	7.44 kW	6.80 kW
COP Tj = +2°C	3.51	2.42
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	9.43 kW	8.87 kW
COP Tj = +7°C	4.42	3.46
Cdh Tj = +7 °C	1.00	1.00
Pdh Tj = 12°C	10.89 kW	10.64 kW
COP Tj = 12°C	4.91	4.59
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	8.25 kW	7.61 kW

This information was generated by the HP KEYMARK database on 22 Jun 2022

COP $T_j = T_{biv}$	3.93	2.81
$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	7.44 kW	6.80 kW
COP $T_j = TOL$ or COP $T_j = T_{designh}$ if $TOL < T_{designh}$	3.51	2.42
WTOL	62 °C	62 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.19 kW	2.07 kW
Annual energy consumption Q_{he}	2896 kWh	3152 kWh

Colder Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level outdoor	58 dB(A)	58 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	128 %	110 %
Prated	5.99 kW	5.61 kW

This information was generated by the HP KEYMARK database on 22 Jun 2022

SCOP	3.28	2.83
Tbiv	-20 °C	-20 °C
TOL	-16 °C	-16 °C
Pdh Tj = -7°C	6.24 kW	5.97 kW
COP Tj = -7°C	2.84	2.38
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	7.60 kW	7.37 kW
COP Tj = +2°C	3.86	3.33
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	9.57 kW	9.46 kW
COP Tj = +7°C	4.61	4.37
Cdh Tj = +7 °C	1.00	1.00
Pdh Tj = 12°C	10.95 kW	11.05 kW
COP Tj = 12°C	4.70	4.80
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	5.18 kW	4.73 kW
COP Tj = Tbiv	2.33	1.85
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.05 kW	4.18 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.27	1.64
WTOL	62 °C	62 °C
Poff	10 W	10 W

This information was generated by the HP KEYMARK database on 22 Jun 2022

PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	5.99 kW	5.61 kW
Annual energy consumption Q _{he}	4508 kWh	4893 kWh
P _{dh} T _j = -15°C (if TOL<-20°C)	5.18	4.86
COP T _j = -15°C (if TOL<-20°C)	2.33	1.91
C _{dh} T _j = -15 °C	1.00	1.00

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level outdoor	58 dB(A)	58 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	144 %	121 %
Prated	8.84 kW	8.13 kW
SCOP	3.67	3.09
T _{biv}	-10 °C	-10 °C

This information was generated by the HP KEYMARK database on 22 Jun 2022

TOL	-4 °C	-4 °C
Pdh Tj = -7°C	6.18 kW	5.81 kW
COP Tj = -7°C	2.74	2.15
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	7.55 kW	7.22 kW
COP Tj = +2°C	3.76	3.05
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	9.52 kW	9.29 kW
COP Tj = +7°C	4.59	4.12
Cdh Tj = +7 °C	1.00	1.00
Pdh Tj = 12°C	10.97 kW	10.91 kW
COP Tj = 12°C	4.92	4.84
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	6.64 kW	6.25 kW
COP Tj = Tbiv	3.07	2.40
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.78 kW	5.38 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.54	1.97
WTOL	62 °C	62 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W

This information was generated by the HP KEYMARK database on 22 Jun 2022

PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.86 kW	2.75 kW
Annual energy consumption Q _{he}	4867 kWh	5440 kWh