

This information was generated by the HP KEYMARK database on 17 Dec 2020

Summary of	THERMASTAGE Compact 06	Reg. No.	012-SC0372-19
Certificate Holder			
Name	Groupe Atlantic		
Address	44 boulevard des Etats-Unis	Zip	85000
City	La Roche Sur Yon	Country	France
Certification Body	RISE CERT		
Name of testing laboratory	RISE		
Subtype title	THERMASTAGE Compact 06		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R410a		
Mass Of Refrigerant	1.1 kg		
Certification Date	30.09.2019		

Model: THERMASTAGE Compact Duo 06

General Data

Power supply	1x230V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	3.71 kW	5.71 kW
El input	0.71 kW	2.22 kW
COP	5.09	2.54
Indoor water flow rate	0.63 m ³ /h	0.62 m ³ /h

EN 14511-4

Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	186 %	128 %
Prated	6.00 kW	5.00 kW
SCOP	4.72	3.27
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.20 kW	4.10 kW
COP Tj = -7°C	2.90	1.90
Pdh Tj = +2°C	3.50 kW	2.70 kW
COP Tj = +2°C	4.60	3.20
Pdh Tj = +7°C	1.90 kW	1.80 kW
COP Tj = +7°C	6.10	4.40
Pdh Tj = 12°C	2.40 kW	2.10 kW
COP Tj = 12°C	9.30	6.50
Pdh Tj = Tbiv	5.20 kW	4.10 kW

This information was generated by the HP KEYMARK database on 17 Dec 2020

COP $T_j = T_{biv}$	2.90	9.90
P _{dh} $T_j = TOL$	4.80 kW	3.90 kW
COP $T_j = TOL$	2.80	1.80
C _{dh}	0.90	0.90
WTOL	55 °C	55 °C
P _{off}	9 W	9 W
P _{TO}	14 W	14 W
P _{SB}	9 W	9 W
P _{CK}	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: P _{SUP}	1.10 kW	0.70 kW
Annual energy consumption Q _{he}	2588 kWh	2933 kWh

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	130 %
COP	3.26
Heating up time	1:36 h:min
Reference hot water temperature	52.5 °C
Mixed water at 40°C	243 l
Standby power input	31.0 W

Model: THERMASTAGE Compact Combi 06

General Data

Power supply	1x230V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	3.71 kW	5.71 kW
El input	0.71 kW	2.22 kW
COP	5.09	2.54
Indoor water flow rate	0.63 m ³ /h	0.62 m ³ /h

EN 14511-4

Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	186 %	128 %
Prated	6.00 kW	5.00 kW
SCOP	4.72	3.27
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.20 kW	4.10 kW
COP Tj = -7°C	2.90	1.90
Pdh Tj = +2°C	3.50 kW	2.70 kW
COP Tj = +2°C	4.60	3.20
Pdh Tj = +7°C	1.90 kW	1.80 kW
COP Tj = +7°C	6.10	4.40
Pdh Tj = 12°C	2.40 kW	2.10 kW
COP Tj = 12°C	9.30	6.50
Pdh Tj = Tbiv	5.20 kW	4.10 kW

This information was generated by the HP KEYMARK database on 17 Dec 2020

COP $T_j = T_{biv}$	2.90	9.90
P _{dh} $T_j = TOL$	4.80 kW	3.90 kW
COP $T_j = TOL$	2.80	1.80
C _{dh}	0.90	0.90
WTOL	55 °C	55 °C
P _{off}	9 W	9 W
PTO	14 W	14 W
PSB	9 W	9 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	1.10 kW	0.70 kW
Annual energy consumption Q _{he}	2588 kWh	2933 kWh