

This information was generated by the HP KEYMARK database on 8 Mar 2021

Summary of	DAITSU MONOBLOC 3D SMART 36	Reg. No.	041-K010-04
Certificate Holder			
Name	Eurofred S.A.		
Address	Marqués de Sentmenat, 97	Zip	08029
City	Barcelona	Country	Spain
Certification Body	BRE Global Limited		
Subtype title	DAITSU MONOBLOC 3D SMART 36		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R32		
Mass Of Refrigerant	2.2 kg		
Certification Date	08.03.2021		
Testing basis	Heat Pump Keymark Scheme Rules Rev 08		

# Model: AOWD-MB SMART-36K + WITD-AQUATANK MB-300-2

## General Data

Power supply	1x230V 50Hz
--------------	-------------

## Heating

### EN 14511-2

	Medium temperature
Heat output	8.50 kW
El input	3.30 kW
COP	2.57

### EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

## Average Climate

### EN 12102-1

	Medium temperature
Sound power level outdoor	69 dB(A)

This information was generated by the HP KEYMARK database on 8 Mar 2021

<b>EN 14825</b>	
	<b>Medium temperature</b>
$\eta_s$	126 %
Prated	8.00 kW
SCOP	3.22
Tbiv	-7 °C
TOL	-10 °C
Pdh Tj = -7°C	7.10 kW
COP Tj = -7°C	1.98
Cdh	0.980
Pdh Tj = +2°C	4.50 kW
COP Tj = +2°C	3.15
Cdh	0.980
Pdh Tj = +7°C	5.73 kW
COP Tj = +7°C	4.30
Cdh	0.980
Pdh Tj = 12°C	6.40 kW
COP Tj = 12°C	5.50
Cdh	0.980
Pdh Tj = Tbiv	7.10 kW
COP Tj = Tbiv	1.98

This information was generated by the HP KEYMARK database on 8 Mar 2021

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	1.70
WTOL	55 °C
Poff	18 W
PTO	18 W
PSB	18 W
PCK	0 W
Supplementary Heater: Type of energy input	electricity
Supplementary Heater: PSUP	0.00 kW
Annual energy consumption Qhe	5128 kWh

## Domestic Hot Water (DHW)

### Average Climate

<b>EN 16147</b>	
Declared load profile	XL
Efficiency $\eta_{DHW}$	110 %
COP	2.62
Heating up time	1:52 h:min
Standby power input	62.6 W
Reference hot water temperature	52.8 °C
Mixed water at 40°C	372 l

# Model: AOWD-MB SMART-36TK + WITD-AQUATANK MB-300-3

## General Data

Power supply	3x400V 50Hz
--------------	-------------

## Heating

### EN 14511-2

	Medium temperature
Heat output	8.50 kW
El input	3.30 kW
COP	2.57

### EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

## Average Climate

### EN 12102-1

	Medium temperature
Sound power level outdoor	69 dB(A)

This information was generated by the HP KEYMARK database on 8 Mar 2021

<b>EN 14825</b>	
	<b>Medium temperature</b>
$\eta_s$	126 %
Prated	8.00 kW
SCOP	3.22
Tbiv	-7 °C
TOL	-10 °C
Pdh Tj = -7°C	7.10 kW
COP Tj = -7°C	1.98
Cdh	0.980
Pdh Tj = +2°C	4.50 kW
COP Tj = +2°C	3.15
Cdh	0.980
Pdh Tj = +7°C	5.73 kW
COP Tj = +7°C	4.30
Cdh	0.980
Pdh Tj = 12°C	6.40 kW
COP Tj = 12°C	5.50
Cdh	0.980
Pdh Tj = Tbiv	7.10 kW
COP Tj = Tbiv	1.98

This information was generated by the HP KEYMARK database on 8 Mar 2021

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	1.70
WTOL	55 °C
Poff	18 W
PTO	18 W
PSB	18 W
PCK	0 W
Supplementary Heater: Type of energy input	electricity
Supplementary Heater: PSUP	0.00 kW
Annual energy consumption Qhe	5128 kWh

## Domestic Hot Water (DHW)

### Average Climate

<b>EN 16147</b>	
Declared load profile	XL
Efficiency $\eta_{DHW}$	110 %
COP	2.62
Heating up time	1:52 h:min
Standby power input	62.6 W
Reference hot water temperature	52.8 °C
Mixed water at 40°C	372 l