

This information was generated by the HP KEYMARK database on 18 Mar 2022

[Login](#)

| | | | |
|---------------------|-------------------------------|----------|---------------|
| Summary of | Alféa Extensa A.I. 6 R32 | Reg. No. | 012-SC0367-19 |
| Certificate Holder | | | |
| Name | Groupe Atlantic | | |
| Address | 44 boulevard des Etats-Unis | Zip | 85000 |
| City | La Roche Sur Yon | Country | France |
| Certification Body | RISE CERT | | |
| Subtype title | Alféa Extensa A.I. 6 R32 | | |
| Heat Pump Type | Outdoor Air/Water | | |
| Refrigerant | R32 | | |
| Mass of Refrigerant | 0.97 kg | | |
| Certification Date | 04.10.2019 | | |
| Testing basis | HP Keymark Scheme Rules rev 7 | | |

Model: Alféa Extensa A.I. 6 R32

| Configure model | |
|-------------------------------------|--------------------------|
| Model name | Alféa Extensa A.I. 6 R32 |
| Application | Heating (medium temp) |
| Units | Indoor + Outdoor |
| Climate Zone | n/a |
| Reversibility | No |
| Cooling mode application (optional) | n/a |

| General Data | |
|--------------|-------------|
| Power supply | 1x230V 50Hz |

Heating

| EN 14511-4 | |
|--|--------|
| Shutting off the heat transfer medium flow | passed |
| Complete power supply failure | passed |
| Defrost test | passed |
| Starting and operating test | passed |

| EN 14511-2 | | |
|-------------|-----------------|--------------------|
| | Low temperature | Medium temperature |
| Heat output | 5.50 kW | 5.50 kW |
| El input | 1.18 kW | 2.06 kW |
| COP | 4.65 | 2.67 |

Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 12102-1

| | Low temperature | Medium temperature |
|---------------------------|-----------------|--------------------|
| Sound power level indoor | 40 dB(A) | 40 dB(A) |
| Sound power level outdoor | 57 dB(A) | 57 dB(A) |

EN 14825

| | Low temperature | Medium temperature |
|----------------|-----------------|--------------------|
| η_s | 175 % | 125 % |
| Prated | 6.00 kW | 5.00 kW |
| SCOP | 4.46 | 3.21 |
| Tbiv | -7 °C | -7 °C |
| TOL | -10 °C | -10 °C |
| Pdh Tj = -7°C | 5.00 kW | 4.70 kW |
| COP Tj = -7°C | 2.74 | 1.97 |
| Cdh Tj = -7 °C | 0.96 | 0.97 |
| Pdh Tj = +2°C | 3.00 kW | 2.90 kW |
| COP Tj = +2°C | 4.68 | 3.11 |
| Cdh Tj = +2 °C | 0.96 | 0.97 |
| Pdh Tj = +7°C | 2.10 kW | 1.80 kW |
| COP Tj = +7°C | 6.04 | 4.29 |
| Cdh Tj = +7 °C | 0.96 | 0.97 |

This information was generated by the HP KEYMARK database on 18 Mar 2022

| | | |
|---|-------------|-------------|
| Pdh Tj = 12°C | 2.40 kW | 2.30 kW |
| COP Tj = 12°C | 7.43 | 6.06 |
| Cdh Tj = +12 °C | 0.96 | 0.97 |
| Pdh Tj = Tbiv | 5.00 kW | 4.70 kW |
| COP Tj = Tbiv | 2.74 | 1.97 |
| Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 4.50 kW | 4.00 kW |
| COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh | 2.67 | 1.73 |
| WTOL | 55 °C | 55 °C |
| Poff | 4 W | 4 W |
| PTO | 12 W | 13 W |
| PSB | 10 W | 10 W |
| PCK | 0 W | 0 W |
| Supplementary Heater: Type of energy input | Electricity | Electricity |
| Supplementary Heater: PSUP | 1.10 kW | 1.30 kW |
| Annual energy consumption Qhe | 2594 kWh | 3411 kWh |

Model: Alféa Extensa A.I. Duo 6 R32

| Configure model | |
|-------------------------------------|------------------------------|
| Model name | Alféa Extensa A.I. Duo 6 R32 |
| Application | Heating + DHW + low temp |
| Units | Indoor + Outdoor |
| Climate Zone | n/a |
| Reversibility | No |
| Cooling mode application (optional) | n/a |

| General Data | |
|--------------|-------------|
| Power supply | 1x230V 50Hz |

Heating

| EN 14511-4 | |
|--|--------|
| Shutting off the heat transfer medium flow | passed |
| Complete power supply failure | passed |
| Defrost test | passed |
| Starting and operating test | passed |

| EN 14511-2 | | |
|-------------|-----------------|--------------------|
| | Low temperature | Medium temperature |
| Heat output | 5.50 kW | 5.50 kW |
| El input | 1.18 kW | 2.06 kW |
| COP | 4.65 | 2.67 |

Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 12102-1

| | Low temperature | Medium temperature |
|---------------------------|-----------------|--------------------|
| Sound power level indoor | 40 dB(A) | 40 dB(A) |
| Sound power level outdoor | 57 dB(A) | 57 dB(A) |

EN 14825

| | Low temperature | Medium temperature |
|----------------|-----------------|--------------------|
| η_s | 175 % | 125 % |
| Prated | 6.00 kW | 5.00 kW |
| SCOP | 4.46 | 3.21 |
| Tbiv | -7 °C | -7 °C |
| TOL | -10 °C | -10 °C |
| Pdh Tj = -7°C | 5.00 kW | 4.70 kW |
| COP Tj = -7°C | 2.74 | 1.97 |
| Cdh Tj = -7 °C | 0.96 | 0.97 |
| Pdh Tj = +2°C | 3.00 kW | 2.90 kW |
| COP Tj = +2°C | 4.68 | 3.11 |
| Cdh Tj = +2 °C | 0.96 | 0.97 |
| Pdh Tj = +7°C | 2.10 kW | 1.80 kW |
| COP Tj = +7°C | 6.04 | 4.29 |
| Cdh Tj = +7 °C | 0.96 | 0.97 |

This information was generated by the HP KEYMARK database on 18 Mar 2022

| | | |
|---|-------------|-------------|
| Pdh Tj = 12°C | 2.40 kW | 2.30 kW |
| COP Tj = 12°C | 7.43 | 6.06 |
| Cdh Tj = +12 °C | 0.96 | 0.97 |
| Pdh Tj = Tbiv | 5.00 kW | 4.70 kW |
| COP Tj = Tbiv | 2.74 | 1.97 |
| Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 4.50 kW | 4.00 kW |
| COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh | 2.67 | 1.73 |
| WTOL | 55 °C | 55 °C |
| Poff | 4 W | 4 W |
| PTO | 12 W | 13 W |
| PSB | 10 W | 10 W |
| PCK | 0 W | 0 W |
| Supplementary Heater: Type of energy input | Electricity | Electricity |
| Supplementary Heater: PSUP | 1.10 kW | 1.30 kW |
| Annual energy consumption Qhe | 2594 kWh | 3411 kWh |

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

| EN 16147 | |
|---------------------------------|------------|
| Declared load profile | L |
| Efficiency η_{DHW} | 130 % |
| COP | 3.10 |
| Heating up time | 1:35 h:min |
| Standby power input | 30.0 W |
| Reference hot water temperature | 54.0 °C |
| Mixed water at 40°C | 245 l |