

Page 1 of 4

This information was generated by the HP KEYMARK database on 18 Mar 2022

Login

Summary of	BoxAir Inverter BA37I	Reg. No.	037-0065-21
Certificate Holder			
Name	Master Therm tepelna cerpadla s.r.o.		
Address	Vaclavske namesti 819/43	Zip	110 00
City	Praha	Country	Czech Republic
Certification Body	SZU - Strojirensky zkusebni ustav (Engineering Test Institute, Public Enterprise)		
Subtype title	BoxAir Inverter BA37I		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R32		
Mass of Refrigerant	2.7 kg		
Certification Date	26.01.2021		
Testing basis	HP Keymark scheme rules rev. no. 7		



This information was generated by the HP KEYMARK database on 18 Mar 2022

Model: BoxAir Inverter BA37I

Configure model			
Model name	BoxAir Inverter BA37I		
Application	Heating (medium temp)		
Units	Outdoor		
Climate Zone	n/a		
Reversibility	Yes		
Cooling mode application (optional)	n/a		

General Data		
Power supply	3x400V 50Hz	

Heating

EN 14511-2			
	Low temperature	Medium temperature	
Heat output	11.46 kW	10.34 kW	
El input	2.38 kW	3.32 kW	
СОР	4.80	3.12	

EN 14511-4		
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	
Defrost test	passed	
Starting and operating test	passed	

Average Climate



This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 12102-1		
	Low temperature	Medium temperature
Sound power level outdoor	58 dB(A)	58 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_{s}	195 %	153 %
Prated	11.25 kW	10.10 kW
SCOP	4.95	3.89
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	9.96 kW	8.93 kW
COP Tj = -7°C	2.91	2.22
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	5.84 kW	5.62 kW
COP Tj = +2°C	4.84	3.83
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	3.76 kW	3.56 kW
$COP Tj = +7^{\circ}C$	6.79	5.38
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	3.14 kW	2.99 kW

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



Page 4 of 4 This information was generated by the HP KEYMARK database on 18 Mar 2022

COP Tj = 12°C	8.32	6.52
Cdh Tj = +12 °C	0.95	0.96
Pdh Tj = Tbiv	9.96 kW	8.93 kW
COP Tj = Tbiv	2.91	2.22
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.56 kW	8.68 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.66	2.01
WTOL	60 °C	60 °C
Poff	19 W	19 W
РТО	19 W	19 W
PSB	19 W	19 W
PCK	o w	o w
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.69 kW	1.41 kW
Annual energy consumption Qhe	4697 kWh	5356 kWh