

This information was generated by the HP KEYMARK database on 18 Mar 2022

[Login](#)

Summary of	HPS.Z 8kW/230 V	Reg. No.	011-1W0438
Certificate Holder			
Name	Kospel SP. z o.o.		
Address	ul. Olchowa 1	Zip	75-136
City	Koszalin	Country	Poland
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Subtype title	HPS.Z 8kW/230 V		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R32		
Mass of Refrigerant	1.6 kg		
Certification Date	15.12.2021		
Testing basis	HP KEYMARK certification scheme rules rev. 9		

Model: HPSO-8/230 + HPSI-6

Configure model	
Model name	HPSO-8/230 + HPSI-6
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	8.13 kW	9.67 kW
El input	1.74 kW	3.61 kW
COP	4.66	2.69

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	41 dB(A)	41 dB(A)
Sound power level outdoor	64 dB(A)	64 dB(A)

EN 14825

		Low temperature	Medium temperature
P _{designh}	6.70 kW		
η_s	176 %	125 %	
P _{rated}	6.40 kW	6.70 kW	
SCOP	4.46	3.20	
T _{biv}	-8 °C	-7 °C	
TOL	-20 °C	-20 °C	
P _{dh} T _j = -7°C	6.24 kW	5.93 kW	
COP T _j = -7°C	2.74	1.95	
C _{dh} T _j = -7 °C	0.99	0.99	
P _{dh} T _j = +2°C	4.25 kW	3.60 kW	
COP T _j = +2°C	4.25	2.90	
C _{dh} T _j = +2 °C	0.99	0.99	
P _{dh} T _j = +7°C	5.09 kW	6.94 kW	
COP T _j = +7°C	6.19	4.93	

This information was generated by the HP KEYMARK database on 18 Mar 2022

Cdh Tj = +7 °C	0.99	0.99
Pdh Tj = 12°C	5.96 kW	6.69 kW
COP Tj = 12°C	8.88	7.34
Cdh Tj = +12 °C	0.99	0.99
Pdh Tj = Tbiv	5.91 kW	5.93 kW
COP Tj = Tbiv	2.63	1.95
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.99 kW	4.74 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.19	1.56
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.99	0.99
WTOL	55 °C	55 °C
Poff	15 W	15 W
PTO	0 W	0 W
PSB	0 W	0 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.41 kW	1.96 kW
Backup Heater	0.00 kW	
Annual energy consumption Qhe	13206 kWh	13788 kWh

Warmer Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	41 dB(A)	41 dB(A)
Sound power level outdoor	64 dB(A)	64 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	238 %	159 %
Prated	8.80 kW	8.40 kW
SCOP	6.03	4.06
Tbiv	2 °C	2 °C
TOL	-20 °C	-20 °C
Pdh Tj = +2°C	8.77 kW	8.37 kW
COP Tj = +2°C	3.40	2.28
Cdh Tj = +2 °C	0.99	0.99
Pdh Tj = +7°C	7.53 kW	6.67 kW
COP Tj = +7°C	5.36	3.38
Cdh Tj = +7 °C	0.99	0.99
Pdh Tj = 12°C	5.90 kW	5.38 kW
COP Tj = 12°C	8.09	5.62
Cdh Tj = +12 °C	0.99	0.99

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = Tbiv	8.77 kW	8.37 kW
COP Tj = Tbiv	3.40	2.28
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.77 kW	8.37 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.40	2.28
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.99	0.99
WTOL	55 °C	55 °C
Poff	15 W	15 W
PTO	0 W	0 W
PSB	0 W	0 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	11720 kWh	11186 kWh

Colder Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	41 dB(A)	41 dB(A)
Sound power level outdoor	64 dB(A)	64 dB(A)

EN 14825

This information was generated by the HP KEYMARK database on 18 Mar 2022

	Low temperature	Medium temperature
η_s	141 %	98 %
Prated	6.80 kW	6.10 kW
SCOP	3.60	2.53
Tbiv	-15 °C	-15 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	4.69 kW	4.20 kW
COP Tj = -7°C	2.97	2.09
Cdh Tj = -7 °C	0.99	0.99
Pdh Tj = +2°C	4.16 kW	3.65 kW
COP Tj = +2°C	4.61	3.18
Cdh Tj = +2 °C	0.99	0.99
Pdh Tj = +7°C	5.14 kW	4.78 kW
COP Tj = +7°C	6.68	5.03
Cdh Tj = +7 °C	0.99	0.99
Pdh Tj = 12°C	6.00 kW	5.75 kW
COP Tj = 12°C	8.83	7.30
Cdh Tj = +12 °C	0.99	0.99
Pdh Tj = Tbiv	5.52 kW	4.95 kW
COP Tj = Tbiv	2.13	1.47
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.30 kW	1.06 kW

This information was generated by the HP KEYMARK database on 18 Mar 2022

COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	1.21	0.32
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.99	0.99
WTOL	55 °C	55 °C
Poff	15 W	15 W
PTO	0 W	0 W
PSB	0 W	0 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	6.77 kW	6.07 kW
Annual energy consumption Qhe	16466 kWh	14650 kWh