Login

Summary of	LW 140	Reg. No.	041-K001-38
Certificate Holder			
Name	ait-deutschland GmbH		
Address	Industriestr. 3	Zip	95359
City	Kasendorf	Country	Germany
Certification Body	BRE Global Limited		
Subtype title	LW 140		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R407c		
Mass of Refrigerant	10.2 kg		
Certification Date	08.10.2019		

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Model: LW 140 (L)

Configure model	
Model name	LW 140 (L)
Application	Heating (medium temp)
Units	Indoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	14.38 kW	13.74 kW
El input	3.26 kW	4.70 kW
COP	4.30	2.83

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Starting and operating test	passed

Average Climate

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	58 dB(A)	58 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	157 %	125 %
Prated	14.43 kW	13.71 kW
SCOP	4.00	3.20
Tbiv	-5 °C	-5 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	11.00 kW	10.40 kW
COP Tj = -7°C	3.13	2.16
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	13.90 kW	13.49 kW
COP Tj = +2°C	3.94	3.10
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	14.53 kW	14.35 kW
COP Tj = +7°C	4.94	4.28
Cdh Tj = +7 °C	1.00	1.00
Pdh Tj = 12°C	16.37 kW	16.34 kW

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

COP Tj = 12°C	5.43	5.27
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	11.66 kW	11.07 kW
COP Tj = Tbiv	3.34	2.34
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.15 kW	9.58 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.87	1.96
WTOL	50 °C	50 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	4.28 kW	4.13 kW
Annual energy consumption Qhe	7447 kWh	8842 kWh

Warmer Climate

EN 14825		
	Low temperature	**Medium temperature**
η_s	190 %	152 %
Prated	16.43 kW	15.64 kW
SCOP	4.82	3.88

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Tbiv	4 °C	4 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	13.79 kW	12.95 kW
COP Tj = +2°C	3.66	2.38
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	14.46 kW	14.03 kW
COP Tj = +7°C	4.71	3.46
Cdh Tj = +7 °C	1.00	1.00
Pdh Tj = 12°C	16.32 kW	16.17 kW
COP Tj = 12°C	5.33	4.80
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	14.08 kW	13.40 kW
COP Tj = Tbiv	4.10	2.76
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	13.79 kW	12.95 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.66	2.38
WTOL	50 °C	50 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Supplementary Heater: PSUP	2.64 kW	2.69 kW
Annual energy consumption Qhe	4553 kWh	5391 kWh

Colder Climate

EN 14825		
	Low temperature	**Medium temperature**
η_s	140 %	115 %
Prated	13.15 kW	12.60 kW
SCOP	3.58	2.95
Tbiv	-12 °C	-12 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	11.09 kW	10.66 kW
COP Tj = -7°C	3.35	2.51
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	13.99 kW	13.70 kW
COP Tj = +2°C	4.14	3.47
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	14.57 kW	14.47 kW
COP Tj = +7°C	5.09	4.70
Cdh Tj = +7 °C	1.00	1.00
Pdh Tj = 12°C	16.36 kW	16.40 kW

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

COP Tj = 12°C	5.31	5.49
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	9.69 kW	9.29 kW
COP Tj = Tbiv	2.95	2.15
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.43 kW	7.71 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.24	1.78
WTOL	50 °C	50 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	13.15 kW	12.60 kW
Annual energy consumption Qhe	9044 kWh	10533 kWh
Pdh Tj = -15°C (if TOL<-20°C)	8.83	8.49
COP Tj = -15°C (if TOL<-20°C)	2.68	1.96
Cdh Tj = -15 °C	1.00	1.00

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Model: LW 140A

Configure model	
Model name	LW 140A
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	14.38 kW	13.74 kW
El input	3.26 kW	4.70 kW
COP	4.30	2.83

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Starting and operating test	passed

Average Climate

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	58 dB(A)	58 dB(A)
Sound power level outdoor	58 dB(A)	58 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	157 %	125 %
Prated	14.43 kW	13.71 kW
SCOP	4.00	3.20
Tbiv	-5 °C	-5 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	11.00 kW	10.40 kW
COP Tj = -7°C	3.13	2.16
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	13.90 kW	13.49 kW
COP Tj = +2°C	3.94	3.10
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	14.53 kW	14.35 kW
COP Tj = +7°C	4.94	4.28
Cdh Tj = +7 °C	1.00	1.00

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Pdh Tj = 12°C	16.37 kW	16.34 kW
COP Tj = 12°C	5.43	5.27
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	11.66 kW	11.07 kW
COP Tj = Tbiv	3.34	2.34
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.15 kW	9.58 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.87	1.96
WTOL	50 °C	50 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	4.28 kW	4.13 kW
Annual energy consumption Qhe	7447 kWh	8842 kWh

Warmer Climate

EN 14825		
	Low temperature	**Medium temperature**
η_s	190 %	152 %
Prated	16.43 kW	15.64 kW

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

SCOP	4.82	3.88
Tbiv	4 °C	4 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	13.79 kW	12.95 kW
COP Tj = +2°C	3.66	2.38
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	14.46 kW	14.03 kW
COP Tj = +7°C	4.71	3.46
Cdh Tj = +7 °C	1.00	1.00
Pdh Tj = 12°C	16.32 kW	16.17 kW
COP Tj = 12°C	5.33	4.80
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	14.08 kW	13.40 kW
COP Tj = Tbiv	4.10	2.76
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	13.79 kW	12.95 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.66	2.38
WTOL	50 °C	50 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.64 kW	2.69 kW
Annual energy consumption Qhe	4553 kWh	5391 kWh

Colder Climate

EN 14825		
	Low temperature	**Medium temperature**
η_s	140 %	115 %
Prated	13.15 kW	12.60 kW
SCOP	3.58	2.95
Tbiv	-12 °C	-12 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	11.09 kW	10.66 kW
COP Tj = -7°C	3.35	2.51
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	13.99 kW	13.70 kW
COP Tj = +2°C	4.14	3.47
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	14.57 kW	14.47 kW
COP Tj = +7°C	5.09	4.70
Cdh Tj = +7 °C	1.00	1.00

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Pdh Tj = 12°C	16.36 kW	16.40 kW
COP Tj = 12°C	5.31	5.49
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	9.69 kW	9.29 kW
COP Tj = Tbiv	2.95	2.15
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.43 kW	7.71 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.24	1.78
WTOL	50 °C	50 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	13.15 kW	12.60 kW
Annual energy consumption Qhe	9044 kWh	10533 kWh
Pdh Tj = -15°C (if TOL<-20°C)	8.83	8.49
COP Tj = -15°C (if TOL<-20°C)	2.68	1.96
Cdh Tj = -15 °C	1.00	1.00

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.