

This information was generated by the HP KEYMARK database on 17 Dec 2020

Summary of	THERMOR Alféa Extensa A.I. size 10	Reg. No.	012-SC0225-19
Certificate Holder			
Name	Groupe Atlantic		
Address	44 boulevard des Etats-Unis	Zip	85000
City	La Roche Sur Yon	Country	France
Certification Body	RISE CERT		
Name of testing laboratory	SP		
Subtype title	THERMOR Alféa Extensa A.I. size 10		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R410a		
Mass Of Refrigerant	1.8 kg		
Certification Date	05.06.2019		

Model: THERMOR Alféa Extensa Duo A.I. 10

General Data

Power supply	1x230V 50Hz
--------------	-------------

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	46 dB(A)	46 dB(A)
Sound power level outdoor	69 dB(A)	69 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	155 %	113 %
Prated	8.00 kW	8.00 kW
SCOP	3.95	2.90
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.50 kW	6.70 kW
COP Tj = -7°C	2.40	1.70
Pdh Tj = +2°C	4.50 kW	4.10 kW
COP Tj = +2°C	3.80	2.70
Pdh Tj = +7°C	3.50 kW	3.20 kW

This information was generated by the HP KEYMARK database on 17 Dec 2020

COP Tj = +7°C	5.70	4.10
Pdh Tj = 12°C	4.00 kW	4.00 kW
COP Tj = 12°C	7.20	5.70
Pdh Tj = Tbiv	7.50 kW	6.70 kW
COP Tj = Tbiv	2.40	1.70
Pdh Tj = TOL	7.00 kW	5.90 kW
COP Tj = TOL	2.20	1.40
Cdh	0.90	0.90
WTOL	55 °C	55 °C
Poff	5 W	5 W
PTO	43 W	22 W
PSB	8 W	8 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	1.40 kW	1.70 kW
Annual energy consumption Qhe	4415 kWh	5415 kWh

Heating

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	10.00 kW	7.00 kW
El input	2.49 kW	2.86 kW
COP	4.02	2.45
Indoor water flow rate	1.80 m ³ /h	0.75 m ³ /h

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	120 %
COP	3.00
Heating up time	1:45 h:min
Standby power input	32.0 W
Reference hot water temperature	54.0 °C
Mixed water at 40°C	249 l

Model: THERMOR Alféa Extensa A.I. 10

General Data

Power supply	1x230V 50Hz
--------------	-------------

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	46 dB(A)	46 dB(A)
Sound power level outdoor	69 dB(A)	69 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	155 %	113 %
Prated	8.00 kW	8.00 kW
SCOP	3.95	2.90
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.50 kW	6.70 kW
COP Tj = -7°C	2.40	1.70
Pdh Tj = +2°C	4.50 kW	4.10 kW
COP Tj = +2°C	3.80	2.70
Pdh Tj = +7°C	3.50 kW	3.20 kW

This information was generated by the HP KEYMARK database on 17 Dec 2020

COP Tj = +7°C	5.70	4.10
Pdh Tj = 12°C	4.00 kW	4.00 kW
COP Tj = 12°C	7.20	5.70
Pdh Tj = Tbiv	7.50 kW	6.70 kW
COP Tj = Tbiv	2.40	1.70
Pdh Tj = TOL	7.00 kW	5.90 kW
COP Tj = TOL	2.20	1.40
Cdh	0.90	0.90
WTOL	55 °C	55 °C
Poff	5 W	5 W
PTO	43 W	22 W
PSB	8 W	8 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	1.40 kW	1.70 kW
Annual energy consumption Qhe	4415 kWh	5415 kWh

Heating

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	10.00 kW	7.00 kW
El input	2.49 kW	2.86 kW
COP	4.02	2.45
Indoor water flow rate	1.80 m ³ /h	0.75 m ³ /h