

## Page 1 of 3

## This information was generated by the HP KEYMARK database on 18 Mar 2022

#### <u>Login</u>

Summary of	VIESSMANN Vitocal 060-A Typ T0S-ze 060-A (250l)	Reg. No.	011-1W0192		
Certificate Holder					
Name	Viessmann Faulquemont SAS				
Address	Avenue André Gouy	Zip	F-57380		
City	Faulquemont	Country	France		
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH				
Subtype title	VIESSMANN Vitocal 060-A Typ T0S-ze 060-A (250I)				
Heat Pump Type	Heat Pump for Domestic Hot Water (DHW)				
Refrigerant	R1234ze				
Mass of Refrigerant	1.25 kg				
Certification Date	27.02.2020				



This information was generated by the HP KEYMARK database on 18 Mar 2022

# Model: VIESSMANN Vitocal 060-A Typ T0S-ze 060-A (250I)

Configure model			
Model name	VIESSMANN Vitocal 060-A Typ T0S-ze 060-A (250I)		
Units	Indoor		
Climate zone (for heating)	n/a		
Heat Source	Outdoor Air		
Any additional heat sources	n/a		

General Data		
Power supply	1x230V 50Hz	
Off-peak product	Yes	

## Domestic Hot Water (DHW)

## Operating test

EN 16147		
Temperature operating range	passed	
Safety devices checking test	passed	
Condensate draining	passed	

# **Average Climate**

EN 12102-2		
Sound power level indoor	50 dB(A)	





 $$\operatorname{\textit{Page}}\ 3$$  of 3 This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 16147			
Declared load profile	L		
Efficiency ηDHW	132 %		
СОР	3.15		
Heating up time	9:37 h:min		
Standby power input	30.0 W		
Reference hot water temperature	54.7 °C		
Mixed water at 40°C	344		