

Summary of	WELLEA MONOBLOC 5/7/9 KW 1ph	Reg. No.	ICIM-PDC-000056-00
Certificate Holder			
Name	Airwell Residential		
Address	10, rue du Fort de Saint Cyr	Zip	78180
City	Montigny le Bretonneux	Country	France
Certification Body	ICIM S.p.A.		
Name of testing laboratory	OBL products - ReLab Politecnico Milano		
Subtype title	WELLEA MONOBLOC 5/7/9 KW 1ph		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R32		
Mass Of Refrigerant	2 kg		
Certification Date	17.01.2020		
Testing basis	EN 14511:2013, EN 14825:2016, EN 12102:2013		



# **Model: WELLEA MONOBLOC 5KW**

General Data	
Power supply	1x230V 50Hz

### Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	4.65 kW	4.65 kW
El input	0.93 kW	1.77 kW
СОР	5.00	2.63
Indoor water flow rate	0.80 m³/h	0.50 m³/h

EN 14511-4	
Shutting off the heat transfer medium flow	nassod
Shutting on the heat transfer medium now	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

### **Average Climate**



EN 12102-1		
	Low temperature	Medium temperature
Sound power level outdoor	61 dB(A)	61 dB(A)

EN 14825		
	Low temperature	Medium temperature
$\eta_{s}$	175 %	127 %
Prated	7.00 kW	7.00 kW
SCOP	4.47	3.24
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.88 kW	5.83 kW
COP Tj = -7°C	2.91	1.97
Cdh	0.90	0.90
Pdh Tj = +2°C	3.64 kW	3.68 kW
COP Tj = +2°C	4.38	3.22
Cdh	0.90	0.90
Pdh Tj = +7°C	2.42 kW	2.47 kW
COP Tj = +7°C	5.89	4.21
Cdh	0.90	0.90
Pdh Tj = 12°C	1.03 kW	1.26 kW
	,	•

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



Page 4 of 10

#### This information was generated by the HP KEYMARK database on 17 Dec 2020

COP Tj = 12°C	5.89	4.91
Cdh	0.90	0.90
Pdh Tj = Tbiv	5.88 kW	5.83 kW
COP Tj = Tbiv	2.91	1.97
Pdh Tj = TOL	6.62 kW	5.86 kW
COP Tj = TOL	2.63	1.62
WTOL	60 °C	60 °C
Poff	9 W	9 W
РТО	9 W	9 W
PSB	9 W	9 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electric	electric
Supplementary Heater: PSUP	0.00 kW	0.70 kW
Annual energy consumption Qhe	3071 kWh	4203 kWh



# **Model: WELLEA MONOBLOC 7KW**

Genera	al Data
Power supply	1x230V 50Hz

### Heating

EN 14511-4		
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	
Defrost test	passed	
Starting and operating test	passed	

EN 14511-2		
	Low temperature	Medium temperature
Heat output	6.65 kW	6.80 kW
El input	1.35 kW	2.42 kW
СОР	4.94	2.81
Indoor water flow rate	1.14 m³/h	0.73 m³/h

#### **Average Climate**



EN 12102-1		
	Low temperature	Medium temperature
Sound power level outdoor	64 dB(A)	64 dB(A)

EN 14825		
	Low temperature	Medium temperature
$\eta_{s}$	176 %	127 %
Prated	7.00 kW	7.00 kW
SCOP	4.47	3.24
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.88 kW	5.83 kW
COP Tj = -7°C	2.91	1.97
Cdh	0.90	0.90
Pdh Tj = +2°C	3.64 kW	3.68 kW
COP Tj = +2°C	4.38	3.22
Cdh	0.90	0.90
Pdh Tj = +7°C	2.42 kW	2.47 kW
COP Tj = +7°C	5.89	4.21
Cdh	0.90	0.90
Pdh Tj = 12°C	1.03 kW	1.26 kW

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



# $$\operatorname{\textit{Page}}\ 7$$ of 10 This information was generated by the HP KEYMARK database on 17 Dec 2020

	<u> </u>	
COP Tj = 12°C	5.89	4.91
Cdh	0.90	0.90
Pdh Tj = Tbiv	5.88 kW	5.83 kW
COP Tj = Tbiv	2.91	1.97
Pdh Tj = TOL	6.62 kW	5.86 kW
COP Tj = TOL	2.63	1.62
WTOL	60 °C	60 °C
Poff	9 W	9 W
РТО	6 W	6 W
PSB	9 W	9 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electric	electric
Supplementary Heater: PSUP	0.00 kW	0.70 kW
Annual energy consumption Qhe	3701 kWh	4203 kWh



# **Model: WELLEA MONOBLOC 9KW**

General Data	
Power supply	1x230V 50Hz

### Heating

EN 14511-2			
	Low temperature	Medium temperature	
Heat output	8.60 kW	8.60 kW	
El input	1.87 kW	3.12 kW	
СОР	4.60	2.75	
Indoor water flow rate	1.48 m³/h	0.92 m³/h	

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

#### **Average Climate**



EN 12102-1		
	Low temperature	Medium temperature
Sound power level outdoor	67 dB(A)	67 dB(A)

EN 14825		
	Low temperature	Medium temperature
$\eta_{s}$	177 %	126 %
Prated	8.00 kW	7.00 kW
SCOP	4.51	3.22
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.42 kW	6.58 kW
COP Tj = -7°C	2.80	1.87
Cdh	0.90	0.90
Pdh Tj = +2°C	4.83 kW	4.25 kW
COP Tj = +2°C	4.33	3.19
Cdh	0.90	0.90
Pdh Tj = +7°C	3.20 kW	2.80 kW
COP Tj = +7°C	6.20	4.38
Cdh	0.90	0.90
Pdh Tj = 12°C	1.55 kW	1.27 kW

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



# $$\operatorname{\textit{Page}}\ 10$$ of 10 This information was generated by the HP KEYMARK database on 17 Dec 2020

COP Tj = 12°C	7.61	5.04
Cdh	0.90	0.90
Pdh Tj = Tbiv	7.42 kW	6.58 kW
COP Tj = Tbiv	2.80	1.87
Pdh Tj = TOL	6.64 kW	5.53 kW
COP Tj = TOL	2.54	1.51
WTOL	60 °C	60 °C
Poff	9 W	9 W
РТО	10 W	10 W
PSB	9 W	9 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electric	electric
Supplementary Heater: PSUP	1.80 kW	1.80 kW
Annual energy consumption Qhe	3844 kWh	4770 kWh