

This information was generated by the HP KEYMARK database on 5 Mar 2021

Summary of	Loria 6010	Reg. No.	012-SC0320-19
Certificate Holder			
Name	Groupe Atlantic		
Address	44 boulevard des Etats-Unis	Zip	85000
City	La Roche Sur Yon	Country	France
Certification Body	RISE CERT		
Subtype title	Loria 6010		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R410a		
Mass Of Refrigerant	1.8 kg		
Certification Date	26.09.2019		

Model: Loria 6010

General Data

Power supply	1x230V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	6.66 kW	6.52 kW
El input	1.31 kW	2.39 kW
COP	5.09	2.72

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 5 Mar 2021

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	68 dB(A)	68 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	176 %	131 %
Prated	9.00 kW	9.00 kW
SCOP	4.47	3.36
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	8.05 kW	7.65 kW
COP Tj = -7°C	2.54	1.89
Cdh	0.90	0.90
Pdh Tj = +2°C	4.90 kW	4.66 kW
COP Tj = +2°C	4.46	3.29
Cdh	0.90	0.90
Pdh Tj = +7°C	3.15 kW	3.42 kW
COP Tj = +7°C	6.20	4.84
Cdh	0.90	0.90

This information was generated by the HP KEYMARK database on 5 Mar 2021

Pdh Tj = 12°C	4.20 kW	4.10 kW
COP Tj = 12°C	9.02	6.82
Cdh	0.90	0.90
Pdh Tj = Tbiv	8.05 kW	7.65 kW
COP Tj = Tbiv	2.54	1.89
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.51 kW	6.74 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.37	1.71
WTOL	55 °C	55 °C
Poff	7 W	7 W
PTO	52 W	52 W
PSB	7 W	7 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	1.60 kW	1.90 kW
Annual energy consumption Qhe	4206 kWh	5320 kWh

Model: Loria Duo 6010

General Data

Power supply	1x230V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	6.66 kW	6.52 kW
El input	1.31 kW	2.39 kW
COP	5.09	2.72

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 5 Mar 2021

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	68 dB(A)	68 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	176 %	131 %
Prated	9.00 kW	9.00 kW
SCOP	4.47	3.36
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	8.05 kW	7.65 kW
COP Tj = -7°C	2.54	1.89
Cdh	0.90	0.90
Pdh Tj = +2°C	4.90 kW	4.66 kW
COP Tj = +2°C	4.46	3.29
Cdh	0.90	0.90
Pdh Tj = +7°C	3.15 kW	3.42 kW
COP Tj = +7°C	6.20	4.84
Cdh	0.90	0.90

This information was generated by the HP KEYMARK database on 5 Mar 2021

Pdh Tj = 12°C	4.20 kW	4.10 kW
COP Tj = 12°C	9.02	6.82
Cdh	0.90	0.90
Pdh Tj = Tbiv	8.05 kW	7.65 kW
COP Tj = Tbiv	2.54	1.89
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.51 kW	6.74 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.37	1.71
WTOL	55 °C	55 °C
Poff	7 W	7 W
PTO	52 W	52 W
PSB	7 W	7 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	1.60 kW	1.90 kW
Annual energy consumption Qhe	4206 kWh	5320 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	130 %
COP	3.26
Heating up time	1:36 h:min
Reference hot water temperature	52.5 °C
Mixed water at 40°C	243 l
Standby power input	31.0 W