


Page 1 of 7

#### This information was generated by the HP KEYMARK database on 18 Mar 2022

#### **Login**

Summary of	TTL 25 AC	Reg. No.	011-1W0491	
Certificate Holder				
Name	tecalor GmbH			
Address	Fürstenbergerstr. 77	Zip	37603	
City	Holzminden	Country	Germany	
Certification Body	DIN CERTCO Gesellschaft für	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Subtype title	TTL 25 AC	TTL 25 AC		
Heat Pump Type	Outdoor Air/Water	Outdoor Air/Water		
Refrigerant	R410A	R410A		
Mass of Refrigerant	5.5 kg	5.5 kg		
Certification Date	01.11.2016	01.11.2016		





# **Model: TTL 25 AC**

Configure model		
Model name	TTL 25 AC	
Application	Heating (medium temp)	
Units	Outdoor	
Climate Zone	Colder Climate + Warmer Climate	
Reversibility	Yes	
Cooling mode application (optional)	n/a	

General Data		
Power supply	3x400V 50Hz	

## Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	7.84 kW	7.36 kW
El input	1.54 kW	2.33 kW
СОР	5.09	3.16

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Starting and operating test	passed

### Average Climate



This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 12102-1		
	Low temperature	Medium temperature
Sound power level outdoor	54 dB(A)	54 dB(A)

EN 14825		
	Low temperature	Medium temperature
$\eta_{s}$	187 %	144 %
Prated	15.00 kW	15.00 kW
SCOP	4.76	3.67
Tbiv	-5 °C	-5 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	12.80 kW	13.80 kW
COP Tj = -7°C	2.98	2.48
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	8.30 kW	8.40 kW
COP Tj = +2°C	4.72	3.51
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	8.00 kW	7.80 kW
$COP Tj = +7^{\circ}C$	6.16	4.61
Cdh Tj = +7 °C	1.00	1.00
Pdh Tj = 12°C	9.10 kW	9.00 kW

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com





This information was generated by the Till Retinantic database on 10 Mar 202		
COP Tj = 12°C	8.11	6.66
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	11.80 kW	12.50 kW
COP Tj = Tbiv	3.16	2.59
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.60 kW	13.40 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.87	2.28
WTOL	65 °C	65 °C
Poff	10 W	10 W
РТО	10 W	10 W
PSB	10 W	10 W
PCK	38 W	38 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.21 kW	0.00 kW
Annual energy consumption Qhe	6513 kWh	8444 kWh

#### Warmer Climate

EN 14825		
	Low temperature	Medium temperature
$\eta_{s}$	246 %	177 %
Prated	8.00 kW	8.00 kW
SCOP	6.22	4.51

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



 $$\operatorname{\textit{Page}}\xspace\:5\:\:\text{of}\:7\:$  This information was generated by the HP KEYMARK database on 18 Mar 2022

Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = $+2$ °C	8.30 kW	8.40 kW
$COP Tj = +2^{\circ}C$	4.14	2.74
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = $+7^{\circ}$ C	7.90 kW	7.50 kW
$COP Tj = +7^{\circ}C$	5.47	3.64
Cdh Tj = $+7$ °C	1.00	1.00
Pdh Tj = 12°C	9.10 kW	9.00 kW
COP Tj = 12°C	7.72	6.11
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	8.30 kW	8.40 kW
COP Tj = Tbiv	4.14	2.74
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	16.90 kW	18.80 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.61	2.31
WTOL	65 °C	65 °C
Poff	10 W	10 W
РТО	10 W	10 W
PSB	10 W	10 W
РСК	38 W	38 W
Supplementary Heater: Type of energy input	Electricity	Electricity





This information was generated by the HP KEYMARK database on 18 Mar 2022

Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1718 kWh	2369 kWh

### Colder Climate

EN 14825		
	Low temperature	Medium temperature
$\eta_{s}$	160 %	131 %
Prated	21.00 kW	22.00 kW
SCOP	4.08	3.35
Tbiv	-10 °C	-10 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	12.60 kW	13.30 kW
COP Tj = -7°C	3.13	2.67
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	8.30 kW	8.30 kW
COP Tj = +2°C	5.15	3.92
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	8.00 kW	7.90 kW
COP Tj = +7°C	6.57	5.12
Cdh Tj = +7 °C	1.00	1.00
Pdh Tj = 12°C	9.10 kW	9.00 kW

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



 $$\operatorname{\textit{Page}}\ 7$$  of 7 This information was generated by the HP KEYMARK database on 18 Mar 2022

The man and general		
COP Tj = 12°C	8.11	6.95
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	14.10 kW	15.20 kW
COP Tj = Tbiv	2.90	2.53
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	16.70 kW	18.30 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.66	2.37
WTOL	65 °C	65 °C
Poff	10 W	10 W
РТО	10 W	10 W
PSB	10 W	10 W
PCK	38 W	38 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	20.59 kW	22.15 kW
Annual energy consumption Qhe	12690 kWh	16179 kWh
Pdh Tj = -15°C (if TOL<-20°C)	16.70	18.30
COP Tj = $-15$ °C (if TOL< $-20$ °C)	2.66	2.37
Cdh Tj = -15 °C	1.00	1.00
1		