

Summary of	20. Yutaki M 5.0HP (mono)	Reg. No.	041-K002-20
Certificate Holder			
Name	Johnson Controls-Hitachi AirConditioning Sp	ain	
Address	Ronda Shimizu, 1. Pol. Ind. Can Torrella	Zip	08233
City	Vacarisses, Barcelona	Country	Spain
Certification Body	BRE Energy & Communications Division		
Name of testing laboratory	CEIS		
Subtype title	20. Yutaki M 5.0HP (mono)		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R410a		
Mass Of Refrigerant	3.1 kg		



# Model: RASM-5VNE - Heating Only

General Data	
Power supply	1x230V 50Hz

### Heating

EN 14511-4		
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed	
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit		
	passed	
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	
Defrost test	passed	

EN 14511-2		
	Low temperature	Medium temperature
Heat output	14.00 kW	14.00 kW
El input	2.97 kW	5.00 kW
СОР	4.71	2.80
Indoor water flow rate	2.40 m³/h	1.50 m³/h

### **Average Climate**



EN 12102-1		
	Low temperature	Medium temperature
Sound power level outdoor	65 dB(A)	65 dB(A)

EN 14825		
	Low temperature	Medium temperature
$\eta_{s}$	175 %	133 %
Prated	14.00 kW	12.00 kW
SCOP	4.45	3.40
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	12.00 kW	10.25 kW
COP Tj = -7°C	2.55	1.70
Pdh Tj = +2°C	7.30 kW	6.24 kW
COP Tj = +2°C	4.70	3.60
Pdh Tj = +7°C	4.70 kW	4.01 kW
COP Tj = +7°C	5.70	4.60
Pdh Tj = 12°C	3.50 kW	3.50 kW
COP Tj = 12°C	6.00	5.50
Pdh Tj = Tbiv	12.00 kW	10.25 kW
COP Tj = Tbiv	2.55	1.70

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



 $$\operatorname{\textit{Page}}$4$ of 7$$  This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = TOL	12.10 kW	10.50 kW
COP Tj = TOL	2.50	1.70
Cdh	0.90	0.90
WTOL	55 °C	55 °C
Poff	13 W	13 W
РТО	0 W	o w
PSB	13 W	13 W
PCK	o w	o w
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	1.90 kW	1.50 kW
Annual energy consumption Qhe	6313 kWh	7042 kWh



# Model: RASM-5VNE - with cooling kit

General Data	
Power supply	1x230V 50Hz

### Heating

EN 14511-4		
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed	
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed	
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	
Defrost test	passed	

EN 14511-2		
	Low temperature	Medium temperature
Heat output	14.00 kW	14.00 kW
El input	2.97 kW	5.00 kW
СОР	4.71	2.80
Indoor water flow rate	2.40 m³/h	1.50 m³/h

#### Average Climate



EN 12102-1		
	Low temperature	Medium temperature
Sound power level outdoor	65 dB(A)	65 dB(A)

EN 14825		
	Low temperature	Medium temperature
$\eta_{s}$	176 %	134 %
Prated	14.00 kW	12.00 kW
SCOP	4.48	3.43
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	12.00 kW	10.25 kW
COP Tj = -7°C	2.55	1.70
Pdh Tj = +2°C	7.30 kW	6.24 kW
COP Tj = +2°C	4.70	3.60
Pdh Tj = +7°C	4.70 kW	4.01 kW
COP Tj = +7°C	5.70	4.60
Pdh Tj = 12°C	3.50 kW	3.50 kW
COP Tj = 12°C	6.00	5.50
Pdh Tj = Tbiv	12.00 kW	10.25 kW
COP Tj = Tbiv	2.55	1.70

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



 $$\operatorname{\textit{Page}}\ 7$$  of 7 This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = TOL	12.10 kW	10.50 kW
COP Tj = TOL	2.50	1.70
Cdh	0.90	0.90
WTOL	55 °C	55 °C
Poff	13 W	13 W
РТО	0 W	o w
PSB	13 W	13 W
PCK	o w	o w
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	1.90 kW	1.50 kW
Annual energy consumption Qhe	6265 kWh	6994 kWh