

Summary of	WELLEA MONOBLOC 12/14/16 KW 1ph	Reg. No.	ICIM-PDC-000055-00
Certificate Holder	:		
Name	Airwell Residential		
Address	10, rue du Fort de Saint Cyr	Zip	78180
City	Montigny le Bretonneux	Country	France
Certification Body	ICIM S.p.A.		
Name of testing laboratory	OBL products - ReLab Politecnico Milano		
Subtype title	WELLEA MONOBLOC 12/14/16 KW 1ph		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R32		
Mass Of Refrigerant	2.8 kg		
Certification Date	17.01.2020		
Testing basis	EN 14511:2013, EN 14825:2016, EN 12102:2013		



## **Model: WELLEA MONOBLOC 12 KW 1PH**

General Data	
Power supply	1x230V 50Hz

### Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	12.30 kW	11.90 kW
El input	2.56 kW	4.28 kW
СОР	4.81	0.78
Indoor water flow rate	2.12 m³/h	1.28 m³/h

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

### **Average Climate**



EN 12102-1		
	Low temperature	Medium temperature
Sound power level outdoor	68 dB(A)	68 dB(A)

EN 14825		
	Low temperature	Medium temperature
$\eta_{s}$	169 %	126 %
Prated	12.00 kW	13.00 kW
SCOP	4.29	3.23
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.52 kW	11.29 kW
COP Tj = -7°C	2.88	2.05
Cdh	0.90	0.90
Pdh Tj = +2°C	6.50 kW	7.31 kW
COP Tj = +2°C	4.15	3.14
Cdh	0.90	0.90
Pdh Tj = +7°C	4.12 kW	4.96 kW
COP Tj = +7°C	5.74	4.25
Cdh	0.90	0.90
Pdh Tj = 12°C	2.23 kW	2.37 kW

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



Page 4 of 10

### This information was generated by the HP KEYMARK database on 17 Dec 2020

COP Tj = 12°C	5.40	4.94
Cdh	0.90	0.90
Pdh Tj = Tbiv	10.52 kW	11.29 kW
COP Tj = Tbiv	2.88	2.05
Pdh Tj = TOL	12.01 kW	11.88 kW
COP Tj = TOL	2.60	1.79
WTOL	60 °C	60 °C
Poff	9 W	9 W
РТО	15 W	15 W
PSB	9 W	9 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electric	electric
Supplementary Heater: PSUP	0.00 kW	0.90 kW
Annual energy consumption Qhe	5726 kWh	8164 kWh



Model: WELLEA MONOBLOC 14 KW 1PH

General Data	
Power supply	1x230V 50Hz

### Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	14.10 kW	14.20 kW
El input	3.07 kW	5.16 kW
СОР	4.60	2.75
Indoor water flow rate	2.43 m³/h	1.53 m³/h

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

### **Average Climate**



EN 12102-1		
	Low temperature	Medium temperature
Sound power level outdoor	71 dB(A)	71 dB(A)

EN 14825		
	Low temperature	Medium temperature
$\eta_{s}$	168 %	128 %
Prated	14.00 kW	14.00 kW
SCOP	4.27	3.26
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	12.47 kW	12.18 kW
COP Tj = -7°C	2.84	2.05
Cdh	0.90	0.90
Pdh Tj = +2°C	7.48 kW	7.84 kW
COP Tj = +2°C	4.19	3.18
Cdh	0.90	0.90
Pdh Tj = +7°C	5.04 kW	5.21 kW
COP Tj = +7°C	5.99	4.29
Cdh	0.90	0.90
Pdh Tj = 12°C	2.23 kW	2.57 kW

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



# $$\operatorname{\textit{Page}}\ 7$$ of 10 This information was generated by the HP KEYMARK database on 17 Dec 2020

	•	
COP Tj = 12°C	5.30	5.14
Cdh	0.90	0.90
Pdh Tj = Tbiv	12.47 kW	12.18 kW
COP Tj = Tbiv	2.84	2.05
Pdh Tj = TOL	12.72 kW	11.68 kW
COP Tj = TOL	2.51	1.74
WTOL	60 °C	60 °C
Poff	9 W	9 W
РТО	26 W	26 W
PSB	9 W	9 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electric	electric
Supplementary Heater: PSUP	1.40 kW	2.10 kW
Annual energy consumption Qhe	6819 kWh	8724 kWh



## **Model: WELLEA MONOBLOC 16 KW 1PH**

General Data	
Power supply	1x230V 50Hz

### Heating

EN 14511-2			
	Low temperature	Medium temperature	
Heat output	16.30 kW	16.10 kW	
El input	3.66 kW	5.90 kW	
СОР	4.45	2.73	
Indoor water flow rate	2.80 m³/h	1.73 m³/h	

EN 14511-4		
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	
Defrost test	passed	
Starting and operating test	passed	

### **Average Climate**



EN 12102-1		
	Low temperature	Medium temperature
Sound power level outdoor	71 dB(A)	71 dB(A)

	EN 14825	
	Low temperature	Medium temperature
$\eta_{s}$	169 %	128 %
Prated	16.00 kW	15.00 kW
SCOP	4.30	3.27
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	14.15 kW	12.90 kW
COP Tj = -7°C	2.72	2.04
Cdh	0.90	0.90
Pdh Tj = +2°C	8.92 kW	8.25 kW
COP Tj = +2°C	4.17	3.21
Cdh	0.90	0.90
Pdh Tj = +7°C	5.64 kW	5.45 kW
COP Tj = +7°C	5.86	4.32
Cdh	0.90	0.90
Pdh Tj = 12°C	2.47 kW	2.57 kW

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



# $$\operatorname{\textit{Page}}\ 10$$ of 10 This information was generated by the HP KEYMARK database on 17 Dec 2020

COP Tj = 12°C	6.28	5.12
Cdh	0.90	0.90
Pdh Tj = Tbiv	14.15 kW	12.90 kW
COP Tj = Tbiv	2.72	2.04
Pdh Tj = TOL	12.93 kW	11.16 kW
COP Tj = TOL	2.41	1.65
WTOL	60 °C	60 °C
Poff	9 W	9 W
PTO	41 W	41 W
PSB	9 W	9 W
PCK	o w	o w
Supplementary Heater: Type of energy input	electric	electric
Supplementary Heater: PSUP	3.10 kW	3.40 kW
Annual energy consumption Qhe	7687 kWh	9216 kWh