

Page 1 of 13

This information was generated by the HP KEYMARK database on 21 Jun 2022

Login

Summary of	TTL 15 AS, TTL 15 ACS	Reg. No.	011-1W0048	
Certificate Holder				
Name	tecalor GmbH			
Address	Fürstenbergerstr. 77	Zip	37603	
City	Holzminden	Country	Germany	
Certification Body	DIN CERTCO Gesellschaft für K	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Subtype title	TTL 15 AS, TTL 15 ACS			
Heat Pump Type	Outdoor Air/Water			
Refrigerant	R410A			
Mass of Refrigerant	4.2 kg			
Certification Date	01.11.2016			



Model: TTL 15 AS

Configure model		
Model name	TTL 15 AS	
Application	Heating (medium temp)	
Units	Outdoor	
Climate Zone	Colder Climate + Warmer Climate	
Reversibility	No	
Cooling mode application (optional)	n/a	


General Data		
Power supply	1x230V 50Hz	

Heating

EN 14511-2			
	Low temperature	Medium temperature	
Heat output	4.68 kW	3.74 kW	
El input	1.11 kW	1.37 kW	
СОР	4.23	2.73	

EN 14511-4		
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	
Starting and operating test	passed	

Average Climate





EN 12102-1			
	Low temperature	Medium temperature	
Sound power level outdoor	50 dB(A)	50 dB(A)	

EN 14825		
	Low temperature	Medium temperature
η_{s}	151 %	122 %
Prated	8.00 kW	8.00 kW
SCOP	3.84	3.20
Tbiv	-8 °C	-8 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7 °C	6.80 kW	7.10 kW
$COP Tj = -7^{\circ}C$	2.49	2.18
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = $+2^{\circ}$ C	4.30 kW	4.20 kW
COP Tj = +2°C	4.04	3.30
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = $+7^{\circ}$ C	4.50 kW	4.20 kW
$COP Tj = +7^{\circ}C$	5.08	4.07
Cdh Tj = $+7$ °C	0.90	0.90
Pdh Tj = 12°C	4.40 kW	4.00 kW

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com





This information was generated by the HP KEYMARK database on 21 Jun 2022 COP Tj = 12°C6.30 5.14 Cdh Tj = +12 °C 0.90 0.90 Pdh Tj = Tbiv7.10 kW 7.40 kW COP Tj = Tbiv2.42 2.13 Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh 6.60 kW 7.00 kW COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh 2.71 1.97 WTOL 65 °C 65 °C Poff 16 W 16 W PTO 16 W 16 W **PSB** 16 W 16 W **PCK** 43 W 43 W Supplementary Heater: Type of energy input Electricity Electricity Supplementary Heater: PSUP 0.00 kW 0.00 kW

Warmer Climate

Annual energy consumption Qhe

EN 14825		
	Low temperature	Medium temperature
η_{S}	153 %	120 %
Prated	4.00 kW	4.00 kW
SCOP	3.91	2.99
	,	

4303 kWh

5300 kWh





This information was gener	ated by the HI KETMA	NK database on 21 juli 2022
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	4.20 kW	4.00 kW
COP Tj = +2°C	3.48	2.50
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = $+7^{\circ}$ C	4.30 kW	3.90 kW
$COPTj = +7^{\circ}C$	4.46	3.16
Cdh Tj = $+7$ °C	0.90	0.90
Pdh Tj = 12°C	4.30 kW	3.80 kW
COP Tj = 12°C	5.89	4.57
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	4.20 kW	4.00 kW
COP Tj = Tbiv	3.48	2.50
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.20 kW	9.80 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.15	1.98
WTOL	65 °C	65 °C
Poff	16 W	16 W
РТО	16 W	16 W
PSB	16 W	16 W
PCK	43 W	43 W
Supplementary Heater: Type of energy input	Electricity	Electricity





Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1367 kWh	1750 kWh

Colder Climate

EN 14825		
	Low temperature	Medium temperature
η_{s}	137 %	118 %
Prated	11.00 kW	12.00 kW
SCOP	3.51	3.05
Tbiv	-10 °C	-10 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	6.80 kW	7.00 kW
COP Tj = -7°C	2.72	2.45
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	4.30 kW	4.20 kW
COP Tj = +2°C	4.45	3.70
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	4.50 kW	4.30 kW
COP Tj = +7°C	5.44	4.53
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	4.40 kW	4.10 kW

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com





	, -	TIR database on 21 jun 2021
COP Tj = 12°C	6.30	5.44
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	7.70 kW	7.90 kW
COP Tj = Tbiv	2.50	2.28
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.10 kW	9.70 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.25	2.10
WTOL	65 °C	65 °C
Poff	16 W	16 W
РТО	16 W	16 W
PSB	16 W	16 W
PCK	43 W	43 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	11.20 kW	11.61 kW
Annual energy consumption Qhe	7727 kWh	9481 kWh
Pdh Tj = -15°C (if TOL<-20°C)	9.10	9.70
COP Tj = -15 °C (if TOL< -20 °C)	2.25	2.10
Cdh Tj = -15 °C	0.90	0.90

Model: TTL 15 ACS

Configure model		
Model name	TTL 15 ACS	
Application	Heating (medium temp)	
Units	Outdoor	
Climate Zone	Colder Climate + Warmer Climate	
Reversibility	No	
Cooling mode application (optional)	n/a	

General Data		
Power supply	1x230V 50Hz	

Heating

EN 14511-2			
	Low temperature	Medium temperature	
Heat output	4.68 kW	3.74 kW	
El input	1.11 kW	1.37 kW	
СОР	4.23	2.73	

EN 14511-4		
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	
Starting and operating test	passed	


Average Climate



EN 12102-1		
	Low temperature	Medium temperature
Sound power level outdoor	50 dB(A)	50 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_{s}	159 %	127 %
Prated	8.00 kW	8.00 kW
SCOP	4.04	3.34
Tbiv	-8 °C	-8 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7° C	6.80 kW	7.10 kW
$COP Tj = -7^{\circ}C$	2.49	2.18
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = $+2$ °C	4.30 kW	4.20 kW
COP Tj = +2°C	4.04	3.30
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = $+7^{\circ}$ C	4.50 kW	4.20 kW
$COPTj = +7^{\circ}C$	5.08	4.07
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	4.40 kW	4.00 kW

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com





Cdh Tj = +12 °C 0.90 0.90 Pdh Tj = Tbiv 7.10 kW 7.40 kW COP Tj = Tbiv 2.42 2.13 Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh 6.60 kW 7.00 kW COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh 2.71 1.97 WTOL 65 °C 65 °C Poff 16 W 16 W PTO 16 W 16 W PSB 16 W 43 W Supplementary Heater: Type of energy input Electricity Electricity Supplementary Heater: PSUP 0.00 kW 0.00 kW			
Pdh Tj = Tbiv 7.10 kW 7.40 kW COP Tj = Tbiv 2.42 2.13 Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	COP Tj = 12°C	6.30	5.14
COP Tj = Tbiv 2.42 2.13 Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	Pdh Tj = Tbiv	7.10 kW	7.40 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	COP Tj = Tbiv	2.42	2.13
WTOL 65 °C 65 °C Poff 16 W 16 W PTO 16 W 16 W PSB 16 W 16 W PCK 43 W 43 W Supplementary Heater: Type of energy input Electricity Electricity Supplementary Heater: PSUP 0.00 kW 0.00 kW	Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.60 kW	7.00 kW
Poff 16 W 16 W PTO 16 W 16 W PSB 16 W 16 W PCK 43 W 43 W Supplementary Heater: Type of energy input Electricity Electricity Supplementary Heater: PSUP 0.00 kW 0.00 kW	COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.71	1.97
PTO 16 W 16 W 16 W PCK 43 W Supplementary Heater: Type of energy input Electricity Electricity Supplementary Heater: PSUP 0.00 kW 0.00 kW	WTOL	65 °C	65 °C
PSB 16 W 16 W PCK 43 W Supplementary Heater: Type of energy input Electricity Electricity Union of the supplementary Heater: PSUP 0.00 kW 0.00 kW	Poff	16 W	16 W
PCK 43 W 43 W Supplementary Heater: Type of energy input Electricity Electricity Supplementary Heater: PSUP 0.00 kW 0.00 kW	РТО	16 W	16 W
Supplementary Heater: Type of energy input Electricity Electricity Supplementary Heater: PSUP 0.00 kW 0.00 kW	PSB	16 W	16 W
Supplementary Heater: PSUP 0.00 kW 0.00 kW	PCK	43 W	43 W
	Supplementary Heater: Type of energy input	Electricity	Electricity
Annual energy consumption Qhe 4086 kWh 5084 kWh	Supplementary Heater: PSUP	0.00 kW	0.00 kW
	Annual energy consumption Qhe	4086 kWh	5084 kWh

Warmer Climate

EN 14825		
	Low temperature	Medium temperature
η_{S}	190 %	142 %
Prated	4.00 kW	4.00 kW
SCOP	4.83	3.50
	,	





This information was gener	ated by the HI KETMA	NK database on 21 juli 2022
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	4.20 kW	4.00 kW
COP Tj = +2°C	3.48	2.50
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = $+7^{\circ}$ C	4.30 kW	3.90 kW
$COPTj = +7^{\circ}C$	4.46	3.16
Cdh Tj = $+7$ °C	0.90	0.90
Pdh Tj = 12°C	4.30 kW	3.80 kW
COP Tj = 12°C	5.89	4.57
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	4.20 kW	4.00 kW
COP Tj = Tbiv	3.48	2.50
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.20 kW	9.80 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.15	1.98
WTOL	65 °C	65 °C
Poff	16 W	16 W
РТО	16 W	16 W
PSB	16 W	16 W
PCK	43 W	43 W
Supplementary Heater: Type of energy input	Electricity	Electricity





Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1106 kWh	1489 kWh

Colder Climate

	Low temperature	Medium temperature
η_{s}	140 %	119 %
Prated	11.00 kW	12.00 kW
SCOP	3.57	3.09
Tbiv	-10 °C	-10 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	6.80 kW	7.00 kW
COP Tj = -7°C	2.72	2.45
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	4.30 kW	4.20 kW
COP Tj = +2°C	4.45	3.70
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	4.50 kW	4.30 kW
$COP Tj = +7^{\circ}C$	5.44	4.53
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	4.40 kW	4.10 kW



Page 13 of 13

COP Tj = 12°C	6.30	5.44
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	7.70 kW	7.90 kW
COP Tj = Tbiv	2.50	2.28
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.10 kW	9.70 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.25	2.10
WTOL	65 °C	65 °C
Poff	16 W	16 W
РТО	16 W	16 W
PSB	16 W	16 W
PCK	43 W	43 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	11.20 kW	11.61 kW
Annual energy consumption Qhe	7597 kWh	9351 kWh
Pdh Tj = -15°C (if TOL<-20°C)	9.10	9.70
COP Tj = -15°C (if TOL<-20°C)	2.25	2.10
Cdh Tj = -15 °C	0.90	0.90