

Page 1 of 4

### This information was generated by the HP KEYMARK database on 23 Jun 2022

#### **Login**

Summary of	MONO AWHP 11 TR	Reg. No.	037-0004-18
Certificate Holder			
Name	Remeha		
Address		Zip	
City		Country	Netherlands
Certification Body	SZU - Strojirensky zkusebni ustav (Engineering Test Institute, Public Enterprise)		
Subtype title	MONO AWHP 11 TR		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R410A		
Mass of Refrigerant	3.3 kg		
Certification Date	15.10.2018		
Testing basis	HP Keymark scheme rules rev. no. 4		

This information was generated by the HP KEYMARK database on 23 Jun 2022

# **Model: MONO AWHP 11 TR**

Configure model			
Model name	MONO AWHP 11 TR		
Application	Heating (medium temp)		
Units	Outdoor		
Climate Zone	n/a		
Reversibility	No		
Cooling mode application (optional)	n/a		

General Data		
Power supply	3x400V 50Hz	

# Heating

EN 14511-2			
	Low temperature	Medium temperature	
Heat output	11.20 kW	11.20 kW	
El input	2.47 kW	4.15 kW	
СОР	4.54	2.70	

EN 14511-4		
Shutting off the heat transfer medium flow	passed	
Shatting on the heat transfer medium now	passeu	
Complete power supply failure	passed	
Defrost test	passed	

## **Average Climate**



 $$\operatorname{\textit{Page}}\ 3$$  of 4 This information was generated by the HP KEYMARK database on 23 Jun 2022

EN 12102-1		
	Low temperature	Medium temperature
Sound power level outdoor	60 dB(A)	60 dB(A)

	EN 14825	
	Low temperature	Medium temperature
$\eta_{s}$	173 %	134 %
Prated	10.00 kW	10.00 kW
SCOP	4.40	3.44
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	8.90 kW	9.00 kW
COP Tj = -7°C	3.17	1.99
Cdh Tj = -7 °C	0.992	0.995
Pdh Tj = +2°C	5.40 kW	5.70 kW
COP Tj = +2°C	4.23	3.29
Cdh Tj = +2 °C	0.983	0.987
Pdh Tj = +7°C	3.60 kW	4.70 kW
COP Tj = +7°C	5.31	4.88
Cdh Tj = +7 °C	0.968	0.977
Pdh Tj = 12°C	4.30 kW	4.10 kW

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



Page 4 of 4 This information was generated by the HP KEYMARK database on 23 Jun 2022

COP Tj = 12°C	7.66	6.35
Cdh Tj = +12 °C	0.961	0.966
Pdh Tj = Tbiv	8.90 kW	9.00 kW
COP Tj = Tbiv	3.17	1.99
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.35 kW	8.42 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.76	1.87
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.950	0.960
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	o w	o w
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.65 kW	1.58 kW
Annual energy consumption Qhe	4693 kWh	6012 kWh