

This information was generated by the HP KEYMARK database on 18 Mar 2022

[Login](#)

Summary of	Split 200	Reg. No.	011-1W0444
Certificate Holder			
Name	Bosch Termotecnologia S.A.		
Address	EN 16 -Km 3.7 - Cacia	Zip	3800-533
City	Aveiro	Country	Portugal
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Subtype title	Split 200		
Heat Pump Type	Heat Pump for Domestic Hot Water (DHW)		
Refrigerant	R134a		
Mass of Refrigerant	1.55 kg		
Certification Date	29.03.2021		
Testing basis	HP KEYMARK certification scheme rules rev. 8		

Model: Bosch Compress CS3000DW 200-1 S

Configure model

Model name	Bosch Compress CS3000DW 200-1 S
Units	Outdoor
Climate zone (for heating)	n/a
Heat Source	Outdoor Air
Any additional heat sources	n/a

General Data

Power supply	1x230V 50Hz
Off-peak product	No

Domestic Hot Water (DHW)

Average Climate

EN 12102-2	
Sound power level indoor	15 dB(A)
Sound power level outdoor	61 dB(A)

EN 16147	
Declared load profile	M
Efficiency η_{DHW}	119 %
COP	2.44
Heating up time	4:39 h:min
Standby power input	36.0 W
Reference hot water temperature	53.6 °C
Mixed water at 40°C	254 l

Operating test

EN 16147	
Temperature operating range	passed
Safety devices checking test	passed
Condensate draining	passed

Model: Buderus Logatherm WPTS200.1

Configure model	
Model name	Buderus Logatherm WPTS200.1
Units	Outdoor
Climate zone (for heating)	n/a
Heat Source	Outdoor Air
Any additional heat sources	n/a

General Data	
Power supply	1x230V 50Hz
Off-peak product	No

Domestic Hot Water (DHW)

Average Climate

EN 12102-2	
Sound power level indoor	15 dB(A)
Sound power level outdoor	61 dB(A)

EN 16147	
Declared load profile	M
Efficiency η_{DHW}	119 %
COP	2.44
Heating up time	4:39 h:min
Standby power input	36.0 W
Reference hot water temperature	53.6 °C
Mixed water at 40°C	254 l

Operating test

EN 16147	
Temperature operating range	passed
Safety devices checking test	passed
Condensate draining	passed

Model: e.l.m leblanc Ondéa PAC Split 200-1

Configure model	
Model name	e.l.m leblanc Ondéa PAC Split 200-1
Units	Outdoor
Climate zone (for heating)	n/a
Heat Source	Outdoor Air
Any additional heat sources	n/a

General Data	
Power supply	1x230V 50Hz
Off-peak product	No

Domestic Hot Water (DHW)

Average Climate

EN 12102-2	
Sound power level indoor	15 dB(A)
Sound power level outdoor	61 dB(A)

EN 16147	
Declared load profile	M
Efficiency η_{DHW}	119 %
COP	2.44
Heating up time	4:39 h:min
Standby power input	36.0 W
Reference hot water temperature	53.6 °C
Mixed water at 40°C	254 l

Operating test

EN 16147	
Temperature operating range	passed
Safety devices checking test	passed
Condensate draining	passed

This information was generated by the HP KEYMARK database on 18 Mar 2022