

This information was generated by the HP KEYMARK database on 17 Dec 2020

Summary of	CTA Aeroheat CM 18a	Reg. No.	012-SC0321-18
Certificate Holder			
Name	Enertech CTC AB		
Address	Box 309, Näsvägen	Zip	SE-381 26
City	Ljungby	Country	Sweden
Certification Body	RISE CERT		
Name of testing laboratory	DTI		
Subtype title	CTA Aeroheat CM 18a		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R407c		
Mass Of Refrigerant	2.7 kg		

Model: CTA Aeroheat CM 18a

General Data

Power supply	3x400V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	11.38 kW	9.35 kW
El input	2.25 kW	2.84 kW
COP	5.06	3.29
Indoor water flow rate	1.94 m ³ /h	1.01 m ³ /h

EN 14511-4

Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1

	Low temperature	Medium temperature
Sound power level outdoor	56 dB(A)	56 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	193 %	147 %
Prated	8.50 kW	8.50 kW
SCOP	4.92	3.77
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.76 kW	7.52 kW
COP Tj = -7°C	3.53	2.41
Pdh Tj = +2°C	4.49 kW	4.61 kW
COP Tj = +2°C	4.97	3.81
Pdh Tj = +7°C	4.81 kW	4.72 kW
COP Tj = +7°C	5.94	4.76
Pdh Tj = 12°C	5.56 kW	5.55 kW
COP Tj = 12°C	7.35	6.15
Pdh Tj = Tbiv	8.75 kW	8.66 kW
COP Tj = Tbiv	3.04	1.99

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = TOL	8.75 kW	8.66 kW
COP Tj = TOL	3.04	1.99
Cdh	0.98	0.99
WTOL	65 °C	65 °C
Poff	12 W	12 W
PTO	12 W	12 W
PSB	12 W	12 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	3567 kWh	4656 kWh

Colder Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level outdoor	56 dB(A)	56 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	167 %	136 %
Prated	12.50 kW	11.50 kW

This information was generated by the HP KEYMARK database on 17 Dec 2020

SCOP	4.26	3.47
Tbiv	-17 °C	-18 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	7.60 kW	7.29 kW
COP Tj = -7°C	3.67	2.91
Pdh Tj = +2°C	4.70 kW	4.63 kW
COP Tj = +2°C	5.49	4.53
Pdh Tj = +7°C	4.87 kW	4.76 kW
COP Tj = +7°C	6.70	5.28
Pdh Tj = 12°C	5.58 kW	5.55 kW
COP Tj = 12°C	7.77	6.44
Pdh Tj = Tbiv	11.35 kW	10.87 kW
COP Tj = Tbiv	1.99	1.46
Pdh Tj = TOL	4.92 kW	4.57 kW
COP Tj = TOL	1.99	1.51
Cdh	0.98	0.99
WTOL	65 °C	65 °C
Poff	12 W	12 W
PTO	12 W	12 W
PSB	12 W	12 W
PCK	0 W	0 W

This information was generated by the HP KEYMARK database on 17 Dec 2020

Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	12.50 kW	11.50 kW
Annual energy consumption Q _{he}	7225 kWh	8159 kWh