

This information was generated by the HP KEYMARK database on 7 Jul 2022

[Login](#)

Summary of	Alféa Extensa +8	Reg. No.	012-009
Certificate Holder			
Name	Groupe Atlantic		
Address	44 boulevard des Etats-Unis	Zip	85000
City	La Roche Sur Yon	Country	France
Certification Body	RISE CERT		
Subtype title	Alféa Extensa +8		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R410A		
Mass of Refrigerant	1.4 kg		

Model: Alféa Extensa +8

Configure model	
Model name	Alféa Extensa +8
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz
Phase-out Date	12.03.2024

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	7.50 kW	5.00 kW
El input	1.84 kW	1.94 kW
COP	4.08	2.58

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	46 dB(A)	46 dB(A)
Sound power level outdoor	69 dB(A)	69 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	156 %	118 %
Prated	7.00 kW	6.00 kW
SCOP	3.97	3.02
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.80 kW	5.30 kW
COP Tj = -7°C	2.40	1.80
Pdh Tj = +2°C	3.50 kW	3.10 kW
COP Tj = +2°C	3.80	2.90
Pdh Tj = +7°C	2.30 kW	2.00 kW
COP Tj = +7°C	5.70	4.10
Pdh Tj = 12°C	2.40 kW	2.20 kW
COP Tj = 12°C	8.20	5.80

This information was generated by the HP KEYMARK database on 7 Jul 2022

Pdh Tj = Tbiv	5.80 kW	5.30 kW
COP Tj = Tbiv	2.40	1.80
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.60 kW	4.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.00	1.50
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	55 °C	55 °C
Poff	6 W	6 W
PTO	30 W	16 W
PSB	9 W	9 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.90 kW	1.20 kW
Annual energy consumption Qhe	3375 kWh	3836 kWh

Model: Alféa Extensa Duo +8

Configure model	
Model name	Alféa Extensa Duo +8
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz
Phase-out Date	12.03.2024

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	7.50 kW	5.00 kW
El input	1.84 kW	1.94 kW
COP	4.08	2.58

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	46 dB(A)	46 dB(A)
Sound power level outdoor	69 dB(A)	69 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	156 %	118 %
Prated	7.00 kW	6.00 kW
SCOP	3.97	3.02
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.80 kW	5.30 kW
COP Tj = -7°C	2.40	1.80
Pdh Tj = +2°C	3.50 kW	3.10 kW
COP Tj = +2°C	3.80	2.90
Pdh Tj = +7°C	2.30 kW	2.00 kW
COP Tj = +7°C	5.70	4.10
Pdh Tj = 12°C	2.40 kW	2.20 kW
COP Tj = 12°C	8.20	5.80

This information was generated by the HP KEYMARK database on 7 Jul 2022

Pdh Tj = Tbiv	5.80 kW	5.30 kW
COP Tj = Tbiv	2.40	1.80
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.60 kW	4.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.00	1.50
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	55 °C	55 °C
Poff	6 W	6 W
PTO	30 W	16 W
PSB	9 W	9 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.90 kW	1.20 kW
Annual energy consumption Qhe	3375 kWh	3836 kWh

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 7 Jul 2022

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	120 %
COP	3.00
Heating up time	01:45 h:min
Standby power input	32.0 W
Reference hot water temperature	54.0 °C
Mixed water at 40°C	249 l

Model: Alféa Extensa A.I. 8

Configure model	
Model name	Alféa Extensa A.I. 8
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz
Phase-out Date	12.03.2024

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	7.50 kW	5.00 kW
El input	1.84 kW	1.94 kW
COP	4.08	2.58

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	46 dB(A)	46 dB(A)
Sound power level outdoor	69 dB(A)	69 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	156 %	118 %
Prated	7.00 kW	6.00 kW
SCOP	3.97	3.02
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.80 kW	5.30 kW
COP Tj = -7°C	2.40	1.80
Pdh Tj = +2°C	3.50 kW	3.10 kW
COP Tj = +2°C	3.80	2.90
Pdh Tj = +7°C	2.30 kW	2.00 kW
COP Tj = +7°C	5.70	4.10
Pdh Tj = 12°C	2.40 kW	2.20 kW
COP Tj = 12°C	8.20	5.80

This information was generated by the HP KEYMARK database on 7 Jul 2022

Pdh Tj = Tbiv	5.80 kW	5.30 kW
COP Tj = Tbiv	2.40	1.80
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.60 kW	4.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.00	1.50
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	55 °C	55 °C
Poff	6 W	6 W
PTO	30 W	16 W
PSB	9 W	9 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.90 kW	1.20 kW
Annual energy consumption Qhe	3375 kWh	3836 kWh

Model: Alféa Extensa Duo A.I. 8

Configure model	
Model name	Alféa Extensa Duo A.I. 8
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz
Phase-out Date	12.03.2024

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	7.50 kW	5.00 kW
El input	1.84 kW	1.94 kW
COP	4.08	2.58

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	46 dB(A)	46 dB(A)
Sound power level outdoor	69 dB(A)	69 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	156 %	118 %
Prated	7.00 kW	6.00 kW
SCOP	3.97	3.02
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.80 kW	5.30 kW
COP Tj = -7°C	2.40	1.80
Pdh Tj = +2°C	3.50 kW	3.10 kW
COP Tj = +2°C	3.80	2.90
Pdh Tj = +7°C	2.30 kW	2.00 kW
COP Tj = +7°C	5.70	4.10
Pdh Tj = 12°C	2.40 kW	2.20 kW
COP Tj = 12°C	8.20	5.80

This information was generated by the HP KEYMARK database on 7 Jul 2022

Pdh Tj = Tbiv	5.80 kW	5.30 kW
COP Tj = Tbiv	2.40	1.80
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.60 kW	4.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.00	1.50
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	55 °C	55 °C
Poff	6 W	6 W
PTO	30 W	16 W
PSB	9 W	9 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.90 kW	1.20 kW
Annual energy consumption Qhe	3375 kWh	3836 kWh

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 7 Jul 2022

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	120 %
COP	3.00
Heating up time	01:45 h:min
Standby power input	32.0 W
Reference hot water temperature	54.0 °C
Mixed water at 40°C	249 l