

Page 1 of 4

This information was generated by the HP KEYMARK database on 22 Jun 2022

<u>Login</u>

Summary of	BoxAir Inverter BA45I	Reg. No.	037-0066-21
Certificate Holder			
Name	Master Therm tepelna cerpadla s.r.o.		
Address	Vaclavske namesti 819/43	Zip	110 00
City	Praha	Country	Czech Republic
Certification Body	SZU - Strojirensky zkusebni ustav (Engineering Test Institute, Public Enterprise)		
Subtype title	BoxAir Inverter BA45I		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R32		
Mass of Refrigerant	3 kg		
Certification Date	26.01.2021		
Testing basis	HP Keymark scheme rules rev. no. 7		

This information was generated by the HP KEYMARK database on 22 Jun 2022

Model: BoxAir Inverter BA45I

Configure model			
Model name	BoxAir Inverter BA45I		
Application	Heating (medium temp)		
Units	Outdoor		
Climate Zone	n/a		
Reversibility	Yes		
Cooling mode application (optional)	n/a		

General Data		
Power supply	3x400V 50Hz	

Heating

EN 14511-2			
	Low temperature	Medium temperature	
Heat output	15.05 kW	14.27 kW	
El input	3.14 kW	4.51 kW	
СОР	4.80	3.16	

EN 14511-4		
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	
Defrost test	passed	
Starting and operating test	passed	

Average Climate



 $$\operatorname{\textit{Page}}\ 3$$ of 4 This information was generated by the HP KEYMARK database on 22 Jun 2022

EN 12102-1			
	Low temperature	Medium temperature	
Sound power level outdoor	60 dB(A)	60 dB(A)	

EN 14825			
	Low temperature	Medium temperature	
η_{s}	194 %	146 %	
Prated	14.22 kW	13.97 kW	
SCOP	4.92	3.72	
Tbiv	-7 °C	-7 °C	
TOL	-10 °C	-10 °C	
Pdh Tj = -7°C	12.58 kW	12.35 kW	
COP Tj = -7°C	2.87	2.10	
Cdh Tj = -7 °C	0.90	0.90	
Pdh Tj = +2°C	7.28 kW	6.92 kW	
COP Tj = +2°C	4.75	3.67	
Cdh Tj = +2 °C	0.90	0.90	
Pdh Tj = +7°C	5.02 kW	4.95 kW	
COP Tj = +7°C	6.91	5.07	
Cdh Tj = +7 °C	0.90	0.90	
Pdh Tj = 12°C	4.44 kW	4.30 kW	

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



Page 4 of 4 This information was generated by the HP KEYMARK database on 22 Jun 2022

COP Tj = 12°C	8.54	6.46
Cdh Tj = +12 °C	0.96	0.97
Pdh Tj = Tbiv	12.58 kW	12.35 kW
COP Tj = Tbiv	2.87	2.10
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.69 kW	12.01 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.63	1.92
WTOL	60 °C	60 °C
Poff	19 W	19 W
РТО	19 W	19 W
PSB	19 W	19 W
PCK	o w	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.53 kW	1.96 kW
Annual energy consumption Qhe	5967 kWh	7748 kWh