

This information was generated by the HP KEYMARK database on 22 Jun 2022

[Login](#)

Summary of	Assure Mono 5 7 9	Reg. No.	ICIM-PDC-000081-00
Certificate Holder			
Name	BAXI Heating UK Limited		
Address	Acordn House, Coventry road	Zip	CV34 4RT
City	Warwick	Country	United Kingdom
Certification Body	ICIM S.p.A.		
Subtype title	Assure Mono 5 7 9		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R32		
Mass of Refrigerant	2 kg		
Certification Date	25.06.2020		
Testing basis	HP KEYMARK certification scheme rules rev. 7		

Model: Assure Mono 5

Configure model	
Model name	Assure Mono 5
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	4.65 kW	4.65 kW
El input	0.93 kW	1.77 kW
COP	5.00	2.63

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

Average Climate

This information was generated by the HP KEYMARK database on 22 Jun 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	dB(A)	dB(A)
Sound power level outdoor	61 dB(A)	61 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	176 %	127 %
Prated	7.00 kW	7.00 kW
SCOP	4.47	3.24
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.88 kW	5.83 kW
COP Tj = -7°C	2.91	1.97
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	3.64 kW	3.68 kW
COP Tj = +2°C	4.38	3.22
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	2.42 kW	2.47 kW
COP Tj = +7°C	5.89	4.21
Cdh Tj = +7 °C	0.90	0.90

This information was generated by the HP KEYMARK database on 22 Jun 2022

Pdh Tj = 12°C	1.03 kW	1.26 kW
COP Tj = 12°C	5.89	4.91
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	5.88 kW	5.83 kW
COP Tj = Tbiv	2.91	1.97
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.62 kW	5.86 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.63	1.62
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	9 W	9 W
PTO	9 W	9 W
PSB	9 W	9 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.70 kW
Annual energy consumption Qhe	3071 kWh	4203 kWh

Model: Assure Mono 7

Configure model	
Model name	Assure Mono 7
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	6.65 kW	6.80 kW
El input	1.35 kW	2.42 kW
COP	4.94	2.81

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

Average Climate

This information was generated by the HP KEYMARK database on 22 Jun 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	dB(A)	dB(A)
Sound power level outdoor	64 dB(A)	64 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	176 %	127 %
Prated	7.00 kW	7.00 kW
SCOP	4.47	3.24
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.88 kW	5.83 kW
COP Tj = -7°C	2.91	1.97
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	3.64 kW	3.68 kW
COP Tj = +2°C	4.38	3.22
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	2.42 kW	2.47 kW
COP Tj = +7°C	5.89	4.21
Cdh Tj = +7 °C	0.90	0.90

This information was generated by the HP KEYMARK database on 22 Jun 2022

Pdh Tj = 12°C	1.03 kW	1.26 kW
COP Tj = 12°C	5.89	4.91
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	5.88 kW	5.83 kW
COP Tj = Tbiv	2.91	1.97
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.62 kW	5.86 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.63	1.62
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	9 W	9 W
PTO	6 W	6 W
PSB	9 W	9 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.70 kW
Annual energy consumption Qhe	3701 kWh	4203 kWh

Model: Assure Mono 9

Configure model	
Model name	Assure Mono 9
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	8.60 kW	8.60 kW
El input	1.87 kW	3.12 kW
COP	4.60	2.75

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

Average Climate

This information was generated by the HP KEYMARK database on 22 Jun 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	dB(A)	dB(A)
Sound power level outdoor	67 dB(A)	67 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	177 %	126 %
Prated	8.00 kW	7.00 kW
SCOP	4.51	3.22
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.42 kW	6.58 kW
COP Tj = -7°C	2.80	1.87
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	4.83 kW	4.25 kW
COP Tj = +2°C	4.33	3.19
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	3.20 kW	2.80 kW
COP Tj = +7°C	6.20	4.38
Cdh Tj = +7 °C	0.90	0.90

This information was generated by the HP KEYMARK database on 22 Jun 2022

Pdh Tj = 12°C	1.55 kW	1.27 kW
COP Tj = 12°C	7.61	5.04
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	7.42 kW	6.58 kW
COP Tj = Tbiv	2.80	1.87
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.64 kW	5.53 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.54	1.51
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	9 W	9 W
PTO	10 W	10 W
PSB	9 W	9 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.80 kW	1.80 kW
Annual energy consumption Qhe	3844 kWh	4770 kWh