

This information was generated by the HP KEYMARK database on 23 Jun 2022

[Login](#)

Summary of	BHP 080 100 W	Reg. No.	041-K011-09
Certificate Holder			
Name	AERMEC S.p.A.		
Address	Via Roma 996	Zip	37040
City	Bevilacqua (VR)	Country	Italy
Certification Body	BRE Global Limited		
Subtype title	BHP 080 100 W		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R32		
Mass of Refrigerant	1.6 kg		
Certification Date	30.07.2021		
Testing basis	HP Keymark Scheme Rules Rev 08		

Model: BHP 080 + BHP 100 W

Configure model	
Model name	BHP 080 + BHP 100 W
Application	Heating + DHW
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2	
	Medium temperature
Heat output	7.98 kW
El input	2.60 kW
COP	3.06

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 23 Jun 2022

EN 12102-1

Medium temperature

Sound power level indoor

42 dB(A)

Sound power level outdoor

67 dB(A)

EN 14825

Medium temperature

 η_s

129 %

Prated

7.00 kW

SCOP

3.31

Tbiv

-7 °C

TOL

-10 °C

Pdh Tj = -7°C

6.34 kW

COP Tj = -7°C

2.24

Cdh Tj = -7 °C

0.99

Pdh Tj = +2°C

4.08 kW

COP Tj = +2°C

3.18

Cdh Tj = +2 °C

0.98

Pdh Tj = +7°C

4.26 kW

COP Tj = +7°C

4.26

Cdh Tj = +7 °C

0.97

This information was generated by the HP KEYMARK database on 23 Jun 2022

Pdh Tj = 12°C	5.01 kW
COP Tj = 12°C	5.93
Cdh Tj = +12 °C	0.97
Pdh Tj = Tbiv	6.34 kW
COP Tj = Tbiv	2.24
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.29 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	1.79
WTOL	60 °C
Poff	25 W
PTO	25 W
PSB	25 W
PCK	25 W
Supplementary Heater: Type of energy input	Electricity
Supplementary Heater: PSUP	0.70 kW
Annual energy consumption Qhe	4371 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	XL
Efficiency η_{DHW}	116 %
COP	2.76
Heating up time	2.7 h:min
Standby power input	54.5 W
Reference hot water temperature	52.8 °C
Mixed water at 40°C	341 l

Model: BHP 100 + BHP 100 W

Configure model	
Model name	BHP 100 + BHP 100 W
Application	Heating + DHW
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2	
	Medium temperature
Heat output	9.47 kW
El input	3.12 kW
COP	3.04

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 23 Jun 2022

EN 12102-1

	Medium temperature
Sound power level indoor	42 dB(A)
Sound power level outdoor	68 dB(A)

EN 14825

	Medium temperature
η_s	127 %
Prated	8.00 kW
SCOP	3.25
Tbiv	-7 °C
TOL	-10 °C
Pdh Tj = -7°C	6.91 kW
COP Tj = -7°C	2.12
Cdh Tj = -7 °C	0.99
Pdh Tj = +2°C	4.22 kW
COP Tj = +2°C	3.09
Cdh Tj = +2 °C	0.98
Pdh Tj = +7°C	4.27 kW
COP Tj = +7°C	4.34
Cdh Tj = +7 °C	0.97

This information was generated by the HP KEYMARK database on 23 Jun 2022

Pdh Tj = 12°C	4.91 kW
COP Tj = 12°C	5.91
Cdh Tj = +12 °C	0.97
Pdh Tj = Tbiv	6.91 kW
COP Tj = Tbiv	2.12
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.85 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	1.75
WTOL	60 °C
Poff	25 W
PTO	25 W
PSB	25 W
PCK	25 W
Supplementary Heater: Type of energy input	Electricity
Supplementary Heater: PSUP	1.20 kW
Annual energy consumption Qhe	5091 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	XL
Efficiency η_{DHW}	116 %
COP	2.76
Heating up time	2.7 h:min
Standby power input	54.5 W
Reference hot water temperature	52.8 °C
Mixed water at 40°C	341 l