

$$\operatorname{\textit{Page}}\ 1$$ of 4 This information was generated by the HP KEYMARK database on 27 Jan 2021

Summary of	BoxAir Inverter BA60I-1	Reg. No.	037-0067-21
Certificate Holder			
Name	Master Therm tepelna cerpadla s.r.o.		
Address	Vaclavske namesti 819/43	Zip	110 00
City	Praha	Country	Czech Republic
Certification Body	SZU - Strojirensky zkusebni ustav (Engineering Test Institute, Public Enterprise)		
Subtype title	BoxAir Inverter BA60I-1		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R410a		
Mass Of Refrigerant	6.9 kg		
Certification Date	26.01.2021		
Testing basis	HP Keymark scheme rules rev. no. 7		



This information was generated by the HP KEYMARK database on 27 Jan 2021

Model: BoxAir Inverter BA60I-1

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2			
	Low temperature	Medium temperature	
Heat output	19.83 kW	22.96 kW	
El input	4.24 kW	7.40 kW	
СОР	4.68	3.10	
Indoor water flow rate	3.42 m³/h	2.47 m³/h	

EN 14511-4		
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	
Defrost test	passed	
Starting and operating test	passed	

Average Climate



 $$\operatorname{\textit{Page}}\xspace$ 3 of 4 This information was generated by the HP KEYMARK database on 27 Jan 2021

	EN 12102-1		
	Low temperature	Medium temperature	
Sound power level outdoor	66 dB(A)	66 dB(A)	

EN 14825		
	Low temperature	Medium temperature
η_s	177 %	135 %
Prated	22.57 kW	22.06 kW
SCOP	4.50	3.45
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	20.64 kW	20.77 kW
COP Tj = -7°C	2.64	2.04
Cdh	0.90	0.90
Pdh Tj = +2°C	12.68 kW	12.27 kW
COP Tj = +2°C	4.21	3.22
Cdh	0.90	0.90
Pdh Tj = +7°C	8.04 kW	7.81 kW
COP Tj = +7°C	6.61	5.06
Cdh	0.90	0.90
Pdh Tj = 12°C	9.26 kW	9.01 kW
		·

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



Page 4 of 4 This information was generated by the HP KEYMARK database on 27 Jan 2021

COP Tj = 12°C	8.02	6.13
Cdh	0.98	0.98
Pdh Tj = Tbiv	22.57 kW	22.06 kW
COP Tj = Tbiv	2.35	1.55
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	22.57 kW	22.06 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.35	1.55
WTOL	60 °C	60 °C
Poff	27 W	27 W
РТО	26 W	26 W
PSB	27 W	27 W
PCK	o w	o w
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	10350 kWh	13226 kWh