

This information was generated by the HP KEYMARK database on 18 Mar 2022

[Login](#)

Summary of	ACV Alféa Excellia Tri 14 BS	Reg. No.	012-C700004
Certificate Holder			
Name	Groupe Atlantic		
Address	44 boulevard des Etats-Unis	Zip	85000
City	La Roche Sur Yon	Country	France
Certification Body	RISE CERT		
Subtype title	ACV Alféa Excellia Tri 14 BS		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R410A		
Mass of Refrigerant	2.5 kg		
Certification Date	19.12.2019		
Testing basis	EN 14511:2013; EN 14825:2013; EN 12102:2013		

Model: ACV Alféa Excellia Tri 14 BS

Configure model	
Model name	ACV Alféa Excellia Tri 14 BS
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	13.00 kW	10.60 kW
El input	3.11 kW	4.40 kW
COP	4.18	2.41

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

Average Climate

EHPA Secretariat | Rue d'Arlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	46 dB(A)	46 dB(A)
Sound power level outdoor	69 dB(A)	69 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	150 %	117 %
Prated	13.00 kW	11.00 kW
SCOP	3.82	3.00
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	11.10 kW	10.00 kW
COP Tj = -7°C	2.50	2.00
Pdh Tj = +2°C	6.70 kW	6.10 kW
COP Tj = +2°C	3.70	2.90
Pdh Tj = +7°C	6.20 kW	5.90 kW
COP Tj = +7°C	5.40	4.10
Pdh Tj = 12°C	7.30 kW	7.10 kW
COP Tj = 12°C	7.00	5.40
Pdh Tj = Tbiv	11.10 kW	10.00 kW

This information was generated by the HP KEYMARK database on 18 Mar 2022

COP $T_j = T_{biv}$	2.50	2.00
$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	10.80 kW	9.30 kW
COP $T_j = TOL$ or COP $T_j = T_{designh}$ if $TOL < T_{designh}$	2.40	1.60
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	0.90	0.90
WTOL	60 °C	60 °C
P _{off}	14 W	14 W
PTO	66 W	43 W
PSB	17 W	17 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.70 kW	2.00 kW
Annual energy consumption Q _{he}	6738 kWh	7803 kWh