

This information was generated by the HP KEYMARK database on 17 Dec 2020

| | | | |
|----------------------------|-------------------|----------|-----------|
| Summary of | CTC EcoPart 414 | Reg. No. | 012-066 |
| Certificate Holder | | | |
| Name | Enertech CTC AB | | |
| Address | Box 309, Näsvägen | Zip | SE-381 26 |
| City | Ljungby | Country | Sweden |
| Certification Body | RISE CERT | | |
| Name of testing laboratory | RISE | | |
| Subtype title | CTC EcoPart 414 | | |
| Heat Pump Type | Brine/Water | | |
| Refrigerant | R407c | | |
| Mass Of Refrigerant | 2.7 kg | | |

Model: CTC EcoPart 414 1x230V

General Data

| | |
|--------------|-------------|
| Power supply | 1x230V 50Hz |
|--------------|-------------|

Heating

EN 14511-2

| | Low temperature | Medium temperature |
|------------------------|------------------------|------------------------|
| Heat output | 14.51 kW | 13.45 kW |
| El input | 3.19 kW | 4.32 kW |
| COP | 4.55 | 3.11 |
| Indoor water flow rate | 2.44 m ³ /h | 2.45 m ³ /h |

EN 14511-4

| Operating range outdoor exchanger/indoor exchanger lower limit/lower limit | passed |
|--|--------|
| Operating range outdoor exchanger/indoor exchanger upper limit/upper limit | passed |
| Shutting off the heat transfer medium flow | passed |
| Complete power supply failure | passed |

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1

| | Low temperature | Medium temperature |
|--------------------------|-----------------|--------------------|
| Sound power level indoor | 53 dB(A) | 53 dB(A) |

EN 14825

| | Low temperature | Medium temperature |
|---------------|-----------------|--------------------|
| η_s | 174 % | 137 % |
| Prated | 16.47 kW | 16.12 kW |
| SCOP | 4.60 | 3.60 |
| Tbiv | -7 °C | -6 °C |
| TOL | -10 °C | -10 °C |
| Pdh Tj = -7°C | 14.60 kW | 13.60 kW |
| COP Tj = -7°C | 4.64 | 3.29 |
| Pdh Tj = +2°C | 14.70 kW | 13.90 kW |
| COP Tj = +2°C | 4.81 | 3.68 |
| Pdh Tj = +7°C | 14.80 kW | 14.20 kW |
| COP Tj = +7°C | 4.97 | 4.03 |
| Pdh Tj = 12°C | 14.90 kW | 14.40 kW |
| COP Tj = 12°C | 5.13 | 4.37 |
| Pdh Tj = Tbiv | 14.60 kW | 13.60 kW |
| COP Tj = Tbiv | 4.64 | 3.34 |

This information was generated by the HP KEYMARK database on 17 Dec 2020

| | | |
|--|-------------|-------------|
| Pdh Tj = TOL | 14.51 kW | 13.45 kW |
| COP Tj = TOL | 4.55 | 3.11 |
| Cdh | 0.96 | 0.99 |
| WTOL | 65 °C | 65 °C |
| Poff | 18 W | 18 W |
| PTO | 97 W | 35 W |
| PSB | 18 W | 18 W |
| PCK | 0 W | 0 W |
| Supplementary Heater: Type of energy input | electricity | electricity |
| Supplementary Heater: PSUP | 2.00 kW | 2.70 kW |
| Annual energy consumption Qhe | 7467 kWh | 9158 kWh |

Colder Climate

| EN 12102-1 | | |
|--------------------------|------------------------|---------------------------|
| | Low temperature | Medium temperature |
| Sound power level indoor | 53 dB(A) | 53 dB(A) |

| EN 14825 | | |
|-----------------|------------------------|---------------------------|
| | Low temperature | Medium temperature |
| η_s | 176 % | 140 % |
| Prated | 16.30 kW | 15.19 kW |

This information was generated by the HP KEYMARK database on 17 Dec 2020

| | | |
|---------------|----------|----------|
| SCOP | 4.60 | 3.70 |
| Tbiv | -18 °C | -18 °C |
| TOL | -22 °C | -22 °C |
| Pdh Tj = -7°C | 14.70 kW | 13.80 kW |
| COP Tj = -7°C | 4.84 | 3.59 |
| Pdh Tj = +2°C | 14.80 kW | 14.10 kW |
| COP Tj = +2°C | 4.98 | 3.94 |
| Pdh Tj = +7°C | 14.90 kW | 14.30 kW |
| COP Tj = +7°C | 5.08 | 4.26 |
| Pdh Tj = 12°C | 14.90 kW | 14.50 kW |
| COP Tj = 12°C | 5.11 | 4.49 |
| Pdh Tj = Tbiv | 14.60 kW | 13.60 kW |
| COP Tj = Tbiv | 4.67 | 3.28 |
| Pdh Tj = TOL | 14.51 kW | 13.45 kW |
| COP Tj = TOL | 4.55 | 3.11 |
| Cdh | 0.96 | 0.99 |
| WTOL | 65 °C | 65 °C |
| Poff | 18 W | 18 W |
| PTO | 97 W | 32 W |
| PSB | 18 W | 18 W |
| PCK | 0 W | 0 W |

This information was generated by the HP KEYMARK database on 17 Dec 2020

| | | |
|--|-------------|-------------|
| Supplementary Heater: Type of energy input | electricity | electricity |
| Supplementary Heater: PSUP | 1.80 kW | 1.70 kW |
| Annual energy consumption Q _{he} | 8758 kWh | 10139 kWh |

Model: CTC EcoPart 414 3x400V

General Data

| | |
|--------------|-------------|
| Power supply | 3x400V 50Hz |
|--------------|-------------|

Heating

EN 14511-2

| | Low temperature | Medium temperature |
|------------------------|------------------------|------------------------|
| Heat output | 14.51 kW | 13.45 kW |
| El input | 3.19 kW | 4.32 kW |
| COP | 4.55 | 3.11 |
| Indoor water flow rate | 2.44 m ³ /h | 2.45 m ³ /h |

EN 14511-4

| Operating range outdoor exchanger/indoor exchanger lower limit/lower limit | passed |
|--|--------|
| Operating range outdoor exchanger/indoor exchanger upper limit/upper limit | passed |
| Shutting off the heat transfer medium flow | passed |
| Complete power supply failure | passed |

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1

| | Low temperature | Medium temperature |
|--------------------------|-----------------|--------------------|
| Sound power level indoor | 53 dB(A) | 53 dB(A) |

EN 14825

| | Low temperature | Medium temperature |
|---------------|-----------------|--------------------|
| η_s | 174 % | 137 % |
| Prated | 16.47 kW | 16.12 kW |
| SCOP | 4.60 | 3.60 |
| Tbiv | -7 °C | -6 °C |
| TOL | -10 °C | -10 °C |
| Pdh Tj = -7°C | 14.60 kW | 13.60 kW |
| COP Tj = -7°C | 4.64 | 3.29 |
| Pdh Tj = +2°C | 14.70 kW | 13.90 kW |
| COP Tj = +2°C | 4.81 | 3.68 |
| Pdh Tj = +7°C | 14.80 kW | 14.20 kW |
| COP Tj = +7°C | 4.97 | 4.03 |
| Pdh Tj = 12°C | 14.90 kW | 14.40 kW |
| COP Tj = 12°C | 5.13 | 4.37 |
| Pdh Tj = Tbiv | 14.60 kW | 13.60 kW |
| COP Tj = Tbiv | 4.64 | 3.34 |

This information was generated by the HP KEYMARK database on 17 Dec 2020

| | | |
|--|-------------|-------------|
| Pdh Tj = TOL | 14.51 kW | 13.45 kW |
| COP Tj = TOL | 4.55 | 3.11 |
| Cdh | 0.96 | 0.99 |
| WTOL | 65 °C | 65 °C |
| Poff | 18 W | 18 W |
| PTO | 97 W | 35 W |
| PSB | 18 W | 18 W |
| PCK | 0 W | 0 W |
| Supplementary Heater: Type of energy input | electricity | electricity |
| Supplementary Heater: PSUP | 2.00 kW | 2.70 kW |
| Annual energy consumption Qhe | 7467 kWh | 9158 kWh |

Colder Climate

| EN 12102-1 | | |
|--------------------------|------------------------|---------------------------|
| | Low temperature | Medium temperature |
| Sound power level indoor | 53 dB(A) | 53 dB(A) |

| EN 14825 | | |
|-----------------|------------------------|---------------------------|
| | Low temperature | Medium temperature |
| η_s | 176 % | 140 % |
| Prated | 16.30 kW | 15.19 kW |

This information was generated by the HP KEYMARK database on 17 Dec 2020

| | | |
|---------------|----------|----------|
| SCOP | 4.60 | 3.70 |
| Tbiv | -18 °C | -18 °C |
| TOL | -22 °C | -22 °C |
| Pdh Tj = -7°C | 14.70 kW | 13.80 kW |
| COP Tj = -7°C | 4.84 | 3.59 |
| Pdh Tj = +2°C | 14.80 kW | 14.10 kW |
| COP Tj = +2°C | 4.98 | 3.94 |
| Pdh Tj = +7°C | 14.90 kW | 14.30 kW |
| COP Tj = +7°C | 5.08 | 4.26 |
| Pdh Tj = 12°C | 14.90 kW | 14.50 kW |
| COP Tj = 12°C | 5.11 | 4.49 |
| Pdh Tj = Tbiv | 14.60 kW | 13.60 kW |
| COP Tj = Tbiv | 4.67 | 3.28 |
| Pdh Tj = TOL | 14.51 kW | 13.45 kW |
| COP Tj = TOL | 4.55 | 3.11 |
| Cdh | 0.96 | 0.99 |
| WTOL | 65 °C | 65 °C |
| Poff | 18 W | 18 W |
| PTO | 97 W | 32 W |
| PSB | 18 W | 18 W |
| PCK | 0 W | 0 W |

This information was generated by the HP KEYMARK database on 17 Dec 2020

| | | |
|--|-------------|-------------|
| Supplementary Heater: Type of energy input | electricity | electricity |
| Supplementary Heater: PSUP | 1.80 kW | 1.70 kW |
| Annual energy consumption Qhe | 8758 kWh | 10139 kWh |