

Summary of	AEROTOP S07.2	Reg. No.	011-1W0391	
Certificate Holder				
Name	ELCO GmbH			
Address	Hohenzollernstrasse 31	Zip	72379	
City	Hechingen	Country	Germany	
Certification Body	DIN CERTCO Gesellschaft für Ko	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Name of testing laboratory	Heat Pump Test Center WPZ			
Subtype title	AEROTOP S07.2			
Heat Pump Type	Outdoor Air/Water			
Refrigerant	R410a			
Mass Of Refrigerant	4 kg			
Certification Date	28.07.2020			



Model: AEROTOP S07.2

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2			
	Low temperature	Medium temperature	
Heat output	5.72 kW	4.76 kW	
El input	1.14 kW	1.75 kW	
СОР	5.02	2.72	
Indoor water flow rate	1.00 m³/h	0.82 m³/h	

EN 14511-4		
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	
Defrost test	passed	
Starting and operating test	passed	

Average Climate



EN 12102-1		
Low temperature Medium temperature		
Sound power level indoor	44 dB(A)	44 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_{s}	199 %	142 %
Prated	7.90 kW	7.42 kW
SCOP	5.06	3.61
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	6.99 kW	6.56 kW
COP Tj = -7°C	3.43	2.55
Cdh	0.99	0.99
Pdh Tj = +2°C	5.01 kW	3.89 kW
COP Tj = +2°C	5.01	3.60
Cdh	0.97	0.97
Pdh Tj = +7°C	2.82 kW	2.65 kW
COP Tj = +7°C	6.35	4.65
Cdh	0.94	0.94
Pdh Tj = 12°C	3.09 kW	2.99 kW

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com





	<u> </u>	
COP Tj = 12°C	7.92	5.86
Cdh	0.93	0.93
Pdh Tj = Tbiv	6.99 kW	6.56 kW
COP Tj = Tbiv	3.43	2.55
Pdh Tj = TOL	7.38 kW	6.96 kW
COP Tj = TOL	3.01	2.01
WTOL	63 °C	63 °C
Poff	35 W	35 W
РТО	36 W	36 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.52 kW	0.46 kW
Annual energy consumption Qhe	3229 kWh	4240 kWh

Warmer Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)

EN 1	4825	
	Low temperature	Medium temperature





η_{S}	245 %	174 %
Prated	7.98 kW	8.02 kW
SCOP	6.20	4.42
Tbiv	2 °C	2 °C
TOL	-20 °C	-20 °C
Pdh Tj = +2°C	7.98 kW	8.02 kW
COP Tj = +2°C	4.18	2.80
Cdh	0.97	0.97
Pdh Tj = +7°C	5.20 kW	5.14 kW
COP Tj = +7°C	5.78	3.89
Cdh	0.94	0.94
Pdh Tj = 12°C	3.04 kW	2.98 kW
COP Tj = 12°C	7.41	5.52
Cdh	0.93	0.93
Pdh Tj = Tbiv	7.98 kW	8.02 kW
COP Tj = Tbiv	4.18	2.80
Pdh Tj = TOL	7.98 kW	8.02 kW
COP Tj = TOL	4.18	4.42
WTOL	63 °C	63 °C
Poff	35 W	35 W
РТО	36 W	36 W

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com





PSB	15 W	15 W
PCK	o w	o w
Supplementary Heater: Type of energy input	Electricity	Elctricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1719 kWh	2427 kWh

Colder Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)

	Low temperature	Medium temperature
η_{s}	159 %	127 %
Prated	10.50 kW	9.19 kW
SCOP	4.06	3.25
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	6.71 kW	5.87 kW
COP Tj = -7°C	3.79	2.96
Cdh	0.99	0.99





		IARK database on 17 Dec 202
Pdh Tj = +2°C	4.12 kW	3.75 kW
COP Tj = +2°C	5.42	4.13
Cdh	0.97	0.97
Pdh Tj = +7°C	2.78 kW	2.73 kW
COP Tj = +7°C	6.62	5.28
Cdh	0.94	0.94
Pdh Tj = 12°C	3.09 kW	3.05 kW
COP Tj = 12°C	7.92	6.24
Cdh	0.93	0.93
Pdh Tj = Tbiv	6.71 kW	5.87 kW
COP Tj = Tbiv	3.79	2.96
Pdh Tj = TOL	5.55 kW	5.23 kW
COP Tj = TOL	2.26	1.50
WTOL	63 °C	63 °C
Poff	35 W	35 W
РТО	36 W	36 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	4.95 kW	3.96 kW
Annual energy consumption Qhe	6733 kWh	7352 kWh
		-



Page 8 of 15

Pdh Tj = -15 °C (if TOL< -20 °C)	
COP Tj = -15 °C (if TOL< -20 °C)	
Cdh	



Model: AEROTOP S07.2_2-parts

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2			
	Low temperature	Medium temperature	
Heat output	5.72 kW	4.76 kW	
El input	1.14 kW	1.75 kW	
СОР	5.02	2.72	
Indoor water flow rate	1.00 m³/h	0.82 m³/h	

EN 14511-4		
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	
Defrost test	passed	
Starting and operating test	passed	

Average Climate



 $$\operatorname{\textit{Page}}\ 10$$ of 15 This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1			
Low temperature Medium temperature			
Sound power level indoor	44 dB(A)	44 dB(A)	

EN 14825		
	Low temperature	Medium temperature
η_{s}	199 %	142 %
Prated	7.90 kW	7.42 kW
SCOP	5.06	3.61
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	6.99 kW	6.56 kW
COP Tj = -7°C	3.43	2.55
Cdh	0.99	0.99
Pdh Tj = +2°C	5.01 kW	3.89 kW
COP Tj = +2°C	5.01	3.60
Cdh	0.97	0.97
Pdh Tj = +7°C	2.82 kW	2.65 kW
COP Tj = +7°C	6.35	4.65
Cdh	0.94	0.94
Pdh Tj = 12°C	3.09 kW	2.99 kW

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com





 $$\operatorname{Page}\ 11$$ of 15 This information was generated by the HP KEYMARK database on 17 Dec 2020

	<u> </u>	
COP Tj = 12°C	7.92	5.86
Cdh	0.93	0.93
Pdh Tj = Tbiv	6.99 kW	6.56 kW
COP Tj = Tbiv	3.43	2.55
Pdh Tj = TOL	7.38 kW	6.96 kW
COP Tj = TOL	3.01	2.01
WTOL	63 °C	63 °C
Poff	35 W	35 W
РТО	36 W	36 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.52 kW	0.46 kW
Annual energy consumption Qhe	3229 kWh	4240 kWh

Warmer Climate


EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)

EN 14825		
	Low temperature	Medium temperature





η_{S}	245 %	174 %
Prated	7.98 kW	8.02 kW
SCOP	6.20	4.42
Tbiv	2 °C	2 °C
TOL	-20 °C	-20 °C
Pdh Tj = +2°C	7.98 kW	8.02 kW
COP Tj = +2°C	4.18	2.80
Cdh	0.97	0.97
Pdh Tj = +7°C	5.20 kW	5.14 kW
COP Tj = +7°C	5.78	3.89
Cdh	0.94	0.94
Pdh Tj = 12°C	3.04 kW	2.98 kW
COP Tj = 12°C	7.41	5.52
Cdh	0.93	0.93
Pdh Tj = Tbiv	7.98 kW	8.02 kW
COP Tj = Tbiv	4.18	2.80
Pdh Tj = TOL	7.98 kW	8.02 kW
COP Tj = TOL	4.18	4.42
WTOL	63 °C	63 °C
Poff	35 W	35 W
РТО	36 W	36 W





PSB	15 W	15 W
PCK	o w	0 W
Supplementary Heater: Type of energy input	Electricity	Elctricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1719 kWh	2427 kWh

Colder Climate

EN 12102-1				
	Low temperature	Medium temperature		
Sound power level indoor	44 dB(A)	44 dB(A)		

EN 14825			
	Low temperature	Medium temperature	
η_{s}	159 %	127 %	
Prated	10.50 kW	9.19 kW	
SCOP	4.06	3.25	
Tbiv	-7 °C	-7 °C	
TOL	-20 °C	-20 °C	
Pdh Tj = -7°C	6.71 kW	5.87 kW	
COP Tj = -7°C	3.79	2.96	
Cdh	0.99	0.99	





This information was g	enerated by the in Rein	ATTIC GOLGBOSE OIL IT DEC 2020
Pdh Tj = +2°C	4.12 kW	3.75 kW
COP Tj = +2°C	5.42	4.13
Cdh	0.97	0.97
Pdh Tj = $+7$ °C	2.78 kW	2.73 kW
$COP Tj = +7^{\circ}C$	6.62	5.28
Cdh	0.94	0.94
Pdh Tj = 12°C	3.09 kW	3.05 kW
COP Tj = 12°C	7.92	6.24
Cdh	0.93	0.93
Pdh Tj = Tbiv	6.71 kW	5.87 kW
COP Tj = Tbiv	3.79	2.96
Pdh Tj = TOL	5.55 kW	5.23 kW
COP Tj = TOL	2.26	1.50
WTOL	63 °C	63 °C
Poff	35 W	35 W
РТО	36 W	36 W
PSB	15 W	15 W
PCK	0 W	o w
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	4.95 kW	3.96 kW
Annual energy consumption Qhe	6733 kWh	7352 kWh
	·	



Page 15 of 15

Pdh Tj = -15°C (if TOL<-20°C)	
COP Tj = -15 °C (if TOL< -20 °C)	
Cdh	