

This information was generated by the HP KEYMARK database on 23 Jun 2022

[Login](#)

| | | | |
|---------------------|--|----------|-------------|
| Summary of | Baxi Platinum BC Mural iR32 6/8 & Platinum BC Integra iR32 6/8 | Reg. No. | 21HK0026/00 |
| Certificate Holder | | | |
| Name | BAXI Climatización S.L.U | | |
| Address | López de Hoyos 35 | Zip | 28002 |
| City | Madrid | Country | Spain |
| Certification Body | Kiwa Nederland B.V. | | |
| Subtype title | Baxi Platinum BC Mural iR32 6/8 & Platinum BC Integra iR32 6/8 | | |
| Heat Pump Type | Outdoor Air/Water | | |
| Refrigerant | R32 | | |
| Mass of Refrigerant | 1.2 kg | | |
| Certification Date | 03.12.2021 | | |
| Testing basis | European KEYMARK Scheme for Heat Pumps (v9) | | |

Model: AWHPR 6 MR + iMPI/E 4-8 iR32

| Configure model | |
|-------------------------------------|------------------------------|
| Model name | AWHPR 6 MR + iMPI/E 4-8 iR32 |
| Application | Heating (medium temp) |
| Units | Indoor + Outdoor |
| Climate Zone | n/a |
| Reversibility | Yes |
| Cooling mode application (optional) | +7°C/12°C and +18°C/+23°C |

| General Data | |
|--------------|-------------|
| Power supply | 1x230V 50Hz |

Heating

| EN 14511-2 | | |
|-------------|-----------------|--------------------|
| | Low temperature | Medium temperature |
| Heat output | 6.40 kW | 5.70 kW |
| El input | 1.28 kW | 1.97 kW |
| COP | 5.00 | 2.90 |

| EN 14511-4 | |
|--|--------|
| Shutting off the heat transfer medium flow | passed |
| Complete power supply failure | passed |
| Defrost test | passed |
| Starting and operating test | passed |

Cooling

This information was generated by the HP KEYMARK database on 23 Jun 2022

| EN 14511-2 | | |
|-------------------|-------------------|--------------------|
| | +7°C/+12°C | +18°C/+23°C |
| El input | 2.10 kW | 1.36 kW |
| Cooling capacity | 6.50 | 7.00 |
| EER | 3.09 | 5.14 |

This information was generated by the HP KEYMARK database on 23 Jun 2022

| EN 14825 | | |
|---|-------------------|--------------------|
| | +7°C/+12°C | +18°C/+23°C |
| P _{designc} | 6.50 kW | 7.00 kW |
| SEER | 4.01 | 6.49 |
| P _{dc} T _j = 35°C | 6.50 kW | 7.00 kW |
| EER T _j = 35°C | 3.09 | 5.14 |
| P _{dc} T _j = 30°C | 4.90 kW | 5.39 kW |
| EER T _j = 30°C | 3.99 | 6.65 |
| P _{dc} T _j = 25°C | 3.10 kW | 3.32 kW |
| EER T _j = 25°C | 4.55 | 4.93 |
| P _{dc} T _j = 20°C | 1.37 kW | 1.78 kW |
| EER T _j = 20°C | 3.96 | 12.82 |
| P _{off} | 12 W | 12 W |
| PTO | 12 W | 12 W |
| PSB | 12 W | 12 W |
| PCK | 0 W | 0 W |
| Annual energy consumption Q _{ce} | 973 kWh | 647 kWh |

Average Climate

This information was generated by the HP KEYMARK database on 23 Jun 2022

EN 12102-1

| | Low temperature | Medium temperature |
|---------------------------|-----------------|--------------------|
| Sound power level indoor | 33 dB(A) | 33 dB(A) |
| Sound power level outdoor | 58 dB(A) | 58 dB(A) |

EN 14825

| | Low temperature | Medium temperature |
|----------------|-----------------|--------------------|
| η_s | 178 % | 132 % |
| Prated | 6.50 kW | 6.00 kW |
| SCOP | 4.52 | 3.38 |
| Tbiv | -10 °C | -7 °C |
| TOL | -10 °C | -10 °C |
| Pdh Tj = -7°C | 5.90 kW | 5.50 kW |
| COP Tj = -7°C | 3.16 | 2.22 |
| Cdh Tj = -7 °C | 0.990 | 0.990 |
| Pdh Tj = +2°C | 3.50 kW | 3.40 kW |
| COP Tj = +2°C | 4.48 | 3.37 |
| Cdh Tj = +2 °C | 0.980 | 0.980 |
| Pdh Tj = +7°C | 2.25 kW | 2.10 kW |
| COP Tj = +7°C | 5.61 | 4.07 |
| Cdh Tj = +7 °C | 0.960 | 0.970 |

This information was generated by the HP KEYMARK database on 23 Jun 2022

| | | |
|---|----------|----------|
| Pdh Tj = 12°C | 2.50 kW | 2.50 kW |
| COP Tj = 12°C | 6.92 | 6.58 |
| Cdh Tj = +12 °C | 0.960 | 0.970 |
| Pdh Tj = Tbiv | 6.60 kW | 5.50 kW |
| COP Tj = Tbiv | 2.68 | 2.22 |
| Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 6.60 kW | 5.30 kW |
| COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh | 2.68 | 1.82 |
| Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 0.990 | 0.990 |
| WTOL | 60 °C | 60 °C |
| Poff | 12 W | 12 W |
| PTO | 12 W | 12 W |
| PSB | 12 W | 12 W |
| PCK | 0 W | 0 W |
| Supplementary Heater: Type of energy input | n/a | n/a |
| Supplementary Heater: PSUP | 0.00 kW | 0.70 kW |
| Annual energy consumption Qhe | 2974 kWh | 3667 kWh |

Model: AWHPR 6 MR + iMPI/E 4-8 iR32 + TANK FIT-IN EVO

| Configure model | |
|-------------------------------------|--|
| Model name | AWHPR 6 MR + iMPI/E 4-8 iR32 + TANK FIT-IN EVO |
| Application | Heating + DHW + low temp |
| Units | Indoor + Outdoor |
| Climate Zone | n/a |
| Reversibility | Yes |
| Cooling mode application (optional) | +7°C/12°C and +18°C/+23°C |

| General Data | |
|--------------|-------------|
| Power supply | 1x230V 50Hz |

Heating

| EN 14511-2 | | |
|-------------|-----------------|--------------------|
| | Low temperature | Medium temperature |
| Heat output | 6.40 kW | 5.70 kW |
| El input | 1.28 kW | 1.97 kW |
| COP | 5.00 | 2.90 |

| EN 14511-4 | |
|--|--------|
| Shutting off the heat transfer medium flow | passed |
| Complete power supply failure | passed |
| Defrost test | passed |
| Starting and operating test | passed |

Cooling

This information was generated by the HP KEYMARK database on 23 Jun 2022

| EN 14511-2 | | |
|-------------------|-------------------|--------------------|
| | +7°C/+12°C | +18°C/+23°C |
| El input | 2.10 kW | 1.36 kW |
| Cooling capacity | 6.50 | 7.00 |
| EER | 3.09 | 5.14 |

This information was generated by the HP KEYMARK database on 23 Jun 2022

| EN 14825 | | |
|---|-------------------|--------------------|
| | +7°C/+12°C | +18°C/+23°C |
| P _{designc} | 6.50 kW | 7.00 kW |
| SEER | 4.01 | 6.49 |
| P _{dc} T _j = 35°C | 6.50 kW | 7.00 kW |
| EER T _j = 35°C | 3.09 | 5.14 |
| P _{dc} T _j = 30°C | 4.90 kW | 5.39 kW |
| EER T _j = 30°C | 3.99 | 6.65 |
| P _{dc} T _j = 25°C | 3.10 kW | 3.32 kW |
| EER T _j = 25°C | 4.55 | 4.93 |
| P _{dc} T _j = 20°C | 1.37 kW | 1.78 kW |
| EER T _j = 20°C | 3.96 | 12.82 |
| P _{off} | 12 W | 12 W |
| PTO | 12 W | 12 W |
| PSB | 12 W | 12 W |
| PCK | 0 W | 0 W |
| Annual energy consumption Q _{ce} | 973 kWh | 647 kWh |

Average Climate

EN 12102-1

| | Low temperature | Medium temperature |
|---------------------------|-----------------|--------------------|
| Sound power level indoor | 33 dB(A) | 33 dB(A) |
| Sound power level outdoor | 58 dB(A) | 58 dB(A) |

EN 14825

| | Low temperature | Medium temperature |
|----------------|-----------------|--------------------|
| η_s | 178 % | 132 % |
| Prated | 6.50 kW | 6.00 kW |
| SCOP | 4.52 | 3.38 |
| Tbiv | -10 °C | -7 °C |
| TOL | -10 °C | -10 °C |
| Pdh Tj = -7°C | 5.90 kW | 5.50 kW |
| COP Tj = -7°C | 3.16 | 2.22 |
| Cdh Tj = -7 °C | 0.990 | 0.990 |
| Pdh Tj = +2°C | 3.50 kW | 3.40 kW |
| COP Tj = +2°C | 4.48 | 3.37 |
| Cdh Tj = +2 °C | 0.980 | 0.980 |
| Pdh Tj = +7°C | 2.25 kW | 2.10 kW |
| COP Tj = +7°C | 5.61 | 4.07 |
| Cdh Tj = +7 °C | 0.960 | 0.970 |

This information was generated by the HP KEYMARK database on 23 Jun 2022

| | | |
|---|----------|----------|
| Pdh Tj = 12°C | 2.50 kW | 2.50 kW |
| COP Tj = 12°C | 6.92 | 6.58 |
| Cdh Tj = +12 °C | 0.960 | 0.970 |
| Pdh Tj = Tbiv | 6.60 kW | 5.50 kW |
| COP Tj = Tbiv | 2.68 | 2.22 |
| Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 6.60 kW | 5.30 kW |
| COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh | 2.68 | 1.82 |
| Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 0.990 | 0.990 |
| WTOL | 60 °C | 60 °C |
| Poff | 12 W | 12 W |
| PTO | 12 W | 12 W |
| PSB | 12 W | 12 W |
| PCK | 0 W | 0 W |
| Supplementary Heater: Type of energy input | n/a | n/a |
| Supplementary Heater: PSUP | 0.00 kW | 0.70 kW |
| Annual energy consumption Qhe | 2974 kWh | 3667 kWh |

Domestic Hot Water (DHW)

Average Climate

| EN 16147 | |
|---------------------------------|-------------|
| Declared load profile | M |
| Efficiency η_{DHW} | 111 % |
| COP | 2.59 |
| Heating up time | 01:25 h:min |
| Standby power input | 25.4 W |
| Reference hot water temperature | 53.1 °C |
| Mixed water at 40°C | 250 l |

Model: AWHPR 6 MR + iMPI/E 4-8 iR32 + TANK FIT-IN EVO

| Configure model | |
|-------------------------------------|--|
| Model name | AWHPR 6 MR + iMPI/E 4-8 iR32 + TANK FIT-IN EVO |
| Application | Heating + DHW + low temp |
| Units | Indoor + Outdoor |
| Climate Zone | n/a |
| Reversibility | Yes |
| Cooling mode application (optional) | +7°C/12°C and +18°C/+23°C |

| General Data | |
|--------------|-------------|
| Power supply | 1x230V 50Hz |

Heating

| EN 14511-2 | | |
|-------------|-----------------|--------------------|
| | Low temperature | Medium temperature |
| Heat output | 6.40 kW | 5.70 kW |
| El input | 1.28 kW | 1.97 kW |
| COP | 5.00 | 2.90 |

| EN 14511-4 | |
|--|--------|
| Shutting off the heat transfer medium flow | passed |
| Complete power supply failure | passed |
| Defrost test | passed |
| Starting and operating test | passed |

Cooling

This information was generated by the HP KEYMARK database on 23 Jun 2022

| EN 14511-2 | | |
|-------------------|-------------------|--------------------|
| | +7°C/+12°C | +18°C/+23°C |
| El input | 2.10 kW | 1.36 kW |
| Cooling capacity | 6.50 | 7.00 |
| EER | 3.09 | 5.14 |

| EN 14825 | | |
|---|-------------------|--------------------|
| | +7°C/+12°C | +18°C/+23°C |
| P _{designc} | 6.50 kW | 7.00 kW |
| SEER | 4.01 | 6.49 |
| P _{dc} T _j = 35°C | 6.50 kW | 7.00 kW |
| EER T _j = 35°C | 3.09 | 5.14 |
| P _{dc} T _j = 30°C | 4.90 kW | 5.39 kW |
| EER T _j = 30°C | 3.99 | 6.65 |
| P _{dc} T _j = 25°C | 3.10 kW | 3.32 kW |
| EER T _j = 25°C | 4.55 | 4.93 |
| P _{dc} T _j = 20°C | 1.37 kW | 1.78 kW |
| EER T _j = 20°C | 3.96 | 12.82 |
| P _{off} | 12 W | 12 W |
| PTO | 12 W | 12 W |
| PSB | 12 W | 12 W |
| PCK | 0 W | 0 W |
| Annual energy consumption Q _{ce} | 973 kWh | 647 kWh |

Average Climate

EN 12102-1

| | Low temperature | Medium temperature |
|---------------------------|-----------------|--------------------|
| Sound power level indoor | 33 dB(A) | 33 dB(A) |
| Sound power level outdoor | 58 dB(A) | 58 dB(A) |

EN 14825

| | Low temperature | Medium temperature |
|----------------|-----------------|--------------------|
| η_s | 178 % | 132 % |
| Prated | 6.50 kW | 6.00 kW |
| SCOP | 4.52 | 3.38 |
| Tbiv | -10 °C | -7 °C |
| TOL | -10 °C | -10 °C |
| Pdh Tj = -7°C | 5.90 kW | 5.50 kW |
| COP Tj = -7°C | 3.16 | 2.22 |
| Cdh Tj = -7 °C | 0.990 | 0.990 |
| Pdh Tj = +2°C | 3.50 kW | 3.40 kW |
| COP Tj = +2°C | 4.48 | 3.37 |
| Cdh Tj = +2 °C | 0.980 | 0.980 |
| Pdh Tj = +7°C | 2.25 kW | 2.10 kW |
| COP Tj = +7°C | 5.61 | 4.07 |
| Cdh Tj = +7 °C | 0.960 | 0.970 |

This information was generated by the HP KEYMARK database on 23 Jun 2022

| | | |
|---|----------|----------|
| Pdh Tj = 12°C | 2.50 kW | 2.50 kW |
| COP Tj = 12°C | 6.92 | 6.58 |
| Cdh Tj = +12 °C | 0.960 | 0.970 |
| Pdh Tj = Tbiv | 6.60 kW | 5.50 kW |
| COP Tj = Tbiv | 2.68 | 2.22 |
| Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 6.60 kW | 5.30 kW |
| COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh | 2.68 | 1.82 |
| Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 0.990 | 0.990 |
| WTOL | 60 °C | 60 °C |
| Poff | 12 W | 12 W |
| PTO | 12 W | 12 W |
| PSB | 12 W | 12 W |
| PCK | 0 W | 0 W |
| Supplementary Heater: Type of energy input | n/a | n/a |
| Supplementary Heater: PSUP | 0.00 kW | 0.70 kW |
| Annual energy consumption Qhe | 2974 kWh | 3667 kWh |

Domestic Hot Water (DHW)

Average Climate

| EN 16147 | |
|---------------------------------|-------------|
| Declared load profile | L |
| Efficiency η_{DHW} | 124 % |
| COP | 2.98 |
| Heating up time | 01:25 h:min |
| Standby power input | 28.1 W |
| Reference hot water temperature | 53.1 °C |
| Mixed water at 40°C | 250 l |

Model: AWHPR 8 MR + iMPI/E 4-8 iR32

| Configure model | |
|-------------------------------------|------------------------------|
| Model name | AWHPR 8 MR + iMPI/E 4-8 iR32 |
| Application | Heating (medium temp) |
| Units | Indoor + Outdoor |
| Climate Zone | n/a |
| Reversibility | Yes |
| Cooling mode application (optional) | +7°C/12°C and +18°C/+23°C |

| General Data | |
|--------------|-------------|
| Power supply | 1x230V 50Hz |

Heating

| EN 14511-2 | | |
|-------------|-----------------|--------------------|
| | Low temperature | Medium temperature |
| Heat output | 7.60 kW | 8.00 kW |
| El input | 1.59 kW | 2.91 kW |
| COP | 4.77 | 2.75 |

| EN 14511-4 | |
|--|--------|
| Shutting off the heat transfer medium flow | passed |
| Complete power supply failure | passed |
| Defrost test | passed |
| Starting and operating test | passed |

Cooling

This information was generated by the HP KEYMARK database on 23 Jun 2022

| EN 14511-2 | | |
|-------------------|-------------------|--------------------|
| | +7°C/+12°C | +18°C/+23°C |
| El input | 2.15 kW | 1.45 kW |
| Cooling capacity | 6.50 | 7.10 |
| EER | 3.02 | 4.88 |

| EN 14825 | | |
|---|-------------------|--------------------|
| | +7°C/+12°C | +18°C/+23°C |
| P _{designc} | 6.50 kW | 7.10 kW |
| SEER | 4.43 | 5.89 |
| P _{dc} T _j = 35°C | 6.50 kW | 7.10 kW |
| EER T _j = 35°C | 3.02 | 4.88 |
| P _{dc} T _j = 30°C | 4.97 kW | 5.65 kW |
| EER T _j = 30°C | 4.12 | 6.81 |
| P _{dc} T _j = 25°C | 3.35 kW | 3.18 kW |
| EER T _j = 25°C | 4.74 | 5.26 |
| P _{dc} T _j = 20°C | 1.55 kW | 1.67 kW |
| EER T _j = 20°C | 5.50 | 7.40 |
| P _{off} | 12 W | 12 W |
| PTO | 12 W | 12 W |
| PSB | 12 W | 12 W |
| PCK | 0 W | 0 W |
| Annual energy consumption Q _{ce} | 881 kWh | 723 kWh |

Average Climate

EN 12102-1

| | Low temperature | Medium temperature |
|---------------------------|-----------------|--------------------|
| Sound power level indoor | 33 dB(A) | 33 dB(A) |
| Sound power level outdoor | 59 dB(A) | 59 dB(A) |

EN 14825

| | Low temperature | Medium temperature |
|----------------|-----------------|--------------------|
| η_s | 177 % | 131 % |
| Prated | 7.00 kW | 7.00 kW |
| SCOP | 4.50 | 3.34 |
| Tbiv | -7 °C | -7 °C |
| TOL | -10 °C | -10 °C |
| Pdh Tj = -7°C | 6.19 kW | 6.19 kW |
| COP Tj = -7°C | 2.97 | 2.09 |
| Cdh Tj = -7 °C | 0.990 | 0.990 |
| Pdh Tj = +2°C | 4.12 kW | 3.79 kW |
| COP Tj = +2°C | 4.46 | 3.24 |
| Cdh Tj = +2 °C | 0.980 | 0.990 |
| Pdh Tj = +7°C | 2.78 kW | 2.49 kW |
| COP Tj = +7°C | 5.70 | 4.57 |
| Cdh Tj = +7 °C | 0.970 | 0.970 |

This information was generated by the HP KEYMARK database on 23 Jun 2022

| | | |
|---|----------|----------|
| Pdh Tj = 12°C | 2.67 kW | 2.55 kW |
| COP Tj = 12°C | 7.80 | 6.10 |
| Cdh Tj = +12 °C | 0.960 | 0.960 |
| Pdh Tj = Tbiv | 6.19 kW | 6.19 kW |
| COP Tj = Tbiv | 2.97 | 2.09 |
| Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 6.64 kW | 4.90 kW |
| COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh | 2.58 | 1.66 |
| Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 0.990 | 0.990 |
| WTOL | 60 °C | 60 °C |
| Poff | 12 W | 12 W |
| PTO | 12 W | 12 W |
| PSB | 12 W | 12 W |
| PCK | 0 W | 0 W |
| Supplementary Heater: Type of energy input | n/a | n/a |
| Supplementary Heater: PSUP | 0.36 kW | 2.10 kW |
| Annual energy consumption Qhe | 3213 kWh | 4334 kWh |

Model: AWHPR 8 MR + iMPI/E 4-8 iR32 + TANK FIT-IN EVO

| Configure model | |
|-------------------------------------|--|
| Model name | AWHPR 8 MR + iMPI/E 4-8 iR32 + TANK FIT-IN EVO |
| Application | Heating + DHW + low temp |
| Units | Indoor + Outdoor |
| Climate Zone | n/a |
| Reversibility | Yes |
| Cooling mode application (optional) | +7°C/12°C and +18°C/+23°C |

| General Data | |
|--------------|-------------|
| Power supply | 1x230V 50Hz |

Heating

| EN 14511-2 | | |
|-------------|-----------------|--------------------|
| | Low temperature | Medium temperature |
| Heat output | 7.60 kW | 8.00 kW |
| El input | 1.59 kW | 2.91 kW |
| COP | 4.77 | 2.75 |

| EN 14511-4 | |
|--|--------|
| Shutting off the heat transfer medium flow | passed |
| Complete power supply failure | passed |
| Defrost test | passed |
| Starting and operating test | passed |

Cooling

This information was generated by the HP KEYMARK database on 23 Jun 2022

| EN 14511-2 | | |
|-------------------|-------------------|--------------------|
| | +7°C/+12°C | +18°C/+23°C |
| El input | 2.15 kW | 1.45 kW |
| Cooling capacity | 6.50 | 7.10 |
| EER | 3.02 | 4.88 |

| EN 14825 | | |
|---|-------------------|--------------------|
| | +7°C/+12°C | +18°C/+23°C |
| P _{designc} | 6.50 kW | 7.10 kW |
| SEER | 4.43 | 5.89 |
| P _{dc} T _j = 35°C | 6.50 kW | 7.10 kW |
| EER T _j = 35°C | 3.02 | 4.88 |
| P _{dc} T _j = 30°C | 4.97 kW | 5.65 kW |
| EER T _j = 30°C | 4.12 | 6.81 |
| P _{dc} T _j = 25°C | 3.35 kW | 3.18 kW |
| EER T _j = 25°C | 4.74 | 5.26 |
| P _{dc} T _j = 20°C | 1.55 kW | 1.67 kW |
| EER T _j = 20°C | 5.50 | 7.40 |
| P _{off} | 12 W | 12 W |
| PTO | 12 W | 12 W |
| PSB | 12 W | 12 W |
| PCK | 0 W | 0 W |
| Annual energy consumption Q _{ce} | 881 kWh | 723 kWh |

Average Climate

EN 12102-1

| | Low temperature | Medium temperature |
|---------------------------|-----------------|--------------------|
| Sound power level indoor | 33 dB(A) | 33 dB(A) |
| Sound power level outdoor | 59 dB(A) | 59 dB(A) |

EN 14825

| | Low temperature | Medium temperature |
|----------------|-----------------|--------------------|
| η_s | 177 % | 131 % |
| Prated | 7.00 kW | 7.00 kW |
| SCOP | 4.50 | 3.34 |
| Tbiv | -7 °C | -7 °C |
| TOL | -10 °C | -10 °C |
| Pdh Tj = -7°C | 6.19 kW | 6.19 kW |
| COP Tj = -7°C | 2.97 | 2.09 |
| Cdh Tj = -7 °C | 0.990 | 0.990 |
| Pdh Tj = +2°C | 4.12 kW | 3.79 kW |
| COP Tj = +2°C | 4.46 | 3.24 |
| Cdh Tj = +2 °C | 0.980 | 0.990 |
| Pdh Tj = +7°C | 2.78 kW | 2.49 kW |
| COP Tj = +7°C | 5.70 | 4.57 |
| Cdh Tj = +7 °C | 0.970 | 0.970 |

This information was generated by the HP KEYMARK database on 23 Jun 2022

| | | |
|---|----------|----------|
| Pdh Tj = 12°C | 2.67 kW | 2.55 kW |
| COP Tj = 12°C | 7.80 | 6.10 |
| Cdh Tj = +12 °C | 0.960 | 0.960 |
| Pdh Tj = Tbiv | 6.19 kW | 6.19 kW |
| COP Tj = Tbiv | 2.97 | 2.09 |
| Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 6.64 kW | 4.90 kW |
| COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh | 2.58 | 1.66 |
| Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 0.990 | 0.990 |
| WTOL | 60 °C | 60 °C |
| Poff | 12 W | 12 W |
| PTO | 12 W | 12 W |
| PSB | 12 W | 12 W |
| PCK | 0 W | 0 W |
| Supplementary Heater: Type of energy input | n/a | n/a |
| Supplementary Heater: PSUP | 0.36 kW | 2.10 kW |
| Annual energy consumption Qhe | 3213 kWh | 4334 kWh |

Domestic Hot Water (DHW)

Average Climate

| EN 16147 | |
|---------------------------------|-------------|
| Declared load profile | M |
| Efficiency η_{DHW} | 111 % |
| COP | 2.59 |
| Heating up time | 01:25 h:min |
| Standby power input | 25.4 W |
| Reference hot water temperature | 53.1 °C |
| Mixed water at 40°C | 250 l |

Model: AWHPR 8 MR + iMPI/E 4-8 iR32 + TANK FIT-IN EVO

| Configure model | |
|-------------------------------------|--|
| Model name | AWHPR 8 MR + iMPI/E 4-8 iR32 + TANK FIT-IN EVO |
| Application | Heating + DHW + low temp |
| Units | Indoor + Outdoor |
| Climate Zone | n/a |
| Reversibility | Yes |
| Cooling mode application (optional) | +7°C/12°C and +18°C/+23°C |

| General Data | |
|--------------|-------------|
| Power supply | 1x230V 50Hz |

Heating

| EN 14511-2 | | |
|-------------|-----------------|--------------------|
| | Low temperature | Medium temperature |
| Heat output | 7.60 kW | 8.00 kW |
| El input | 1.59 kW | 2.91 kW |
| COP | 4.77 | 2.75 |

| EN 14511-4 | |
|--|--------|
| Shutting off the heat transfer medium flow | passed |
| Complete power supply failure | passed |
| Defrost test | passed |
| Starting and operating test | passed |

Cooling

This information was generated by the HP KEYMARK database on 23 Jun 2022

| EN 14511-2 | | |
|-------------------|-------------------|--------------------|
| | +7°C/+12°C | +18°C/+23°C |
| El input | 2.15 kW | 1.45 kW |
| Cooling capacity | 6.50 | 7.10 |
| EER | 3.02 | 4.88 |

| EN 14825 | | |
|---|-------------------|--------------------|
| | +7°C/+12°C | +18°C/+23°C |
| P _{designc} | 6.50 kW | 7.10 kW |
| SEER | 4.43 | 5.89 |
| P _{dc} T _j = 35°C | 6.50 kW | 7.10 kW |
| EER T _j = 35°C | 3.02 | 4.88 |
| P _{dc} T _j = 30°C | 4.97 kW | 5.65 kW |
| EER T _j = 30°C | 4.12 | 6.81 |
| P _{dc} T _j = 25°C | 3.35 kW | 3.18 kW |
| EER T _j = 25°C | 4.74 | 5.26 |
| P _{dc} T _j = 20°C | 1.55 kW | 1.67 kW |
| EER T _j = 20°C | 5.50 | 7.40 |
| P _{off} | 12 W | 12 W |
| PTO | 12 W | 12 W |
| PSB | 12 W | 12 W |
| PCK | 0 W | 0 W |
| Annual energy consumption Q _{ce} | 881 kWh | 723 kWh |

Average Climate

EN 12102-1

| | Low temperature | Medium temperature |
|---------------------------|-----------------|--------------------|
| Sound power level indoor | 33 dB(A) | 33 dB(A) |
| Sound power level outdoor | 59 dB(A) | 59 dB(A) |

EN 14825

| | Low temperature | Medium temperature |
|----------------|-----------------|--------------------|
| η_s | 177 % | 131 % |
| Prated | 7.00 kW | 7.00 kW |
| SCOP | 4.50 | 3.34 |
| Tbiv | -7 °C | -7 °C |
| TOL | -10 °C | -10 °C |
| Pdh Tj = -7°C | 6.19 kW | 6.19 kW |
| COP Tj = -7°C | 2.97 | 2.09 |
| Cdh Tj = -7 °C | 0.990 | 0.990 |
| Pdh Tj = +2°C | 4.12 kW | 3.79 kW |
| COP Tj = +2°C | 4.46 | 3.24 |
| Cdh Tj = +2 °C | 0.980 | 0.990 |
| Pdh Tj = +7°C | 2.78 kW | 2.49 kW |
| COP Tj = +7°C | 5.70 | 4.57 |
| Cdh Tj = +7 °C | 0.970 | 0.970 |

This information was generated by the HP KEYMARK database on 23 Jun 2022

| | | |
|---|----------|----------|
| Pdh Tj = 12°C | 2.67 kW | 2.55 kW |
| COP Tj = 12°C | 7.80 | 6.10 |
| Cdh Tj = +12 °C | 0.960 | 0.960 |
| Pdh Tj = Tbiv | 6.19 kW | 6.19 kW |
| COP Tj = Tbiv | 2.97 | 2.09 |
| Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 6.64 kW | 4.90 kW |
| COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh | 2.58 | 1.66 |
| Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 0.990 | 0.990 |
| WTOL | 60 °C | 60 °C |
| Poff | 12 W | 12 W |
| PTO | 12 W | 12 W |
| PSB | 12 W | 12 W |
| PCK | 0 W | 0 W |
| Supplementary Heater: Type of energy input | n/a | n/a |
| Supplementary Heater: PSUP | 0.36 kW | 2.10 kW |
| Annual energy consumption Qhe | 3213 kWh | 4334 kWh |

Domestic Hot Water (DHW)

Average Climate

| EN 16147 | |
|---------------------------------|-------------|
| Declared load profile | L |
| Efficiency η_{DHW} | 124 % |
| COP | 2.98 |
| Heating up time | 01:25 h:min |
| Standby power input | 28.1 W |
| Reference hot water temperature | 53.1 °C |
| Mixed water at 40°C | 250 l |