

This information was generated by the HP KEYMARK database on 18 Mar 2022

[Login](#)

Summary of	Buderus Logatherm WPS 8K-1	Reg. No.	011-1W0178
Certificate Holder			
Name	Bosch Thermotechnik GmbH (Buderus)		
Address	Sophienstraße 30-32	Zip	35576
City	Wetzlar	Country	Germany
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Subtype title	Buderus Logatherm WPS 8K-1		
Heat Pump Type	Brine/Water		
Refrigerant	R410A		
Mass of Refrigerant	1.95 kg		

Model: Buderus Logatherm WPS 8K-1

Configure model	
Model name	Buderus Logatherm WPS 8K-1
Application	Heating + DHW + low temp
Units	Indoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz
Off-peak product	No

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	7.40 kW	6.85 kW
El input	1.66 kW	2.39 kW
COP	4.47	2.87

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed

Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	52 dB(A)	52 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	186 %	131 %
Prated	9.00 kW	8.00 kW
SCOP	4.85	3.48
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.50 kW	6.80 kW
COP Tj = -7°C	4.66	2.92
Pdh Tj = +2°C	7.60 kW	7.00 kW
COP Tj = +2°C	4.87	3.43
Pdh Tj = +7°C	7.70 kW	7.20 kW
COP Tj = +7°C	5.07	3.86
Pdh Tj = 12°C	7.80 kW	7.40 kW
COP Tj = 12°C	5.26	4.29
Pdh Tj = Tbiv	7.50 kW	6.80 kW
COP Tj = Tbiv	4.66	2.92

This information was generated by the HP KEYMARK database on 18 Mar 2022

$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	7.50 kW	6.70 kW
$COP T_j = TOL$ or $COP T_j = T_{designh}$ if $TOL < T_{designh}$	4.55	2.68
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	1.00	1.00
WTOL	62 °C	62 °C
Poff	6 W	6 W
PTO	6 W	6 W
PSB	6 W	6 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.00 kW	1.00 kW
Annual energy consumption Q_{he}	3619 kWh	4540 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	83 %
COP	2.09
Heating up time	01:29 h:min
Standby power input	59.8 W
Reference hot water temperature	50.3 °C
Mixed water at 40°C	235 l