

This information was generated by the HP KEYMARK database on 18 Mar 2022

[Login](#)

Summary of	AURIGA 4/6-A	Reg. No.	041-K023-01
Certificate Holder			
Name	BAXI S.p.A.		
Address	Via Trozzetti, 20	Zip	
City	Bassano del Grappa (VI)	Country	Italy
Certification Body	BRE Global Limited		
Subtype title	AURIGA 4/6-A		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R32		
Mass of Refrigerant	1.5 kg		
Certification Date	18.03.2022		
Testing basis	Heat Pump Keymark Scheme Rules Rev 09		

Model: Auriga 4 M-A

Configure model	
Model name	Auriga 4 M-A
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	4.20 kW	4.40 kW
El input	0.82 kW	1.49 kW
COP	5.10	2.95

Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level outdoor	55 dB(A)	55 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	191 %	130 %
Prated	5.52 kW	4.40 kW
SCOP	4.85	3.31
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	4.88 kW	3.89 kW
COP Tj = -7°C	3.19	2.17
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	3.06 kW	2.38 kW
COP Tj = +2°C	4.78	3.30
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	1.93 kW	2.95 kW
COP Tj = +7°C	6.13	4.41
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	1.48 kW	1.32 kW

This information was generated by the HP KEYMARK database on 18 Mar 2022

COP Tj = 12°C	8.05	5.66
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	4.88 kW	3.89 kW
COP Tj = Tbiv	3.19	2.17
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.42 kW	3.42 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.86	1.91
WTOL	65 °C	65 °C
Poff	14 W	14 W
PTO	24 W	24 W
PSB	14 W	14 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.11 kW	0.98 kW
Annual energy consumption Qhe	2351 kWh	2744 kWh

Warmer Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level outdoor	55 dB(A)	55 dB(A)

EN 14825		
	Low temperature	Medium temperature

This information was generated by the HP KEYMARK database on 18 Mar 2022

η_s	254 %	162 %
Prated	5.54 kW	5.02 kW
SCOP	6.52	4.14
Tbiv	7 °C	7 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	5.35 kW	4.84 kW
COP Tj = +2°C	3.94	2.51
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	3.56 kW	3.23 kW
COP Tj = +7°C	5.92	3.68
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	1.64 kW	1.47 kW
COP Tj = 12°C	7.91	5.15
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	3.56 kW	3.23 kW
COP Tj = Tbiv	5.92	3.68
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.35 kW	4.84 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.94	2.51
WTOL	65 °C	65 °C
Poff	14 W	14 W

This information was generated by the HP KEYMARK database on 18 Mar 2022

PTO	24 W	24 W
PSB	14 W	14 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.19 kW	0.18 kW
Annual energy consumption Q _{he}	1152 kWh	1621 kWh

Colder Climate

EN 14825		
	Low temperature	Medium temperature
η_s	159 %	102 %
Prated	4.57 kW	3.37 kW
SCOP	4.06	2.63
T _{biv}	-15 °C	-15 °C
TOL	-22 °C	-22 °C
P _{dh} T _j = -7°C	2.76 kW	2.14 kW
COP T _j = -7°C	3.49	2.32
C _{dh} T _j = -7 °C	0.90	0.90
P _{dh} T _j = +2°C	1.77 kW	1.28 kW
COP T _j = +2°C	4.95	2.99
C _{dh} T _j = +2 °C	0.90	0.90

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = +7°C	1.17 kW	1.01 kW
COP Tj = +7°C	5.53	3.86
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	1.43 kW	1.36 kW
COP Tj = 12°C	7.67	6.28
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	3.72 kW	2.75 kW
COP Tj = Tbiv	2.57	1.74
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	2.80 kW	1.64 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	1.97	1.02
WTOL	65 °C	65 °C
Poff	14 W	14 W
PTO	24 W	24 W
PSB	14 W	14 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.76 kW	1.73 kW
Annual energy consumption Qhe	2770 kWh	3159 kWh
Pdh Tj = -15°C (if TOL<-20°C)	3.72	2.75
COP Tj = -15°C (if TOL<-20°C)	2.57	1.74
Cdh Tj = -15 °C	0.90	0.90

EN 12102-1		
	Low temperature	Medium temperature
Sound power level outdoor	55 dB(A)	55 dB(A)

Model: Auriga 6 M-A

Configure model	
Model name	Auriga 6 M-A
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	6.35 kW	6.00 kW
El input	1.28 kW	2.03 kW
COP	4.95	2.95

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level outdoor	58 dB(A)	58 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	195 %	138 %
Prated	6.82 kW	5.70 kW
SCOP	4.95	3.52
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	6.03 kW	5.05 kW
COP Tj = -7°C	3.09	2.17
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	3.88 kW	3.12 kW
COP Tj = +2°C	4.85	3.51
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	2.40 kW	2.09 kW
COP Tj = +7°C	6.63	4.54
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	1.39 kW	1.28 kW

This information was generated by the HP KEYMARK database on 18 Mar 2022

COP Tj = 12°C	7.83	5.59
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	6.03 kW	5.05 kW
COP Tj = Tbiv	3.09	2.17
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.36 kW	4.52 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.76	1.91
WTOL	65 °C	65 °C
Poff	14 W	14 W
PTO	24 W	24 W
PSB	14 W	14 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.45 kW	1.18 kW
Annual energy consumption Qhe	2846 kWh	3345 kWh

Warmer Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level outdoor	58 dB(A)	58 dB(A)

EN 14825		
	Low temperature	Medium temperature

This information was generated by the HP KEYMARK database on 18 Mar 2022

η_s	258 %	165 %
Prated	6.12 kW	5.15 kW
SCOP	6.63	4.19
Tbiv	7 °C	7 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	5.94 kW	5.03 kW
COP Tj = +2°C	3.91	2.48
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	3.93 kW	3.31 kW
COP Tj = +7°C	5.89	3.67
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	1.80 kW	1.60 kW
COP Tj = 12°C	8.20	5.29
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	3.93 kW	3.31 kW
COP Tj = Tbiv	5.89	3.67
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.94 kW	5.03 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.91	2.48
WTOL	65 °C	65 °C
Poff	14 W	14 W

This information was generated by the HP KEYMARK database on 18 Mar 2022

PTO	24 W	24 W
PSB	14 W	14 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.18 kW	0.12 kW
Annual energy consumption Q _{he}	1251 kWh	1640 kWh

Colder Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level outdoor	58 dB(A)	58 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	165 %	111 %
Prated	5.63 kW	4.26 kW
SCOP	4.21	2.85
T _{biv}	-15 °C	-15 °C
TOL	-22 °C	-22 °C
P _{dh} T _j = -7°C	3.42 kW	2.70 kW
COP T _j = -7°C	3.59	2.46

This information was generated by the HP KEYMARK database on 18 Mar 2022

Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	2.06 kW	1.61 kW
COP Tj = +2°C	5.21	3.36
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	1.47 kW	1.02 kW
COP Tj = +7°C	6.24	3.94
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	1.44 kW	1.37 kW
COP Tj = 12°C	7.66	6.35
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	4.60 kW	3.48 kW
COP Tj = Tbiv	2.53	1.86
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.48 kW	2.10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	1.96	1.13
WTOL	65 °C	65 °C
Poff	20 W	20 W
PTO	24 W	24 W
PSB	14 W	14 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.15 kW	2.16 kW

This information was generated by the HP KEYMARK database on 18 Mar 2022

Annual energy consumption Q_{he}	3301 kWh	3681 kWh
$P_{dh} T_j = -15^{\circ}\text{C}$ (if $TOL < -20^{\circ}\text{C}$)	4.60	3.48
$COP T_j = -15^{\circ}\text{C}$ (if $TOL < -20^{\circ}\text{C}$)	2.53	1.86
$C_{dh} T_j = -15^{\circ}\text{C}$	0.90	0.90