

This information was generated by the HP KEYMARK database on 23 Jun 2022

[Login](#)

Summary of	DAIKIN ALTHERMA 3 H MT F 08-12KW (500L)	Reg. No.	011-1W0502
Certificate Holder			
Name	DAIKIN Europe N.V.		
Address	Zandvoordestraat 300	Zip	B-8400
City	Oostende	Country	Belgium
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Subtype title	DAIKIN ALTHERMA 3 H MT F 08-12KW (500L)		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R32		
Mass of Refrigerant	3.25 kg		
Certification Date	24.11.2021		
Testing basis	HP KEYMARK certification scheme rules rev. 9		

Model: EPRA08EV3 / ETSH(B)12P50E

Configure model	
Model name	EPRA08EV3 / ETSH(B)12P50E
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	6.17 kW	7.72 kW
El input	1.25 kW	2.63 kW
COP	4.92	2.94

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

EN 14511-2

	+7°C/+12°C
El input	2.15 kW
Cooling capacity	6.81
EER	3.17

EN 14825

This information was generated by the HP KEYMARK database on 23 Jun 2022

	+7°C/+12°C
P _{designc}	6.5 kW
SEER	5.38
P _{dc} T _j = 35°C	6.81 kW
EER T _j = 35°C	3.17
P _{dc} T _j = 30°C	5.00 kW
EER T _j = 30°C	4.37
C _{dc}	0.98
P _{dc} T _j = 25°C	3.01 kW
EER T _j = 25°C	6.58
C _{dc}	0.94
P _{dc} T _j = 20°C	2.57 kW
EER T _j = 20°C	8.00
C _{dc}	0.91
P _{off}	25 W
PTO	3 W
PSB	25 W
PCK	0 W
Annual energy consumption Q _{ce}	725 kWh

Average Climate

This information was generated by the HP KEYMARK database on 23 Jun 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	47.3 dB(A)	47.3 dB(A)
Sound power level outdoor	53.0 dB(A)	53.0 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	184 %	134 %
Prated	8.3 kW	8.5 kW
SCOP	4.69	3.41
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.5 kW	7.6 kW
COP Tj = -7°C	3.10	2.21
Cdh Tj = -7 °C	1.0	1.0
Pdh Tj = +2°C	4.4 kW	4.6 kW
COP Tj = +2°C	4.76	3.37
Cdh Tj = +2 °C	1.0	1.0
Pdh Tj = +7°C	4.3 kW	3.0 kW
COP Tj = +7°C	6.14	4.48
Cdh Tj = +7 °C	1.0	1.0

This information was generated by the HP KEYMARK database on 23 Jun 2022

Pdh Tj = 12°C	6.6 kW	3.7 kW
COP Tj = 12°C	7.84	5.98
Cdh Tj = +12 °C	1.0	1.0
Pdh Tj = Tbiv	7.5 kW	7.6 kW
COP Tj = Tbiv	3.10	2.21
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.92 kW	6.96 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.80	1.93
WTOL	35 °C	55 °C
Poff	21 W	21 W
PTO	24 W	24 W
PSB	21 W	21 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.38 kW	1.54 kW
Annual energy consumption Qhe	3659 kWh	5142 kWh

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 23 Jun 2022

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	128 %
COP	3.10
Heating up time	3:13 h:min
Standby power input	32.7 W
Reference hot water temperature	44.5 °C
Mixed water at 40°C	246.0 l

Model: EPRA08EW1 / ETSH(B)12P50E

Configure model	
Model name	EPRA08EW1 / ETSH(B)12P50E
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	6.17 kW	7.72 kW
El input	1.21 kW	2.53 kW
COP	5.10	3.05

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

This information was generated by the HP KEYMARK database on 23 Jun 2022

EN 14511-2

	+7°C/+12°C
El input	2.08 kW
Cooling capacity	6.81
EER	3.28

EN 14825

This information was generated by the HP KEYMARK database on 23 Jun 2022

	+7°C/+12°C
P _{designc}	6.5 kW
SEER	5.41
P _{dc} T _j = 35°C	6.81 kW
EER T _j = 35°C	3.28
P _{dc} T _j = 30°C	5.00 kW
EER T _j = 30°C	4.52
C _{dc}	0.97
P _{dc} T _j = 25°C	3.01 kW
EER T _j = 25°C	6.66
C _{dc}	0.94
P _{dc} T _j = 20°C	2.57 kW
EER T _j = 20°C	7.98
C _{dc}	0.91
P _{off}	31 W
PTO	0 W
PSB	31 W
PCK	0 W
Annual energy consumption Q _{ce}	719 kWh

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	47.3 dB(A)	47.3 dB(A)
Sound power level outdoor	53.0 dB(A)	53.0 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	190 %	138 %
Prated	8.3 kW	8.5 kW
SCOP	4.81	3.52
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.5 kW	7.6 kW
COP Tj = -7°C	3.20	2.30
Cdh Tj = -7 °C	1.0	1.0
Pdh Tj = +2°C	4.4 kW	4.6 kW
COP Tj = +2°C	4.93	3.50
Cdh Tj = +2 °C	1.0	1.0
Pdh Tj = +7°C	4.3 kW	3.0 kW
COP Tj = +7°C	6.37	4.61
Cdh Tj = +7 °C	1.0	1.0

This information was generated by the HP KEYMARK database on 23 Jun 2022

Pdh Tj = 12°C	6.6 kW	3.7 kW
COP Tj = 12°C	8.13	6.16
Cdh Tj = +12 °C	1.0	1.0
Pdh Tj = Tbiv	7.5 kW	7.6 kW
COP Tj = Tbiv	3.20	2.30
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.92 kW	6.96 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.90	2.01
WTOL	35 °C	55 °C
Poff	27 W	27 W
PTO	24 W	24 W
PSB	27 W	27 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.38 kW	1.54 kW
Annual energy consumption Qhe	3561 kWh	4993 kWh

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 23 Jun 2022

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	131 %
COP	3.17
Heating up time	4:13 h:min
Standby power input	32.1 W
Reference hot water temperature	44.5 °C
Mixed water at 40°C	246.0 l

Model: EPRA10EV3 / ETSH(B)12P50E

Configure model	
Model name	EPRA10EV3 / ETSH(B)12P50E
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	6.17 kW	7.72 kW
El input	1.25 kW	2.63 kW
COP	4.92	2.94

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

EN 14511-2

	+7°C/+12°C
El input	2.66 kW
Cooling capacity	7.97
EER	3.00

EN 14825

This information was generated by the HP KEYMARK database on 23 Jun 2022

	+7°C/+12°C
P _{designc}	7.5 kW
SEER	5.34
P _{dc} T _j = 35°C	7.97 kW
EER T _j = 35°C	3.00
P _{dc} T _j = 30°C	5.76 kW
EER T _j = 30°C	4.28
C _{dc}	0.98
P _{dc} T _j = 25°C	3.63 kW
EER T _j = 25°C	6.31
C _{dc}	0.95
P _{dc} T _j = 20°C	2.63 kW
EER T _j = 20°C	8.37
C _{dc}	0.91
P _{off}	25 W
PTO	3 W
PSB	25 W
PCK	0 W
Annual energy consumption Q _{ce}	843 kWh

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	47.3 dB(A)	47.3 dB(A)
Sound power level outdoor	53.0 dB(A)	53.0 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	186 %	134 %
Prated	8.3 kW	8.5 kW
SCOP	4.71	3.43
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.5 kW	7.6 kW
COP Tj = -7°C	3.10	2.21
Cdh Tj = -7 °C	1.0	1.0
Pdh Tj = +2°C	4.4 kW	4.6 kW
COP Tj = +2°C	4.76	3.37
Cdh Tj = +2 °C	1.0	1.0
Pdh Tj = +7°C	4.3 kW	3.0 kW
COP Tj = +7°C	6.14	4.48
Cdh Tj = +7 °C	1.0	1.0

This information was generated by the HP KEYMARK database on 23 Jun 2022

Pdh Tj = 12°C	6.6 kW	3.7 kW
COP Tj = 12°C	7.84	5.98
Cdh Tj = +12 °C	1.0	1.0
Pdh Tj = Tbiv	8.1 kW	8.3 kW
COP Tj = Tbiv	2.77	1.97
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.14 kW	8.31 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.77	1.97
WTOL	35 °C	55 °C
Poff	21 W	21 W
PTO	24 W	24 W
PSB	21 W	21 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.0 kW	0.0 kW
Annual energy consumption Qhe	3637 kWh	5120 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	128 %
COP	3.10
Heating up time	5:13 h:min
Standby power input	32.7 W
Reference hot water temperature	44.5 °C
Mixed water at 40°C	246.0 l

Model: EPRA10EW1 / ETSH(B)12P50E

Configure model

Model name	EPRA10EW1 / ETSH(B)12P50E
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data

Power supply	3x400V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	6.17 kW	7.72 kW
El input	1.21 kW	2.53 kW
COP	5.10	3.05

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

EN 14511-2

	+7°C/+12°C
El input	2.57 kW
Cooling capacity	7.97
EER	3.10

EN 14825

This information was generated by the HP KEYMARK database on 23 Jun 2022

	+7°C/+12°C
P _{designc}	7.5 kW
SEER	5.41
P _{dc} T _j = 35°C	7.97 kW
EER T _j = 35°C	3.10
P _{dc} T _j = 30°C	5.76 kW
EER T _j = 30°C	4.43
C _{dc}	0.98
P _{dc} T _j = 25°C	3.63 kW
EER T _j = 25°C	6.47
C _{dc}	0.95
P _{dc} T _j = 20°C	2.63 kW
EER T _j = 20°C	8.35
C _{dc}	0.91
P _{off}	31 W
PTO	0 W
PSB	31 W
PCK	0 W
Annual energy consumption Q _{ce}	831 kWh

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	47.3 dB(A)	47.3 dB(A)
Sound power level outdoor	53.0 dB(A)	53.0 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	191 %	138 %
Prated	8.3 kW	8.5 kW
SCOP	4.84	3.53
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.5 kW	7.6 kW
COP Tj = -7°C	3.20	2.30
Cdh Tj = -7 °C	1.0	1.0
Pdh Tj = +2°C	4.4 kW	4.6 kW
COP Tj = +2°C	4.93	3.50
Cdh Tj = +2 °C	1.0	1.0
Pdh Tj = +7°C	4.3 kW	3.0 kW
COP Tj = +7°C	6.37	4.61
Cdh Tj = +7 °C	1.0	1.0

This information was generated by the HP KEYMARK database on 23 Jun 2022

Pdh Tj = 12°C	6.6 kW	3.7 kW
COP Tj = 12°C	8.13	6.16
Cdh Tj = +12 °C	1.0	1.0
Pdh Tj = Tbiv	8.1 kW	8.3 kW
COP Tj = Tbiv	2.86	2.05
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.14 kW	8.31 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.86	2.05
WTOL	35 °C	55 °C
Poff	27 W	27 W
PTO	24 W	24 W
PSB	27 W	27 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.0 kW	0.0 kW
Annual energy consumption Qhe	3539 kWh	4970 kWh

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 23 Jun 2022

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	131 %
COP	3.17
Heating up time	6:13 h:min
Standby power input	32.1 W
Reference hot water temperature	44.5 °C
Mixed water at 40°C	246.0 l

Model: EPRA12EV3 / ETSH(B)12P50E

Configure model	
Model name	EPRA12EV3 / ETSH(B)12P50E
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	6.17 kW	7.72 kW
El input	1.25 kW	2.63 kW
COP	4.92	2.94

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

EN 14511-2

	+7°C/+12°C
El input	2.96 kW
Cooling capacity	8.62
EER	2.91

EN 14825

This information was generated by the HP KEYMARK database on 23 Jun 2022

	+7°C/+12°C
P _{designc}	8.5 kW
SEER	5.31
P _{dc} T _j = 35°C	8.62 kW
EER T _j = 35°C	2.91
P _{dc} T _j = 30°C	6.68 kW
EER T _j = 30°C	4.17
C _{dc}	0.98
P _{dc} T _j = 25°C	4.04 kW
EER T _j = 25°C	6.13
C _{dc}	0.96
P _{dc} T _j = 20°C	2.69 kW
EER T _j = 20°C	8.75
C _{dc}	0.91
P _{off}	25 W
PTO	3 W
PSB	25 W
PCK	0 W
Annual energy consumption Q _{ce}	961 kWh

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	47.3 dB(A)	47.3 dB(A)
Sound power level outdoor	53.0 dB(A)	53.0 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	186 %	134 %
Prated	8.3 kW	8.5 kW
SCOP	4.71	3.43
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.5 kW	7.6 kW
COP Tj = -7°C	3.10	2.21
Cdh Tj = -7 °C	1.0	1.0
Pdh Tj = +2°C	4.4 kW	4.6 kW
COP Tj = +2°C	4.76	3.37
Cdh Tj = +2 °C	1.0	1.0
Pdh Tj = +7°C	4.3 kW	3.0 kW
COP Tj = +7°C	6.14	4.48
Cdh Tj = +7 °C	1.0	1.0

This information was generated by the HP KEYMARK database on 23 Jun 2022

Pdh Tj = 12°C	6.6 kW	3.7 kW
COP Tj = 12°C	7.84	5.98
Cdh Tj = +12 °C	1.0	1.0
Pdh Tj = Tbiv	8.1 kW	8.3 kW
COP Tj = Tbiv	2.77	1.97
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.14 kW	8.31 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.77	1.97
WTOL	35 °C	55 °C
Poff	21 W	21 W
PTO	24 W	24 W
PSB	21 W	21 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.0 kW	0.0 kW
Annual energy consumption Qhe	3637 kWh	5120 kWh

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 23 Jun 2022

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	128 %
COP	3.10
Heating up time	7:13 h:min
Standby power input	32.7 W
Reference hot water temperature	44.5 °C
Mixed water at 40°C	246.0 l

Model: EPRA12EW1 / ETSH(B)12P50E

Configure model

Model name	EPRA12EW1 / ETSH(B)12P50E
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data

Power supply	3x400V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	6.17 kW	7.72 kW
El input	1.21 kW	2.53 kW
COP	5.10	3.05

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

EN 14511-2

	+7°C/+12°C
El input	2.86 kW
Cooling capacity	8.62
EER	3.01

EN 14825

This information was generated by the HP KEYMARK database on 23 Jun 2022

	+7°C/+12°C
P _{designc}	8.5 kW
SEER	5.41
P _{dc} T _j = 35°C	8.62 kW
EER T _j = 35°C	3.01
P _{dc} T _j = 30°C	6.68 kW
EER T _j = 30°C	4.32
C _{dc}	0.98
P _{dc} T _j = 25°C	4.04 kW
EER T _j = 25°C	6.34
C _{dc}	0.96
P _{dc} T _j = 20°C	2.69 kW
EER T _j = 20°C	8.72
C _{dc}	0.91
P _{off}	31 W
PTO	0 W
PSB	31 W
PCK	0 W
Annual energy consumption Q _{ce}	943 kWh

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	47.3 dB(A)	47.3 dB(A)
Sound power level outdoor	53.0 dB(A)	53.0 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	191 %	138 %
Prated	8.3 kW	8.5 kW
SCOP	4.84	3.53
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.5 kW	7.6 kW
COP Tj = -7°C	3.20	2.30
Cdh Tj = -7 °C	1.0	1.0
Pdh Tj = +2°C	4.4 kW	4.6 kW
COP Tj = +2°C	4.93	3.50
Cdh Tj = +2 °C	1.0	1.0
Pdh Tj = +7°C	4.3 kW	3.0 kW
COP Tj = +7°C	6.37	4.61
Cdh Tj = +7 °C	1.0	1.0

This information was generated by the HP KEYMARK database on 23 Jun 2022

Pdh Tj = 12°C	6.6 kW	3.7 kW
COP Tj = 12°C	8.13	6.16
Cdh Tj = +12 °C	1.0	1.0
Pdh Tj = Tbiv	8.1 kW	8.3 kW
COP Tj = Tbiv	2.86	2.05
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.14 kW	8.31 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.86	2.05
WTOL	35 °C	55 °C
Poff	27 W	27 W
PTO	24 W	24 W
PSB	27 W	27 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.0 kW	0.0 kW
Annual energy consumption Qhe	3539 kWh	4970 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	131 %
COP	3.17
Heating up time	8:13 h:min
Standby power input	32.1 W
Reference hot water temperature	44.5 °C
Mixed water at 40°C	246.0 l

Model: EPRA08EV3 / ETSX(B)12P50E

Configure model	
Model name	EPRA08EV3 / ETSX(B)12P50E
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	6.17 kW	7.72 kW
El input	1.25 kW	2.63 kW
COP	4.92	2.94

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

EN 14511-2

	+7°C/+12°C
El input	2.15 kW
Cooling capacity	6.81
EER	3.17

EN 14825

This information was generated by the HP KEYMARK database on 23 Jun 2022

	+7°C/+12°C
P _{designc}	6.5 kW
SEER	5.38
P _{dc} T _j = 35°C	6.81 kW
EER T _j = 35°C	3.17
P _{dc} T _j = 30°C	5.00 kW
EER T _j = 30°C	4.37
C _{dc}	0.98
P _{dc} T _j = 25°C	3.01 kW
EER T _j = 25°C	6.58
C _{dc}	0.94
P _{dc} T _j = 20°C	2.57 kW
EER T _j = 20°C	8.00
C _{dc}	0.91
P _{off}	25 W
PTO	3 W
PSB	25 W
PCK	0 W
Annual energy consumption Q _{ce}	725 kWh

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	47.3 dB(A)	47.3 dB(A)
Sound power level outdoor	53.0 dB(A)	53.0 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	189 %	136 %
Prated	8.3 kW	8.5 kW
SCOP	4.79	3.47
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.5 kW	7.6 kW
COP Tj = -7°C	3.10	2.21
Cdh Tj = -7 °C	1.0	1.0
Pdh Tj = +2°C	4.4 kW	4.6 kW
COP Tj = +2°C	4.76	3.37
Cdh Tj = +2 °C	1.0	1.0
Pdh Tj = +7°C	4.3 kW	3.0 kW
COP Tj = +7°C	6.14	4.48
Cdh Tj = +7 °C	1.0	1.0

This information was generated by the HP KEYMARK database on 23 Jun 2022

Pdh Tj = 12°C	6.6 kW	3.7 kW
COP Tj = 12°C	7.84	5.98
Cdh Tj = +12 °C	1.0	1.0
Pdh Tj = Tbiv	7.5 kW	7.6 kW
COP Tj = Tbiv	3.10	2.21
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.92 kW	6.96 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.80	1.93
WTOL	35 °C	55 °C
Poff	21 W	21 W
PTO	24 W	24 W
PSB	21 W	21 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.38 kW	1.54 kW
Annual energy consumption Qhe	3582 kWh	5065 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	128 %
COP	3.10
Heating up time	9:13 h:min
Standby power input	32.7 W
Reference hot water temperature	44.5 °C
Mixed water at 40°C	246.0 l

Model: EPRA08EW1 / ETSX(B)12P50E

Configure model	
Model name	EPRA08EW1 / ETSX(B)12P50E
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	6.17 kW	7.72 kW
El input	1.21 kW	2.53 kW
COP	5.10	3.05

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

EN 14511-2

	+7°C/+12°C
El input	2.08 kW
Cooling capacity	6.81
EER	3.28

EN 14825

This information was generated by the HP KEYMARK database on 23 Jun 2022

	+7°C/+12°C
P _{designc}	6.5 kW
SEER	5.41
P _{dc} T _j = 35°C	6.81 kW
EER T _j = 35°C	3.28
P _{dc} T _j = 30°C	5.00 kW
EER T _j = 30°C	4.52
C _{dc}	0.97
P _{dc} T _j = 25°C	3.01 kW
EER T _j = 25°C	6.66
C _{dc}	0.94
P _{dc} T _j = 20°C	2.57 kW
EER T _j = 20°C	7.98
C _{dc}	0.91
P _{off}	31 W
PTO	0 W
PSB	31 W
PCK	0 W
Annual energy consumption Q _{ce}	719 kWh

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	47.3 dB(A)	47.3 dB(A)
Sound power level outdoor	53.0 dB(A)	53.0 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	195 %	141 %
Prated	8.3 kW	8.5 kW
SCOP	4.95	3.59
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.5 kW	7.6 kW
COP Tj = -7°C	3.20	2.30
Cdh Tj = -7 °C	1.0	1.0
Pdh Tj = +2°C	4.4 kW	4.6 kW
COP Tj = +2°C	4.93	3.50
Cdh Tj = +2 °C	1.0	1.0
Pdh Tj = +7°C	4.3 kW	3.0 kW
COP Tj = +7°C	6.37	4.61
Cdh Tj = +7 °C	1.0	1.0

This information was generated by the HP KEYMARK database on 23 Jun 2022

Pdh Tj = 12°C	6.6 kW	3.7 kW
COP Tj = 12°C	8.13	6.16
Cdh Tj = +12 °C	1.0	1.0
Pdh Tj = Tbiv	7.5 kW	7.6 kW
COP Tj = Tbiv	3.20	2.30
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.92 kW	6.96 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.90	2.01
WTOL	35 °C	55 °C
Poff	27 W	27 W
PTO	24 W	24 W
PSB	27 W	27 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.38 kW	1.54 kW
Annual energy consumption Qhe	3462 kWh	4894 kWh

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 23 Jun 2022

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	131 %
COP	3.17
Heating up time	10:13 h:min
Standby power input	32.1 W
Reference hot water temperature	44.5 °C
Mixed water at 40°C	246.0 l

Model: EPRA10EV3 / ETSX(B)12P50E

Configure model

Model name	EPRA10EV3 / ETSX(B)12P50E
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data

Power supply	1x230V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	6.17 kW	7.72 kW
El input	1.25 kW	2.63 kW
COP	4.92	2.94

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

EN 14511-2

	+7°C/+12°C
El input	2.66 kW
Cooling capacity	7.97
EER	3.00

EN 14825

This information was generated by the HP KEYMARK database on 23 Jun 2022

	+7°C/+12°C
P _{designc}	7.5 kW
SEER	5.34
P _{dc} T _j = 35°C	7.97 kW
EER T _j = 35°C	3.00
P _{dc} T _j = 30°C	5.76 kW
EER T _j = 30°C	4.28
C _{dc}	0.98
P _{dc} T _j = 25°C	3.63 kW
EER T _j = 25°C	6.31
C _{dc}	0.95
P _{dc} T _j = 20°C	2.63 kW
EER T _j = 20°C	8.37
C _{dc}	0.91
P _{off}	25 W
PTO	3 W
PSB	25 W
PCK	0 W
Annual energy consumption Q _{ce}	843 kWh

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	47.3 dB(A)	47.3 dB(A)
Sound power level outdoor	53.0 dB(A)	53.0 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	190 %	136 %
Prated	8.3 kW	8.5 kW
SCOP	4.82	3.48
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.5 kW	7.6 kW
COP Tj = -7°C	3.10	2.21
Cdh Tj = -7 °C	1.0	1.0
Pdh Tj = +2°C	4.4 kW	4.6 kW
COP Tj = +2°C	4.76	3.37
Cdh Tj = +2 °C	1.0	1.0
Pdh Tj = +7°C	4.3 kW	3.0 kW
COP Tj = +7°C	6.14	4.48
Cdh Tj = +7 °C	1.0	1.0

This information was generated by the HP KEYMARK database on 23 Jun 2022

Pdh Tj = 12°C	6.6 kW	3.7 kW
COP Tj = 12°C	7.84	5.98
Cdh Tj = +12 °C	1.0	1.0
Pdh Tj = Tbiv	8.1 kW	8.3 kW
COP Tj = Tbiv	2.77	1.97
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.14 kW	8.31 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.77	1.97
WTOL	35 °C	55 °C
Poff	21 W	21 W
PTO	24 W	24 W
PSB	21 W	21 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.0 kW	0.0 kW
Annual energy consumption Qhe	3560 kWh	5043 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	128 %
COP	3.10
Heating up time	11:13 h:min
Standby power input	32.7 W
Reference hot water temperature	44.5 °C
Mixed water at 40°C	246.0 l

Model: EPRA10EW1 / ETSX(B)12P50E

Configure model

Model name	EPRA10EW1 / ETSX(B)12P50E
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data

Power supply	3x400V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	6.17 kW	7.72 kW
El input	1.21 kW	2.53 kW
COP	5.10	3.05

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

EN 14511-2

	+7°C/+12°C
El input	2.57 kW
Cooling capacity	7.97
EER	3.10

EN 14825

This information was generated by the HP KEYMARK database on 23 Jun 2022

	+7°C/+12°C
P _{designc}	7.5 kW
SEER	5.41
P _{dc} T _j = 35°C	7.97 kW
EER T _j = 35°C	3.10
P _{dc} T _j = 30°C	5.76 kW
EER T _j = 30°C	4.43
C _{dc}	0.98
P _{dc} T _j = 25°C	3.63 kW
EER T _j = 25°C	6.47
C _{dc}	0.95
P _{dc} T _j = 20°C	2.63 kW
EER T _j = 20°C	8.35
C _{dc}	0.91
P _{off}	31 W
PTO	0 W
PSB	31 W
PCK	0 W
Annual energy consumption Q _{ce}	831 kWh

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	47.3 dB(A)	47.3 dB(A)
Sound power level outdoor	53.0 dB(A)	53.0 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	196 %	141 %
Prated	8.3 kW	8.5 kW
SCOP	4.98	3.60
Tbiv	-7 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.5 kW	7.6 kW
COP Tj = -7°C	3.20	2.30
Cdh Tj = -7 °C	1.0	1.0
Pdh Tj = +2°C	4.4 kW	4.6 kW
COP Tj = +2°C	4.93	3.50
Cdh Tj = +2 °C	1.0	1.0
Pdh Tj = +7°C	4.3 kW	3.0 kW
COP Tj = +7°C	6.37	4.61
Cdh Tj = +7 °C	1.0	1.0

This information was generated by the HP KEYMARK database on 23 Jun 2022

Pdh Tj = 12°C	6.6 kW	3.7 kW
COP Tj = 12°C	8.13	6.16
Cdh Tj = +12 °C	1.0	1.0
Pdh Tj = Tbiv	8.1 kW	8.3 kW
COP Tj = Tbiv	2.86	2.05
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.14 kW	8.31 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.86	2.05
WTOL	35 °C	55 °C
Poff	27 W	27 W
PTO	24 W	24 W
PSB	27 W	27 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.0 kW	0.0 kW
Annual energy consumption Qhe	3440 kWh	4871 kWh

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 23 Jun 2022

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	131 %
COP	3.17
Heating up time	12:13 h:min
Standby power input	32.1 W
Reference hot water temperature	44.5 °C
Mixed water at 40°C	246.0 l

Model: EPRA12EV3 / ETSX(B)12P50E

Configure model	
Model name	EPRA12EV3 / ETSX(B)12P50E
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	6.17 kW	7.72 kW
El input	1.25 kW	2.63 kW
COP	4.92	2.94

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

EN 14511-2

	+7°C/+12°C
El input	2.96 kW
Cooling capacity	8.62
EER	2.91

EN 14825

This information was generated by the HP KEYMARK database on 23 Jun 2022

	+7°C/+12°C
P _{designc}	8.5 kW
SEER	5.31
P _{dc} T _j = 35°C	8.62 kW
EER T _j = 35°C	2.91
P _{dc} T _j = 30°C	6.68 kW
EER T _j = 30°C	4.17
C _{dc}	0.98
P _{dc} T _j = 25°C	4.04 kW
EER T _j = 25°C	6.13
C _{dc}	0.96
P _{dc} T _j = 20°C	2.69 kW
EER T _j = 20°C	8.75
C _{dc}	0.91
P _{off}	25 W
PTO	3 W
PSB	25 W
PCK	0 W
Annual energy consumption Q _{ce}	961 kWh

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	47.3 dB(A)	47.3 dB(A)
Sound power level outdoor	53.0 dB(A)	53.0 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	190 %	136 %
Prated	8.3 kW	8.5 kW
SCOP	4.82	3.48
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.5 kW	7.6 kW
COP Tj = -7°C	3.10	2.21
Cdh Tj = -7 °C	1.0	1.0
Pdh Tj = +2°C	4.4 kW	4.6 kW
COP Tj = +2°C	4.76	3.37
Cdh Tj = +2 °C	1.0	1.0
Pdh Tj = +7°C	4.3 kW	3.0 kW
COP Tj = +7°C	6.14	4.48
Cdh Tj = +7 °C	1.0	1.0

This information was generated by the HP KEYMARK database on 23 Jun 2022

Pdh Tj = 12°C	6.6 kW	3.7 kW
COP Tj = 12°C	7.84	5.98
Cdh Tj = +12 °C	1.0	1.0
Pdh Tj = Tbiv	8.1 kW	8.3 kW
COP Tj = Tbiv	2.77	1.97
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.14 kW	8.31 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.77	1.97
WTOL	35 °C	55 °C
Poff	21 W	21 W
PTO	24 W	24 W
PSB	21 W	21 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.0 kW	0.0 kW
Annual energy consumption Qhe	3560 kWh	5043 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	128 %
COP	3.10
Heating up time	13:13 h:min
Standby power input	32.7 W
Reference hot water temperature	44.5 °C
Mixed water at 40°C	246.0 l

Model: EPRA12EW1 / ETSX(B)12P50E

Configure model

Model name	EPRA12EW1 / ETSX(B)12P50E
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data

Power supply	3x400V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	6.17 kW	7.72 kW
El input	1.21 kW	2.53 kW
COP	5.10	3.05

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

EN 14511-2

	+7°C/+12°C
El input	2.86 kW
Cooling capacity	8.62
EER	3.01

EN 14825

This information was generated by the HP KEYMARK database on 23 Jun 2022

	+7°C/+12°C
P _{designc}	8.5 kW
SEER	5.41
P _{dc} T _j = 35°C	8.62 kW
EER T _j = 35°C	3.01
P _{dc} T _j = 30°C	6.68 kW
EER T _j = 30°C	4.32
C _{dc}	0.98
P _{dc} T _j = 25°C	4.04 kW
EER T _j = 25°C	6.34
C _{dc}	0.96
P _{dc} T _j = 20°C	2.69 kW
EER T _j = 20°C	8.72
C _{dc}	0.91
P _{off}	31 W
PTO	0 W
PSB	31 W
PCK	0 W
Annual energy consumption Q _{ce}	943 kWh

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	47.3 dB(A)	47.3 dB(A)
Sound power level outdoor	53.0 dB(A)	53.0 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	196 %	141 %
Prated	8.3 kW	8.5 kW
SCOP	4.98	3.60
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.5 kW	7.6 kW
COP Tj = -7°C	3.20	2.30
Cdh Tj = -7 °C	1.0	1.0
Pdh Tj = +2°C	4.4 kW	4.6 kW
COP Tj = +2°C	4.93	3.50
Cdh Tj = +2 °C	1.0	1.0
Pdh Tj = +7°C	4.3 kW	3.0 kW
COP Tj = +7°C	6.37	4.61
Cdh Tj = +7 °C	1.0	1.0

This information was generated by the HP KEYMARK database on 23 Jun 2022

Pdh Tj = 12°C	6.6 kW	3.7 kW
COP Tj = 12°C	8.13	6.16
Cdh Tj = +12 °C	1.0	1.0
Pdh Tj = Tbiv	8.1 kW	8.3 kW
COP Tj = Tbiv	2.86	2.05
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.14 kW	8.31 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.86	2.05
WTOL	35 °C	55 °C
Poff	27 W	27 W
PTO	24 W	24 W
PSB	27 W	27 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.0 kW	0.0 kW
Annual energy consumption Qhe	3440 kWh	4871 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	131 %
COP	3.17
Heating up time	14:13 h:min
Standby power input	32.1 W
Reference hot water temperature	44.5 °C
Mixed water at 40°C	246.0 l