

This information was generated by the HP KEYMARK database on 17 Dec 2020

Summary of	AUREA 5	Reg. No.	012-SC1489-17
Certificate Holder			
Name	Groupe Atlantic		
Address	44 boulevard des Etats-Unis	Zip	85000
City	La Roche Sur Yon	Country	France
Certification Body	RISE CERT		
Name of testing laboratory	RISE		
Subtype title	AUREA 5		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R410a		
Mass Of Refrigerant	1.05 kg		

## Model: AUREA 5

### General Data

Power supply	1x230V 50Hz
--------------	-------------

## Heating

### EN 14511-2

	Low temperature	Medium temperature
Heat output	4.84 kW	4.10 kW
El input	1.20 kW	1.58 kW
COP	4.03	2.60
Indoor water flow rate	0.87 m <sup>3</sup> /h	0.46 m <sup>3</sup> /h

### EN 14511-4

Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

## Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

### EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	0 dB(A)	0 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

### EN 14825

	Low temperature	Medium temperature
$\eta_s$	167 %	119 %
Prated	4.40 kW	4.40 kW
SCOP	4.25	3.06
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	3.89 kW	3.89 kW
COP Tj = -7°C	2.64	1.82
Pdh Tj = +2°C	2.37 kW	2.37 kW
COP Tj = +2°C	4.35	3.11
Pdh Tj = +7°C	2.16 kW	1.92 kW
COP Tj = +7°C	5.93	4.15
Pdh Tj = 12°C	1.15 kW	0.96 kW
COP Tj = 12°C	7.55	5.03
Pdh Tj = Tbiv	3.89 kW	3.89 kW

This information was generated by the HP KEYMARK database on 17 Dec 2020

COP $T_j = T_{biv}$	2.64	1.82
P <sub>dh</sub> $T_j = TOL$	3.72 kW	3.41 kW
COP $T_j = TOL$	2.57	1.52
C <sub>dh</sub>	0.84	0.89
WTOL	55 °C	55 °C
P <sub>off</sub>	5 W	5 W
PTO	60 W	50 W
PSB	5 W	5 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	0.70 kW	1.00 kW
Annual energy consumption Q <sub>he</sub>	2137 kWh	2973 kWh