

This information was generated by the HP KEYMARK database on 18 Mar 2022

[Login](#)

Summary of	HMI120 / DHWT300	Reg. No.	041-K011-05
Certificate Holder			
Name	AERMEC S.p.A.		
Address	Via Roma 996	Zip	37040
City	Bevilacqua (VR)	Country	Italy
Certification Body	BRE Global Limited		
Subtype title	HMI120 / DHWT300		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R32		
Mass of Refrigerant	2.2 kg		
Certification Date	25.03.2021		
Testing basis	Heat Pump Keymark Scheme Rules Rev 08		

Model: HMI120 / DHWT300X

Configure model	
Model name	HMI120 / DHWT300X
Application	Heating + DHW
Units	Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2	
	Medium temperature
Heat output	10.50 kW
El input	4.12 kW
COP	2.55

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 12102-1

Medium temperature

Sound power level outdoor

69 dB(A)

EN 14825

Medium temperature

 η_s

126 %

Prated

10.00 kW

SCOP

3.23

Tbiv

-7 °C

TOL

-10 °C

Pdh Tj = -7°C

8.40 kW

COP Tj = -7°C

2.05

Cdh Tj = -7 °C

0.98

Pdh Tj = +2°C

5.50 kW

COP Tj = +2°C

3.15

Cdh Tj = +2 °C

0.98

Pdh Tj = +7°C

5.76 kW

COP Tj = +7°C

4.24

Cdh Tj = +7 °C

0.98

Pdh Tj = 12°C

6.36 kW

This information was generated by the HP KEYMARK database on 18 Mar 2022

COP Tj = 12°C	5.06
Cdh Tj = +12 °C	0.98
Pdh Tj = Tbiv	8.40 kW
COP Tj = Tbiv	2.05
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.80 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	1.75
WTOL	55 °C
Poff	18 W
PTO	18 W
PSB	18 W
PCK	0 W
Supplementary Heater: Type of energy input	Electricity
Supplementary Heater: PSUP	0.20 kW
Annual energy consumption Qhe	6406 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	XL
Efficiency η_{DHW}	110 %
COP	2.62
Heating up time	1:52 h:min
Standby power input	62.6 W
Reference hot water temperature	52.8 °C
Mixed water at 40°C	372 l

Model: HMI120T / DHWT300XT

Configure model	
Model name	HMI120T / DHWT300XT
Application	Heating + DHW
Units	Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2	
	Medium temperature
Heat output	10.50 kW
El input	4.12 kW
COP	2.55

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 12102-1

Medium temperature

Sound power level outdoor

69 dB(A)

EN 14825

Medium temperature

 η_s

126 %

Prated

10.00 kW

SCOP

3.23

Tbiv

-7 °C

TOL

-10 °C

Pdh Tj = -7°C

8.40 kW

COP Tj = -7°C

2.05

Cdh Tj = -7 °C

0.98

Pdh Tj = +2°C

5.50 kW

COP Tj = +2°C

3.15

Cdh Tj = +2 °C

0.98

Pdh Tj = +7°C

5.76 kW

COP Tj = +7°C

4.24

Cdh Tj = +7 °C

0.98

Pdh Tj = 12°C

6.36 kW

This information was generated by the HP KEYMARK database on 18 Mar 2022

COP Tj = 12°C	5.06
Cdh Tj = +12 °C	0.98
Pdh Tj = Tbiv	8.40 kW
COP Tj = Tbiv	2.05
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.80 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	1.75
WTOL	55 °C
Poff	18 W
PTO	18 W
PSB	18 W
PCK	0 W
Supplementary Heater: Type of energy input	Electricity
Supplementary Heater: PSUP	0.20 kW
Annual energy consumption Qhe	6406 kWh

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 16147	
Declared load profile	XL
Efficiency η_{DHW}	110 %
COP	2.62
Heating up time	1:52 h:min
Standby power input	62.6 W
Reference hot water temperature	52.8 °C
Mixed water at 40°C	372 l