Login

Summary of	NIMBUS/ARIANEXT/AEROTOP/ENERGION 80 M - Plus/LB	Reg. No.	ICIM-PDC-000117
Certificate Holder			
Name	Ariston Thermo Group		
Address	Viale Aristide Merloni 45	Zip	I-60044
City	Fabriano (AN)	Country	Italy
Certification Body	ICIM S.p.A.		
Subtype title	NIMBUS/ARIANEXT/AEROTOP/ENERGION 80 M - Plus/LB		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R32		
Mass of Refrigerant	1.4 kg		
Certification Date	05.07.2022		
Testing basis	Heat Pump KEYMARK rev9		

Model: NIMBUS PLUS 80 M NET R32

Configure model	
Model name	NIMBUS PLUS 80 M NET R32
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	8.00 kW	5.80 kW
El input	1.67 kW	1.97 kW
COP	4.80	2.95

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

EN 14511-2

	+7°C/+12°C	+18°C/+23°C
El input	2.26 kW	1.49 kW
Cooling capacity	7	7.00
EER	3.10	4.70

EN 14825

	+7°C/+12°C
Pdesignc	7 kW
SEER	4.64
Pdc Tj = 35°C	7 kW
EER Tj = 35°C	3.1
Pdc Tj = 30°C	5.17 kW
EER Tj = 30°C	4.13
Cdc Tj = 30 °C	0.99
Pdc Tj = 25°C	3.32 kW
EER Tj = 25°C	4.89
Cdc Tj = 25 °C	0.98
Pdc Tj = 20°C	3.19 kW
EER Tj = 20°C	6.85
Cdc Tj = 20 °C	0.97
Poff	14 W
PTO	14 W
PSB	14 W
PCK	0 W
Annual energy consumption Qce	1381 kWh

Warmer Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	35 dB(A)	35 dB(A)
Sound power level outdoor	57 dB(A)	57 dB(A)

EN 14825

	Low temperature	Medium temperature
Pdesignh	4.93 kW	4.48 kW
η_s	242 %	151 %
Prated	4.93 kW	4.48 kW
SCOP	6.14	3.84
Tbiv	2 °C	2 °C
TOL	-20 °C	-20 °C
Pdh Tj = +2°C	4.93 kW	4.48 kW
COP Tj = +2°C	4.05	2.53
Cdh Tj = +2 °C	0.989	0.992
Pdh Tj = +7°C	3.10 kW	2.81 kW
COP Tj = +7°C	5.70	3.08
Cdh Tj = +7 °C	0.975	0.985
Pdh Tj = 12°C	3.28 kW	3.16 kW
COP Tj = 12°C	7.86	5.45

Cdh Tj = +12 °C	0.967	0.977
Pdh Tj = Tbiv	4.93 kW	4.48 kW
COP Tj = Tbiv	4.05	2.53
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.51 kW	4.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.22	1.51
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		
WTOL	60 °C	60 °C
Poff	14 W	14 W
PTO	14 W	14 W
PSB	14 W	14 W
PCK	14 W	14 W
Supplementary Heater: Type of energy input	n/a	n/a
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Backup Heater	4.00 kW	4.00 kW
Annual energy consumption Qhe	1073 kWh	1557 kWh

Colder Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	35 dB(A)	35 dB(A)
Sound power level outdoor	57 dB(A)	57 dB(A)

EN 14825

	Low temperature	Medium temperature
Pdesignh	11.78 kW	11.53 kW
η_s	154 %	120 %
Prated	11.78 kW	11.53 kW
SCOP	3.93	3.08
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	7.13 kW	6.98 kW
COP Tj = -7°C	3.47	2.73
Cdh Tj = -7 °C	0.993	0.995
Pdh Tj = +2°C	4.51 kW	4.20 kW
COP Tj = +2°C	5.32	4.07
Cdh Tj = +2 °C	0.984	0.987
Pdh Tj = +7°C	3.06 kW	2.84 kW
COP Tj = +7°C	7.24	5.15
Cdh Tj = +7 °C	0.968	0.975
Pdh Tj = 12°C	3.18 kW	3.24 kW
COP Tj = 12°C	8.02	6.47
Cdh Tj = +12 °C	0.966	0.973
Pdh Tj = Tbiv	7.13 kW	6.98 kW

COP Tj = Tbiv	3.47	2.70
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.51 kW	4.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.22	1.51
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.993	0.995
WTOL	60 °C	60 °C
Poff	14 W	14 W
PTO	14 W	14 W
PSB	14 W	14 W
PCK	14 W	14 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	11.16 kW	10.93 kW
Backup Heater	4.00 kW	4.00 kW
Annual energy consumption Qhe	7398 kWh	9226 kWh
Pdh Tj = -15°C (if TOL<-20°C)		
COP Tj = -15°C (if TOL<-20°C)		
Cdh Tj = -15 °C		

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	35 dB(A)	35 dB(A)
Sound power level outdoor	57 dB(A)	57 dB(A)

EN 14825

	Low temperature	Medium temperature
Pdesignh	8.37 kW	7.62 kW
η_s	195 %	140 %
Prated	8.37 kW	7.62 kW
SCOP	4.95	3.57
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	7.40 kW	6.74 kW
COP Tj = -7°C	3.10	2.29
Cdh Tj = -7 °C	0.994	0.995
Pdh Tj = +2°C	4.54 kW	4.22 kW
COP Tj = +2°C	4.80	3.51
Cdh Tj = +2 °C	0.986	0.989
Pdh Tj = +7°C	2.94 kW	2.74 kW
COP Tj = +7°C	6.61	4.36
Cdh Tj = +7 °C	0.969	0.978
Pdh Tj = 12°C	3.16 kW	3.28 kW
COP Tj = 12°C	8.15	6.50
Cdh Tj = +12 °C	0.965	0.973
Pdh Tj = Tbiv	7.40 kW	6.74 kW

COP Tj = Tbiv	3.10	2.29
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.51 kW	4.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.22	1.51
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.994	0.995
WTOL	60 °C	60 °C
Poff	14 W	14 W
PTO	14 W	14 W
PSB	14 W	14 W
PCK	14 W	14 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.86 kW	2.72 kW
Backup Heater	4.00 kW	4.00 kW
Annual energy consumption Qhe	3490 kWh	4405 kWh

Model: NIMBUS PLUS 80 M-T NET R32

Configure model	
Model name	NIMBUS PLUS 80 M-T NET R32
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	8.00 kW	5.80 kW
El input	1.67 kW	1.97 kW
COP	4.80	2.95

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

EN 14511-2

	+7°C/+12°C	+18°C/+23°C
El input	2.26 kW	1.49 kW
Cooling capacity	7	7.00
EER	3.10	4.70

EN 14825

	+7°C/+12°C
Pdesignc	7 kW
SEER	4.64
Pdc Tj = 35°C	7 kW
EER Tj = 35°C	3.1
Pdc Tj = 30°C	5.17 kW
EER Tj = 30°C	4.13
Cdc Tj = 30 °C	0.99
Pdc Tj = 25°C	3.32 kW
EER Tj = 25°C	4.89
Cdc Tj = 25 °C	0.98
Pdc Tj = 20°C	3.19 kW
EER Tj = 20°C	6.85
Cdc Tj = 20 °C	0.97
Poff	14 W
PTO	14 W
PSB	14 W
PCK	0 W
Annual energy consumption Qce	1381 kWh

Warmer Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	35 dB(A)	35 dB(A)
Sound power level outdoor	57 dB(A)	57 dB(A)

EN 14825

	Low temperature	Medium temperature
Pdesignh	4.93 kW	4.48 kW
η_s	242 %	151 %
Prated	4.93 kW	4.48 kW
SCOP	6.14	3.84
Tbiv	2 °C	2 °C
TOL	-20 °C	-20 °C
Pdh Tj = +2°C	4.93 kW	4.48 kW
COP Tj = +2°C	4.05	2.53
Cdh Tj = +2 °C	0.989	0.992
Pdh Tj = +7°C	3.10 kW	2.81 kW
COP Tj = +7°C	5.70	3.08
Cdh Tj = +7 °C	0.975	0.985
Pdh Tj = 12°C	3.28 kW	3.16 kW
COP Tj = 12°C	7.86	5.45

Cdh Tj = +12 °C	0.967	0.977
Pdh Tj = Tbiv	4.93 kW	4.48 kW
COP Tj = Tbiv	4.05	2.53
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.51 kW	4.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.22	1.51
WTOL	60 °C	60 °C
Poff	14 W	14 W
PTO	14 W	14 W
PSB	14 W	14 W
PCK	14 W	14 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Backup Heater	4.00 kW	4.00 kW
Annual energy consumption Qhe	1073 kWh	1557 kWh

Colder Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	35 dB(A)	35 dB(A)
Sound power level outdoor	57 dB(A)	57 dB(A)

EN 14825

	Low temperature	**Medium temperature**
Pdesignh	11.78 kW	11.53 kW
η_s	154 %	120 %
Prated	11.78 kW	11.53 kW
SCOP	3.93	3.08
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	7.13 kW	6.98 kW
COP Tj = -7°C	3.47	2.73
Cdh Tj = -7 °C	0.993	0.995
Pdh Tj = +2°C	4.51 kW	4.20 kW
COP Tj = +2°C	5.32	4.07
Cdh Tj = +2 °C	0.984	0.987
Pdh Tj = +7°C	3.06 kW	2.84 kW
COP Tj = +7°C	7.24	5.15
Cdh Tj = +7 °C	0.968	0.975
Pdh Tj = 12°C	3.18 kW	3.24 kW
COP Tj = 12°C	8.02	6.47
Cdh Tj = +12 °C	0.966	0.973
Pdh Tj = Tbiv	7.13 kW	6.98 kW

COP Tj = Tbiv	3.47	2.70
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.51 kW	4.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.22	1.51
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.993	0.995
WTOL	60 °C	60 °C
Poff	14 W	14 W
PTO	14 W	14 W
PSB	14 W	14 W
PCK	14 W	14 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	11.16 kW	10.93 kW
Backup Heater	4.00 kW	4.00 kW
Annual energy consumption Qhe	7398 kWh	9226 kWh

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	35 dB(A)	35 dB(A)
Sound power level outdoor	57 dB(A)	57 dB(A)

EN 14825

	Low temperature	**Medium temperature**
Pdesignh	8.37 kW	7.62 kW
η_s	195 %	140 %
Prated	8.37 kW	7.62 kW
SCOP	4.95	3.57
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	7.40 kW	6.74 kW
COP Tj = -7°C	3.10	2.29
Cdh Tj = -7 °C	0.994	0.995
Pdh Tj = +2°C	4.54 kW	4.22 kW
COP Tj = +2°C	4.80	3.51
Cdh Tj = +2 °C	0.986	0.989
Pdh Tj = +7°C	2.94 kW	2.74 kW
COP Tj = +7°C	6.61	4.36
Cdh Tj = +7 °C	0.969	0.978
Pdh Tj = 12°C	3.16 kW	3.28 kW
COP Tj = 12°C	8.15	6.50
Cdh Tj = +12 °C	0.965	0.973
Pdh Tj = Tbiv	7.40 kW	6.74 kW
COP Tj = Tbiv	3.10	2.29

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.51 kW	4.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.22	1.51
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.994	0.995
WTOL	60 °C	60 °C
Poff	14 W	14 W
PTO	14 W	14 W
PSB	14 W	14 W
PCK	14 W	14 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.86 kW	2.72 kW
Backup Heater	4.00 kW	4.00 kW
Annual energy consumption Qhe	3490 kWh	4405 kWh

Model: NIMBUS POCKET 80 M NET R32

Configure model	
Model name	NIMBUS POCKET 80 M NET R32
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	8.00 kW	5.80 kW
El input	1.67 kW	1.97 kW
COP	4.80	2.95

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

EN 14511-2

	+7°C/+12°C	+18°C/+23°C
El input	2.26 kW	1.49 kW
Cooling capacity	7	7.00
EER	3.10	4.70

EN 14825

	+7°C/+12°C
Pdesignc	7 kW
SEER	4.64
Pdc Tj = 35°C	7 kW
EER Tj = 35°C	3.1
Pdc Tj = 30°C	5.17 kW
EER Tj = 30°C	4.13
Cdc Tj = 30 °C	0.99
Pdc Tj = 25°C	3.32 kW
EER Tj = 25°C	4.89
Cdc Tj = 25 °C	0.98
Pdc Tj = 20°C	3.19 kW
EER Tj = 20°C	6.85
Cdc Tj = 20 °C	0.97
Poff	14 W
PTO	14 W
PSB	14 W
PCK	0 W
Annual energy consumption Qce	1381 kWh

Warmer Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	15 dB(A)	15 dB(A)
Sound power level outdoor	57 dB(A)	57 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
Pdesignh	4.93 kW	4.48 kW
η_s	242 %	151 %
Prated	4.93 kW	4.48 kW
SCOP	6.14	3.84
Tbiv	2 °C	2 °C
TOL	-20 °C	-20 °C
Pdh Tj = +2°C	4.93 kW	4.48 kW
COP Tj = +2°C	4.05	2.53
Cdh Tj = +2 °C	0.989	0.992
Pdh Tj = +7°C	3.10 kW	2.81 kW
COP Tj = +7°C	5.70	3.08
Cdh Tj = +7 °C	0.975	0.985
Pdh Tj = 12°C	3.28 kW	3.16 kW
COP Tj = 12°C	7.86	5.45

Cdh Tj = +12 °C	0.967	0.977
Pdh Tj = Tbiv	4.93 kW	4.48 kW
COP Tj = Tbiv	4.05	2.53
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.51 kW	4.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.22	1.51
WTOL	60 °C	60 °C
Poff	14 W	14 W
PTO	14 W	14 W
PSB	14 W	14 W
PCK	14 W	14 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Backup Heater	4.00 kW	4.00 kW
Annual energy consumption Qhe	1073 kWh	1557 kWh

Colder Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	15 dB(A)	15 dB(A)
Sound power level outdoor	57 dB(A)	57 dB(A)

EN 14825

	Low temperature	**Medium temperature**
Pdesignh	11.78 kW	11.53 kW
η_s	154 %	120 %
Prated	11.78 kW	11.53 kW
SCOP	3.93	3.08
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	7.13 kW	6.98 kW
COP Tj = -7°C	3.47	2.73
Cdh Tj = -7 °C	0.993	0.995
Pdh Tj = +2°C	4.51 kW	4.20 kW
COP Tj = +2°C	5.32	4.07
Cdh Tj = +2 °C	0.984	0.987
Pdh Tj = +7°C	3.06 kW	2.84 kW
COP Tj = +7°C	7.24	5.15
Cdh Tj = +7 °C	0.968	0.975
Pdh Tj = 12°C	3.18 kW	3.24 kW
COP Tj = 12°C	8.02	6.47
Cdh Tj = +12 °C	0.966	0.973
Pdh Tj = Tbiv	7.13 kW	6.98 kW

COP Tj = Tbiv	3.47	2.70
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.51 kW	4.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.22	1.51
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.993	0.995
WTOL	60 °C	60 °C
Poff	14 W	14 W
PTO	14 W	14 W
PSB	14 W	14 W
PCK	14 W	14 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	11.16 kW	10.93 kW
Backup Heater	4.00 kW	4.00 kW
Annual energy consumption Qhe	7398 kWh	9226 kWh

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	15 dB(A)	15 dB(A)
Sound power level outdoor	57 dB(A)	57 dB(A)

EN 14825

	Low temperature	**Medium temperature**
Pdesignh	8.37 kW	7.62 kW
η_s	195 %	140 %
Prated	8.37 kW	7.62 kW
SCOP	4.95	3.57
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	7.40 kW	6.74 kW
COP Tj = -7°C	3.10	2.29
Cdh Tj = -7 °C	0.994	0.995
Pdh Tj = +2°C	4.54 kW	4.22 kW
COP Tj = +2°C	4.80	3.51
Cdh Tj = +2 °C	0.986	0.989
Pdh Tj = +7°C	2.94 kW	2.74 kW
COP Tj = +7°C	6.61	4.36
Cdh Tj = +7 °C	0.969	0.978
Pdh Tj = 12°C	3.16 kW	3.28 kW
COP Tj = 12°C	8.15	6.50
Cdh Tj = +12 °C	0.965	0.973
Pdh Tj = Tbiv	7.40 kW	6.74 kW
COP Tj = Tbiv	3.10	2.29

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.51 kW	4.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.22	1.51
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.994	0.995
WTOL	60 °C	60 °C
Poff	14 W	14 W
PTO	14 W	14 W
PSB	14 W	14 W
PCK	14 W	14 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.86 kW	2.72 kW
Backup Heater	4.00 kW	4.00 kW
Annual energy consumption Qhe	3490 kWh	4405 kWh

Model: NIMBUS POCKET 80 M-T NET R32

Configure model	
Model name	NIMBUS POCKET 80 M-T NET R32
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	8.00 kW	5.80 kW
El input	1.67 kW	1.97 kW
COP	4.80	2.95

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

EN 14511-2

	+7°C/+12°C	+18°C/+23°C
El input	2.26 kW	1.49 kW
Cooling capacity	7	7.00
EER	3.10	4.70

EN 14825

	+7°C/+12°C
Pdesignc	7 kW
SEER	4.64
Pdc Tj = 35°C	7 kW
EER Tj = 35°C	3.1
Pdc Tj = 30°C	5.17 kW
EER Tj = 30°C	4.13
Cdc Tj = 30 °C	0.99
Pdc Tj = 25°C	3.32 kW
EER Tj = 25°C	4.89
Cdc Tj = 25 °C	0.98
Pdc Tj = 20°C	3.19 kW
EER Tj = 20°C	6.85
Cdc Tj = 20 °C	0.97
Poff	14 W
PTO	14 W
PSB	14 W
PCK	0 W
Annual energy consumption Qce	1381 kWh

Warmer Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	15 dB(A)	15 dB(A)
Sound power level outdoor	57 dB(A)	57 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
Pdesignh	4.93 kW	4.48 kW
η_s	242 %	151 %
Prated	4.93 kW	4.48 kW
SCOP	6.14	3.84
Tbiv	2 °C	2 °C
TOL	-20 °C	-20 °C
Pdh Tj = +2°C	4.93 kW	4.48 kW
COP Tj = +2°C	4.05	2.53
Cdh Tj = +2 °C	0.989	0.992
Pdh Tj = +7°C	3.10 kW	2.81 kW
COP Tj = +7°C	5.70	3.08
Cdh Tj = +7 °C	0.975	0.985
Pdh Tj = 12°C	3.28 kW	3.16 kW
COP Tj = 12°C	7.86	5.45

Cdh Tj = +12 °C	0.967	0.977
Pdh Tj = Tbiv	4.93 kW	4.48 kW
COP Tj = Tbiv	4.05	2.53
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.51 kW	4.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.22	1.51
WTOL	60 °C	60 °C
Poff	14 W	14 W
PTO	14 W	14 W
PSB	14 W	14 W
PCK	14 W	14 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Backup Heater	4.00 kW	4.00 kW
Annual energy consumption Qhe	1073 kWh	1557 kWh

Colder Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	15 dB(A)	15 dB(A)
Sound power level outdoor	57 dB(A)	57 dB(A)

EN 14825

	Low temperature	**Medium temperature**
Pdesignh	11.78 kW	11.53 kW
η_s	154 %	120 %
Prated	11.78 kW	11.53 kW
SCOP	3.93	3.08
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	7.13 kW	6.98 kW
COP Tj = -7°C	3.47	2.73
Cdh Tj = -7 °C	0.993	0.995
Pdh Tj = +2°C	4.51 kW	4.20 kW
COP Tj = +2°C	5.32	4.07
Cdh Tj = +2 °C	0.984	0.987
Pdh Tj = +7°C	3.06 kW	2.84 kW
COP Tj = +7°C	7.24	5.15
Cdh Tj = +7 °C	0.968	0.975
Pdh Tj = 12°C	3.18 kW	3.24 kW
COP Tj = 12°C	8.02	6.47
Cdh Tj = +12 °C	0.966	0.973
Pdh Tj = Tbiv	7.13 kW	6.98 kW

COP Tj = Tbiv	3.47	2.70
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.51 kW	4.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.22	1.51
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.993	0.995
WTOL	60 °C	60 °C
Poff	14 W	14 W
PTO	14 W	14 W
PSB	14 W	14 W
PCK	14 W	14 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	11.16 kW	10.93 kW
Backup Heater	4.00 kW	4.00 kW
Annual energy consumption Qhe	7398 kWh	9226 kWh

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	15 dB(A)	15 dB(A)
Sound power level outdoor	57 dB(A)	57 dB(A)

EN 14825

	Low temperature	**Medium temperature**
Pdesignh	8.37 kW	7.62 kW
η_s	195 %	140 %
Prated	8.37 kW	7.62 kW
SCOP	4.95	3.57
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	7.40 kW	6.74 kW
COP Tj = -7°C	3.10	2.29
Cdh Tj = -7 °C	0.994	0.995
Pdh Tj = +2°C	4.54 kW	4.22 kW
COP Tj = +2°C	4.80	3.51
Cdh Tj = +2 °C	0.986	0.989
Pdh Tj = +7°C	2.94 kW	2.74 kW
COP Tj = +7°C	6.61	4.36
Cdh Tj = +7 °C	0.969	0.978
Pdh Tj = 12°C	3.16 kW	3.28 kW
COP Tj = 12°C	8.15	6.50
Cdh Tj = +12 °C	0.965	0.973
Pdh Tj = Tbiv	7.40 kW	6.74 kW
COP Tj = Tbiv	3.10	2.29

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.51 kW	4.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.22	1.51
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.994	0.995
WTOL	60 °C	60 °C
Poff	14 W	14 W
PTO	14 W	14 W
PSB	14 W	14 W
PCK	14 W	14 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.86 kW	2.72 kW
Backup Heater	4.00 kW	4.00 kW
Annual energy consumption Qhe	3490 kWh	4405 kWh

Model: ARIANEXT PLUS 80 M LINK R32

Configure model	
Model name	ARIANEXT PLUS 80 M LINK R32
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	8.00 kW	5.80 kW
El input	1.67 kW	1.97 kW
COP	4.80	2.95

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

EN 14511-2

	+7°C/+12°C	+18°C/+23°C
El input	2.26 kW	1.49 kW
Cooling capacity	7	7.00
EER	3.10	4.70

EN 14825

	+7°C/+12°C
Pdesignc	7 kW
SEER	4.64
Pdc Tj = 35°C	7 kW
EER Tj = 35°C	3.1
Pdc Tj = 30°C	5.17 kW
EER Tj = 30°C	4.13
Cdc Tj = 30 °C	0.99
Pdc Tj = 25°C	3.32 kW
EER Tj = 25°C	4.89
Cdc Tj = 25 °C	0.98
Pdc Tj = 20°C	3.19 kW
EER Tj = 20°C	6.85
Cdc Tj = 20 °C	0.97
Poff	14 W
PTO	14 W
PSB	14 W
PCK	0 W
Annual energy consumption Qce	1381 kWh

Warmer Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	35 dB(A)	35 dB(A)
Sound power level outdoor	57 dB(A)	57 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
Pdesignh	4.93 kW	4.48 kW
η_s	242 %	151 %
Prated	4.93 kW	4.48 kW
SCOP	6.14	3.84
Tbiv	2 °C	2 °C
TOL	-20 °C	-20 °C
Pdh Tj = +2°C	4.93 kW	4.48 kW
COP Tj = +2°C	4.05	2.53
Cdh Tj = +2 °C	0.989	0.992
Pdh Tj = +7°C	3.10 kW	2.81 kW
COP Tj = +7°C	5.70	3.08
Cdh Tj = +7 °C	0.975	0.985
Pdh Tj = 12°C	3.28 kW	3.16 kW
COP Tj = 12°C	7.86	5.45

Cdh Tj = +12 °C	0.967	0.977
Pdh Tj = Tbiv	4.93 kW	4.48 kW
COP Tj = Tbiv	4.05	2.53
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.51 kW	4.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.22	1.51
WTOL	60 °C	60 °C
Poff	14 W	14 W
PTO	14 W	14 W
PSB	14 W	14 W
PCK	14 W	14 W
Supplementary Heater: Type of energy input	n/a	n/a
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Backup Heater	4.00 kW	4.00 kW
Annual energy consumption Qhe	1073 kWh	1557 kWh

Colder Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	35 dB(A)	35 dB(A)
Sound power level outdoor	57 dB(A)	57 dB(A)

EN 14825

	Low temperature	**Medium temperature**
Pdesignh	11.78 kW	11.53 kW
η_s	154 %	120 %
Prated	11.78 kW	11.53 kW
SCOP	3.93	3.08
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	7.13 kW	6.98 kW
COP Tj = -7°C	3.47	2.73
Cdh Tj = -7 °C	0.993	0.995
Pdh Tj = +2°C	4.51 kW	4.20 kW
COP Tj = +2°C	5.32	4.07
Cdh Tj = +2 °C	0.984	0.987
Pdh Tj = +7°C	3.06 kW	2.84 kW
COP Tj = +7°C	7.24	5.15
Cdh Tj = +7 °C	0.968	0.975
Pdh Tj = 12°C	3.18 kW	3.24 kW
COP Tj = 12°C	8.02	6.47
Cdh Tj = +12 °C	0.966	0.973
Pdh Tj = Tbiv	7.13 kW	6.98 kW

COP Tj = Tbiv	3.47	2.70
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.51 kW	4.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.22	1.51
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.993	0.995
WTOL	60 °C	60 °C
Poff	14 W	14 W
PTO	14 W	14 W
PSB	14 W	14 W
PCK	14 W	14 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	11.16 kW	10.93 kW
Backup Heater	4.00 kW	4.00 kW
Annual energy consumption Qhe	7398 kWh	9226 kWh

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	35 dB(A)	35 dB(A)
Sound power level outdoor	57 dB(A)	57 dB(A)

EN 14825

	Low temperature	**Medium temperature**
Pdesignh	8.37 kW	7.62 kW
η_s	195 %	140 %
Prated	8.37 kW	7.62 kW
SCOP	4.95	3.57
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	7.40 kW	6.74 kW
COP Tj = -7°C	3.10	2.29
Cdh Tj = -7 °C	0.994	0.995
Pdh Tj = +2°C	4.54 kW	4.22 kW
COP Tj = +2°C	4.80	3.51
Cdh Tj = +2 °C	0.986	0.989
Pdh Tj = +7°C	2.94 kW	2.74 kW
COP Tj = +7°C	6.61	4.36
Cdh Tj = +7 °C	0.969	0.978
Pdh Tj = 12°C	3.16 kW	3.28 kW
COP Tj = 12°C	8.15	6.50
Cdh Tj = +12 °C	0.965	0.973
Pdh Tj = Tbiv	7.40 kW	6.74 kW
COP Tj = Tbiv	3.10	2.29

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.51 kW	4.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.22	1.51
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.994	0.995
WTOL	60 °C	60 °C
Poff	14 W	14 W
PTO	14 W	14 W
PSB	14 W	14 W
PCK	14 W	14 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.86 kW	2.72 kW
Backup Heater	4.00 kW	4.00 kW
Annual energy consumption Qhe	3490 kWh	4405 kWh

Model: ARIANEXT PLUS 80 M-T LINK R32

Configure model	
Model name	ARIANEXT PLUS 80 M-T LINK R32
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	8.00 kW	5.80 kW
El input	1.67 kW	1.97 kW
COP	4.80	2.95

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

EN 14511-2

	+7°C/+12°C	+18°C/+23°C
El input	2.26 kW	1.49 kW
Cooling capacity	7	7.00
EER	3.10	4.70

EN 14825

	+7°C/+12°C
Pdesignc	7 kW
SEER	4.64
Pdc Tj = 35°C	7 kW
EER Tj = 35°C	3.1
Pdc Tj = 30°C	5.17 kW
EER Tj = 30°C	4.13
Cdc Tj = 30 °C	0.99
Pdc Tj = 25°C	3.32 kW
EER Tj = 25°C	4.89
Cdc Tj = 25 °C	0.98
Pdc Tj = 20°C	3.19 kW
EER Tj = 20°C	6.85
Cdc Tj = 20 °C	0.97
Poff	14 W
PTO	14 W
PSB	14 W
PCK	0 W
Annual energy consumption Qce	1381 kWh

Warmer Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	35 dB(A)	35 dB(A)
Sound power level outdoor	57 dB(A)	57 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
Pdesignh	4.93 kW	4.48 kW
η_s	242 %	151 %
Prated	4.93 kW	4.48 kW
SCOP	6.14	3.84
Tbiv	2 °C	2 °C
TOL	-20 °C	-20 °C
Pdh Tj = +2°C	4.93 kW	4.48 kW
COP Tj = +2°C	4.05	2.53
Cdh Tj = +2 °C	0.989	0.992
Pdh Tj = +7°C	3.10 kW	2.81 kW
COP Tj = +7°C	5.70	3.08
Cdh Tj = +7 °C	0.975	0.985
Pdh Tj = 12°C	3.28 kW	3.16 kW
COP Tj = 12°C	7.86	5.45

Cdh Tj = +12 °C	0.967	0.977
Pdh Tj = Tbiv	4.93 kW	4.48 kW
COP Tj = Tbiv	4.05	2.53
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.51 kW	4.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.22	1.51
WTOL	60 °C	60 °C
Poff	14 W	14 W
PTO	14 W	14 W
PSB	14 W	14 W
PCK	14 W	14 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Backup Heater	4.00 kW	4.00 kW
Annual energy consumption Qhe	1073 kWh	1557 kWh

Colder Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	35 dB(A)	35 dB(A)
Sound power level outdoor	57 dB(A)	57 dB(A)

EN 14825

	Low temperature	**Medium temperature**
Pdesignh	11.78 kW	11.53 kW
η_s	154 %	120 %
Prated	11.78 kW	11.53 kW
SCOP	3.93	3.08
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	7.13 kW	6.98 kW
COP Tj = -7°C	3.47	2.73
Cdh Tj = -7 °C	0.993	0.995
Pdh Tj = +2°C	4.51 kW	4.20 kW
COP Tj = +2°C	5.32	4.07
Cdh Tj = +2 °C	0.984	0.987
Pdh Tj = +7°C	3.06 kW	2.84 kW
COP Tj = +7°C	7.24	5.15
Cdh Tj = +7 °C	0.968	0.975
Pdh Tj = 12°C	3.18 kW	3.24 kW
COP Tj = 12°C	8.02	6.47
Cdh Tj = +12 °C	0.966	0.973
Pdh Tj = Tbiv	7.13 kW	6.98 kW

COP Tj = Tbiv	3.47	2.70
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.51 kW	4.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.22	1.51
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.993	0.995
WTOL	60 °C	60 °C
Poff	14 W	14 W
PTO	14 W	14 W
PSB	14 W	14 W
PCK	14 W	14 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	11.16 kW	10.93 kW
Backup Heater	4.00 kW	4.00 kW
Annual energy consumption Qhe	7398 kWh	9226 kWh

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	35 dB(A)	35 dB(A)
Sound power level outdoor	57 dB(A)	57 dB(A)

EN 14825

	Low temperature	**Medium temperature**
Pdesignh	8.37 kW	7.62 kW
η_s	195 %	140 %
Prated	8.37 kW	7.62 kW
SCOP	4.95	3.57
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	7.40 kW	6.74 kW
COP Tj = -7°C	3.10	2.29
Cdh Tj = -7 °C	0.994	0.995
Pdh Tj = +2°C	4.54 kW	4.22 kW
COP Tj = +2°C	4.80	3.51
Cdh Tj = +2 °C	0.986	0.989
Pdh Tj = +7°C	2.94 kW	2.74 kW
COP Tj = +7°C	6.61	4.36
Cdh Tj = +7 °C	0.969	0.978
Pdh Tj = 12°C	3.16 kW	3.28 kW
COP Tj = 12°C	8.15	6.50
Cdh Tj = +12 °C	0.965	0.973
Pdh Tj = Tbiv	7.40 kW	6.74 kW
COP Tj = Tbiv	3.10	2.29

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.51 kW	4.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.22	1.51
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.994	0.995
WTOL	60 °C	60 °C
Poff	14 W	14 W
PTO	14 W	14 W
PSB	14 W	14 W
PCK	14 W	14 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.86 kW	2.72 kW
Backup Heater	4.00 kW	4.00 kW
Annual energy consumption Qhe	3490 kWh	4405 kWh

Model: ARIANEXT LITE 80 M LINK R32

Configure model	
Model name	ARIANEXT LITE 80 M LINK R32
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	8.00 kW	5.80 kW
El input	1.67 kW	1.97 kW
COP	4.80	2.95

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

EN 14511-2

	+7°C/+12°C	+18°C/+23°C
El input	2.26 kW	1.49 kW
Cooling capacity	7	7.00
EER	3.10	4.70

EN 14825

	+7°C/+12°C
Pdesignc	7 kW
SEER	4.64
Pdc Tj = 35°C	7 kW
EER Tj = 35°C	3.1
Pdc Tj = 30°C	5.17 kW
EER Tj = 30°C	4.13
Cdc Tj = 30 °C	0.99
Pdc Tj = 25°C	3.32 kW
EER Tj = 25°C	4.89
Cdc Tj = 25 °C	0.98
Pdc Tj = 20°C	3.19 kW
EER Tj = 20°C	6.85
Cdc Tj = 20 °C	0.97
Poff	14 W
PTO	14 W
PSB	14 W
PCK	0 W
Annual energy consumption Qce	1381 kWh

Warmer Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	15 dB(A)	15 dB(A)
Sound power level outdoor	57 dB(A)	57 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
Pdesignh	4.93 kW	4.48 kW
η_s	242 %	151 %
Prated	4.93 kW	4.48 kW
SCOP	6.14	3.84
Tbiv	2 °C	2 °C
TOL	-20 °C	-20 °C
Pdh Tj = +2°C	4.93 kW	4.48 kW
COP Tj = +2°C	4.05	2.53
Cdh Tj = +2 °C	0.989	0.992
Pdh Tj = +7°C	3.10 kW	2.81 kW
COP Tj = +7°C	5.70	3.08
Cdh Tj = +7 °C	0.975	0.985
Pdh Tj = 12°C	3.28 kW	3.16 kW
COP Tj = 12°C	7.86	5.45

Cdh Tj = +12 °C	0.967	0.977
Pdh Tj = Tbiv	4.93 kW	4.48 kW
COP Tj = Tbiv	4.05	2.53
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.51 kW	4.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.22	1.51
WTOL	60 °C	60 °C
Poff	14 W	14 W
PTO	14 W	14 W
PSB	14 W	14 W
PCK	14 W	14 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Backup Heater	4.00 kW	4.00 kW
Annual energy consumption Qhe	1073 kWh	1557 kWh

Colder Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	15 dB(A)	15 dB(A)
Sound power level outdoor	57 dB(A)	57 dB(A)

EN 14825

	Low temperature	**Medium temperature**
Pdesignh	11.78 kW	11.53 kW
η_s	154 %	120 %
Prated	11.78 kW	11.53 kW
SCOP	3.93	3.08
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	7.13 kW	6.98 kW
COP Tj = -7°C	3.47	2.73
Cdh Tj = -7 °C	0.993	0.995
Pdh Tj = +2°C	4.51 kW	4.20 kW
COP Tj = +2°C	5.32	4.07
Cdh Tj = +2 °C	0.984	0.987
Pdh Tj = +7°C	3.06 kW	2.84 kW
COP Tj = +7°C	7.24	5.15
Cdh Tj = +7 °C	0.968	0.975
Pdh Tj = 12°C	3.18 kW	3.24 kW
COP Tj = 12°C	8.02	6.47
Cdh Tj = +12 °C	0.966	0.973
Pdh Tj = Tbiv	7.13 kW	6.98 kW

COP Tj = Tbiv	3.47	2.70
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.51 kW	4.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.22	1.51
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.993	0.995
WTOL	60 °C	60 °C
Poff	14 W	14 W
PTO	14 W	14 W
PSB	14 W	14 W
PCK	14 W	14 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	11.16 kW	10.93 kW
Backup Heater	4.00 kW	4.00 kW
Annual energy consumption Qhe	7398 kWh	9226 kWh

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	15 dB(A)	15 dB(A)
Sound power level outdoor	57 dB(A)	57 dB(A)

EN 14825

	Low temperature	**Medium temperature**
Pdesignh	8.37 kW	7.62 kW
η_s	195 %	140 %
Prated	8.37 kW	7.62 kW
SCOP	4.95	3.57
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	7.40 kW	6.74 kW
COP Tj = -7°C	3.10	2.29
Cdh Tj = -7 °C	0.994	0.995
Pdh Tj = +2°C	4.54 kW	4.22 kW
COP Tj = +2°C	4.80	3.51
Cdh Tj = +2 °C	0.986	0.989
Pdh Tj = +7°C	2.94 kW	2.74 kW
COP Tj = +7°C	6.61	4.36
Cdh Tj = +7 °C	0.969	0.978
Pdh Tj = 12°C	3.16 kW	3.28 kW
COP Tj = 12°C	8.15	6.50
Cdh Tj = +12 °C	0.965	0.973
Pdh Tj = Tbiv	7.40 kW	6.74 kW
COP Tj = Tbiv	3.10	2.29

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.51 kW	4.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.22	1.51
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.994	0.995
WTOL	60 °C	60 °C
Poff	14 W	14 W
PTO	14 W	14 W
PSB	14 W	14 W
PCK	14 W	14 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.86 kW	2.72 kW
Backup Heater	4.00 kW	4.00 kW
Annual energy consumption Qhe	3490 kWh	4405 kWh

Model: ARIANEXT LITE 80 M-T LINK R32

Configure model	
Model name	ARIANEXT LITE 80 M-T LINK R32
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	8.00 kW	5.80 kW
El input	1.67 kW	1.97 kW
COP	4.80	2.95

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

EN 14511-2

	+7°C/+12°C	+18°C/+23°C
El input	2.26 kW	1.49 kW
Cooling capacity	7	7.00
EER	3.10	4.70

EN 14825

	+7°C/+12°C
Pdesignc	7 kW
SEER	4.64
Pdc Tj = 35°C	7 kW
EER Tj = 35°C	3.1
Pdc Tj = 30°C	5.17 kW
EER Tj = 30°C	4.13
Cdc Tj = 30 °C	0.99
Pdc Tj = 25°C	3.32 kW
EER Tj = 25°C	4.89
Cdc Tj = 25 °C	0.98
Pdc Tj = 20°C	3.19 kW
EER Tj = 20°C	6.85
Cdc Tj = 20 °C	0.97
Poff	14 W
PTO	14 W
PSB	14 W
PCK	0 W
Annual energy consumption Qce	1381 kWh

Warmer Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	15 dB(A)	15 dB(A)
Sound power level outdoor	57 dB(A)	57 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
Pdesignh	4.93 kW	4.48 kW
η_s	242 %	151 %
Prated	4.93 kW	4.48 kW
SCOP	6.14	3.84
Tbiv	2 °C	2 °C
TOL	-20 °C	-20 °C
Pdh Tj = +2°C	4.93 kW	4.48 kW
COP Tj = +2°C	4.05	2.53
Cdh Tj = +2 °C	0.989	0.992
Pdh Tj = +7°C	3.10 kW	2.81 kW
COP Tj = +7°C	5.70	3.08
Cdh Tj = +7 °C	0.975	0.985
Pdh Tj = 12°C	3.28 kW	3.16 kW
COP Tj = 12°C	7.86	5.45

Cdh Tj = +12 °C	0.967	0.977
Pdh Tj = Tbiv	4.93 kW	4.48 kW
COP Tj = Tbiv	4.05	2.53
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.51 kW	4.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.22	1.51
WTOL	60 °C	60 °C
Poff	14 W	14 W
PTO	14 W	14 W
PSB	14 W	14 W
PCK	14 W	14 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Backup Heater	4.00 kW	4.00 kW
Annual energy consumption Qhe	1073 kWh	1557 kWh

Colder Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	15 dB(A)	15 dB(A)
Sound power level outdoor	57 dB(A)	57 dB(A)

EN 14825

	Low temperature	**Medium temperature**
Pdesignh	11.78 kW	11.53 kW
η_s	154 %	120 %
Prated	11.78 kW	11.53 kW
SCOP	3.93	3.08
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	7.13 kW	6.98 kW
COP Tj = -7°C	3.47	2.73
Cdh Tj = -7 °C	0.993	0.995
Pdh Tj = +2°C	4.51 kW	4.20 kW
COP Tj = +2°C	5.32	4.07
Cdh Tj = +2 °C	0.984	0.987
Pdh Tj = +7°C	3.06 kW	2.84 kW
COP Tj = +7°C	7.24	5.15
Cdh Tj = +7 °C	0.968	0.975
Pdh Tj = 12°C	3.18 kW	3.24 kW
COP Tj = 12°C	8.02	6.47
Cdh Tj = +12 °C	0.966	0.973
Pdh Tj = Tbiv	7.13 kW	6.98 kW

COP Tj = Tbiv	3.47	2.70
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.51 kW	4.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.22	1.51
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.993	0.995
WTOL	60 °C	60 °C
Poff	14 W	14 W
PTO	14 W	14 W
PSB	14 W	14 W
PCK	14 W	14 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	11.16 kW	10.93 kW
Backup Heater	4.00 kW	4.00 kW
Annual energy consumption Qhe	7398 kWh	9226 kWh

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	15 dB(A)	15 dB(A)
Sound power level outdoor	57 dB(A)	57 dB(A)

EN 14825

	Low temperature	**Medium temperature**
Pdesignh	8.37 kW	7.62 kW
η_s	195 %	140 %
Prated	8.37 kW	7.62 kW
SCOP	4.95	3.57
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	7.40 kW	6.74 kW
COP Tj = -7°C	3.10	2.29
Cdh Tj = -7 °C	0.994	0.995
Pdh Tj = +2°C	4.54 kW	4.22 kW
COP Tj = +2°C	4.80	3.51
Cdh Tj = +2 °C	0.986	0.989
Pdh Tj = +7°C	2.94 kW	2.74 kW
COP Tj = +7°C	6.61	4.36
Cdh Tj = +7 °C	0.969	0.978
Pdh Tj = 12°C	3.16 kW	3.28 kW
COP Tj = 12°C	8.15	6.50
Cdh Tj = +12 °C	0.965	0.973
Pdh Tj = Tbiv	7.40 kW	6.74 kW
COP Tj = Tbiv	3.10	2.29

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.51 kW	4.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.22	1.51
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.994	0.995
WTOL	60 °C	60 °C
Poff	14 W	14 W
PTO	14 W	14 W
PSB	14 W	14 W
PCK	14 W	14 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.86 kW	2.72 kW
Backup Heater	4.00 kW	4.00 kW
Annual energy consumption Qhe	3490 kWh	4405 kWh

Model: AEROTOP MONO 08.2 M-RX

Configure model	
Model name	AEROTOP MONO 08.2 M-RX
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	8.00 kW	5.80 kW
El input	1.67 kW	1.97 kW
COP	4.80	2.95

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

EN 14511-2

	+7°C/+12°C	+18°C/+23°C
El input	2.26 kW	1.49 kW
Cooling capacity	7	7.00
EER	3.10	4.70

EN 14825

	+7°C/+12°C
Pdesignc	7 kW
SEER	4.64
Pdc Tj = 35°C	7 kW
EER Tj = 35°C	3.1
Pdc Tj = 30°C	5.17 kW
EER Tj = 30°C	4.13
Cdc Tj = 30 °C	0.99
Pdc Tj = 25°C	3.32 kW
EER Tj = 25°C	4.89
Cdc Tj = 25 °C	0.98
Pdc Tj = 20°C	3.19 kW
EER Tj = 20°C	6.85
Cdc Tj = 20 °C	0.97
Poff	14 W
PTO	14 W
PSB	14 W
PCK	0 W
Annual energy consumption Qce	1381 kWh

Warmer Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	35 dB(A)	35 dB(A)
Sound power level outdoor	57 dB(A)	57 dB(A)

EN 14825

	Low temperature	Medium temperature
Pdesignh	4.93 kW	4.48 kW
η_s	242 %	151 %
Prated	4.93 kW	4.48 kW
SCOP	6.14	3.84
Tbiv	2 °C	2 °C
TOL	-20 °C	-20 °C
Pdh Tj = +2°C	4.93 kW	4.48 kW
COP Tj = +2°C	4.05	2.53
Cdh Tj = +2 °C	0.989	0.992
Pdh Tj = +7°C	3.10 kW	2.81 kW
COP Tj = +7°C	5.70	3.08
Cdh Tj = +7 °C	0.975	0.985
Pdh Tj = 12°C	3.28 kW	3.16 kW
COP Tj = 12°C	7.86	5.45

Cdh Tj = +12 °C	0.967	0.977
Pdh Tj = Tbiv	4.93 kW	4.48 kW
COP Tj = Tbiv	4.05	2.53
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.51 kW	4.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.22	1.51
WTOL	60 °C	60 °C
Poff	14 W	14 W
PTO	14 W	14 W
PSB	14 W	14 W
PCK	14 W	14 W
Supplementary Heater: Type of energy input	n/a	n/a
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Backup Heater	4.00 kW	4.00 kW
Annual energy consumption Qhe	1073 kWh	1557 kWh

Colder Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	35 dB(A)	35 dB(A)
Sound power level outdoor	57 dB(A)	57 dB(A)

EN 14825

	Low temperature	**Medium temperature**
Pdesignh	11.78 kW	11.53 kW
η_s	154 %	120 %
Prated	11.78 kW	11.53 kW
SCOP	3.93	3.08
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	7.13 kW	6.98 kW
COP Tj = -7°C	3.47	2.73
Cdh Tj = -7 °C	0.993	0.995
Pdh Tj = +2°C	4.51 kW	4.20 kW
COP Tj = +2°C	5.32	4.07
Cdh Tj = +2 °C	0.984	0.987
Pdh Tj = +7°C	3.06 kW	2.84 kW
COP Tj = +7°C	7.24	5.15
Cdh Tj = +7 °C	0.968	0.975
Pdh Tj = 12°C	3.18 kW	3.24 kW
COP Tj = 12°C	8.02	6.47
Cdh Tj = +12 °C	0.966	0.973
Pdh Tj = Tbiv	7.13 kW	6.98 kW

COP Tj = Tbiv	3.47	2.70
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.51 kW	4.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.22	1.51
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.993	0.995
WTOL	60 °C	60 °C
Poff	14 W	14 W
PTO	14 W	14 W
PSB	14 W	14 W
PCK	14 W	14 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	11.16 kW	10.93 kW
Backup Heater	4.00 kW	4.00 kW
Annual energy consumption Qhe	7398 kWh	9226 kWh

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	35 dB(A)	35 dB(A)
Sound power level outdoor	57 dB(A)	57 dB(A)

EN 14825

	Low temperature	**Medium temperature**
Pdesignh	8.37 kW	7.62 kW
η_s	195 %	140 %
Prated	8.37 kW	7.62 kW
SCOP	4.95	3.57
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	7.40 kW	6.74 kW
COP Tj = -7°C	3.10	2.29
Cdh Tj = -7 °C	0.994	0.995
Pdh Tj = +2°C	4.54 kW	4.22 kW
COP Tj = +2°C	4.80	3.51
Cdh Tj = +2 °C	0.986	0.989
Pdh Tj = +7°C	2.94 kW	2.74 kW
COP Tj = +7°C	6.61	4.36
Cdh Tj = +7 °C	0.969	0.978
Pdh Tj = 12°C	3.16 kW	3.28 kW
COP Tj = 12°C	8.15	6.50
Cdh Tj = +12 °C	0.965	0.973
Pdh Tj = Tbiv	7.40 kW	6.74 kW
COP Tj = Tbiv	3.10	2.29

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.51 kW	4.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.22	1.51
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.994	0.995
WTOL	60 °C	60 °C
Poff	14 W	14 W
PTO	14 W	14 W
PSB	14 W	14 W
PCK	14 W	14 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.86 kW	2.72 kW
Backup Heater	4.00 kW	4.00 kW
Annual energy consumption Qhe	3490 kWh	4405 kWh

Model: AEROTOP MONO 08.2 M-R

Configure model	
Model name	AEROTOP MONO 08.2 M-R
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	8.00 kW	5.80 kW
El input	1.67 kW	1.97 kW
COP	4.80	2.95

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

EN 14511-2

	+7°C/+12°C	+18°C/+23°C
El input	2.26 kW	1.49 kW
Cooling capacity	7	7.00
EER	3.10	4.70

EN 14825

	+7°C/+12°C
Pdesignc	7 kW
SEER	4.64
Pdc Tj = 35°C	7 kW
EER Tj = 35°C	3.1
Pdc Tj = 30°C	5.17 kW
EER Tj = 30°C	4.13
Cdc Tj = 30 °C	0.99
Pdc Tj = 25°C	3.32 kW
EER Tj = 25°C	4.89
Cdc Tj = 25 °C	0.98
Pdc Tj = 20°C	3.19 kW
EER Tj = 20°C	6.85
Cdc Tj = 20 °C	0.97
Poff	14 W
PTO	14 W
PSB	14 W
PCK	0 W
Annual energy consumption Qce	1381 kWh

Warmer Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	35 dB(A)	35 dB(A)
Sound power level outdoor	57 dB(A)	57 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
Pdesignh	4.93 kW	4.48 kW
η_s	242 %	151 %
Prated	4.93 kW	4.48 kW
SCOP	6.14	3.84
Tbiv	2 °C	2 °C
TOL	-20 °C	-20 °C
Pdh Tj = +2°C	4.93 kW	4.48 kW
COP Tj = +2°C	4.05	2.53
Cdh Tj = +2 °C	0.989	0.992
Pdh Tj = +7°C	3.10 kW	2.81 kW
COP Tj = +7°C	5.70	3.08
Cdh Tj = +7 °C	0.975	0.985
Pdh Tj = 12°C	3.28 kW	3.16 kW
COP Tj = 12°C	7.86	5.45

Cdh Tj = +12 °C	0.967	0.977
Pdh Tj = Tbiv	4.93 kW	4.48 kW
COP Tj = Tbiv	4.05	2.53
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.51 kW	4.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.22	1.51
WTOL	60 °C	60 °C
Poff	14 W	14 W
PTO	14 W	14 W
PSB	14 W	14 W
PCK	14 W	14 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Backup Heater	4.00 kW	4.00 kW
Annual energy consumption Qhe	1073 kWh	1557 kWh

Colder Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	35 dB(A)	35 dB(A)
Sound power level outdoor	57 dB(A)	57 dB(A)

EN 14825

	Low temperature	**Medium temperature**
Pdesignh	11.78 kW	11.53 kW
η_s	154 %	120 %
Prated	11.78 kW	11.53 kW
SCOP	3.93	3.08
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	7.13 kW	6.98 kW
COP Tj = -7°C	3.47	2.73
Cdh Tj = -7 °C	0.993	0.995
Pdh Tj = +2°C	4.51 kW	4.20 kW
COP Tj = +2°C	5.32	4.07
Cdh Tj = +2 °C	0.984	0.987
Pdh Tj = +7°C	3.06 kW	2.84 kW
COP Tj = +7°C	7.24	5.15
Cdh Tj = +7 °C	0.968	0.975
Pdh Tj = 12°C	3.18 kW	3.24 kW
COP Tj = 12°C	8.02	6.47
Cdh Tj = +12 °C	0.966	0.973
Pdh Tj = Tbiv	7.13 kW	6.98 kW

COP Tj = Tbiv	3.47	2.70
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.51 kW	4.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.22	1.51
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.993	0.995
WTOL	60 °C	60 °C
Poff	14 W	14 W
PTO	14 W	14 W
PSB	14 W	14 W
PCK	14 W	14 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	11.16 kW	10.93 kW
Backup Heater	4.00 kW	4.00 kW
Annual energy consumption Qhe	7398 kWh	9226 kWh

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	35 dB(A)	35 dB(A)
Sound power level outdoor	57 dB(A)	57 dB(A)

EN 14825

	Low temperature	**Medium temperature**
Pdesignh	8.37 kW	7.62 kW
η_s	195 %	140 %
Prated	8.37 kW	7.62 kW
SCOP	4.95	3.57
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	7.40 kW	6.74 kW
COP Tj = -7°C	3.10	2.29
Cdh Tj = -7 °C	0.994	0.995
Pdh Tj = +2°C	4.54 kW	4.22 kW
COP Tj = +2°C	4.80	3.51
Cdh Tj = +2 °C	0.986	0.989
Pdh Tj = +7°C	2.94 kW	2.74 kW
COP Tj = +7°C	6.61	4.36
Cdh Tj = +7 °C	0.969	0.978
Pdh Tj = 12°C	3.16 kW	3.28 kW
COP Tj = 12°C	8.15	6.50
Cdh Tj = +12 °C	0.965	0.973
Pdh Tj = Tbiv	7.40 kW	6.74 kW
COP Tj = Tbiv	3.10	2.29

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.51 kW	4.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.22	1.51
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.994	0.995
WTOL	60 °C	60 °C
Poff	14 W	14 W
PTO	14 W	14 W
PSB	14 W	14 W
PCK	14 W	14 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.86 kW	2.72 kW
Backup Heater	4.00 kW	4.00 kW
Annual energy consumption Qhe	3490 kWh	4405 kWh

Model: AEROTOP MONO 08.2 M-RXL

Configure model	
Model name	AEROTOP MONO 08.2 M-RXL
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	8.00 kW	5.80 kW
El input	1.67 kW	1.97 kW
COP	4.80	2.95

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

EN 14511-2

	+7°C/+12°C	+18°C/+23°C
El input	2.26 kW	1.49 kW
Cooling capacity	7	7.00
EER	3.10	4.70

EN 14825

	+7°C/+12°C
Pdesignc	7 kW
SEER	4.64
Pdc Tj = 35°C	7 kW
EER Tj = 35°C	3.1
Pdc Tj = 30°C	5.17 kW
EER Tj = 30°C	4.13
Cdc Tj = 30 °C	0.99
Pdc Tj = 25°C	3.32 kW
EER Tj = 25°C	4.89
Cdc Tj = 25 °C	0.98
Pdc Tj = 20°C	3.19 kW
EER Tj = 20°C	6.85
Cdc Tj = 20 °C	0.97
Poff	14 W
PTO	14 W
PSB	14 W
PCK	0 W
Annual energy consumption Qce	1381 kWh

Warmer Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	15 dB(A)	15 dB(A)
Sound power level outdoor	57 dB(A)	57 dB(A)

EN 14825

	Low temperature	Medium temperature
Pdesignh	4.93 kW	4.48 kW
η_s	242 %	151 %
Prated	4.93 kW	4.48 kW
SCOP	6.14	3.84
Tbiv	2 °C	2 °C
TOL	-20 °C	-20 °C
Pdh Tj = +2°C	4.93 kW	4.48 kW
COP Tj = +2°C	4.05	2.53
Cdh Tj = +2 °C	0.989	0.992
Pdh Tj = +7°C	3.10 kW	2.81 kW
COP Tj = +7°C	5.70	3.08
Cdh Tj = +7 °C	0.975	0.985
Pdh Tj = 12°C	3.28 kW	3.16 kW
COP Tj = 12°C	7.86	5.45

Cdh Tj = +12 °C	0.967	0.977
Pdh Tj = Tbiv	4.93 kW	4.48 kW
COP Tj = Tbiv	4.05	2.53
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.51 kW	4.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.22	1.51
WTOL	60 °C	60 °C
Poff	14 W	14 W
PTO	14 W	14 W
PSB	14 W	14 W
PCK	14 W	14 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Backup Heater	4.00 kW	4.00 kW
Annual energy consumption Qhe	1073 kWh	1557 kWh

Colder Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	15 dB(A)	15 dB(A)
Sound power level outdoor	57 dB(A)	57 dB(A)

EN 14825

	Low temperature	**Medium temperature**
Pdesignh	11.78 kW	11.53 kW
η_s	154 %	120 %
Prated	11.78 kW	11.53 kW
SCOP	3.93	3.08
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	7.13 kW	6.98 kW
COP Tj = -7°C	3.47	2.73
Cdh Tj = -7 °C	0.993	0.995
Pdh Tj = +2°C	4.51 kW	4.20 kW
COP Tj = +2°C	5.32	4.07
Cdh Tj = +2 °C	0.984	0.987
Pdh Tj = +7°C	3.06 kW	2.84 kW
COP Tj = +7°C	7.24	5.15
Cdh Tj = +7 °C	0.968	0.975
Pdh Tj = 12°C	3.18 kW	3.24 kW
COP Tj = 12°C	8.02	6.47
Cdh Tj = +12 °C	0.966	0.973
Pdh Tj = Tbiv	7.13 kW	6.98 kW

COP Tj = Tbiv	3.47	2.70
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.51 kW	4.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.22	1.51
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.993	0.995
WTOL	60 °C	60 °C
Poff	14 W	14 W
PTO	14 W	14 W
PSB	14 W	14 W
PCK	14 W	14 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	11.16 kW	10.93 kW
Backup Heater	4.00 kW	4.00 kW
Annual energy consumption Qhe	7398 kWh	9226 kWh

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	15 dB(A)	15 dB(A)
Sound power level outdoor	57 dB(A)	57 dB(A)

EN 14825

	Low temperature	**Medium temperature**
Pdesignh	8.37 kW	7.62 kW
η_s	195 %	140 %
Prated	8.37 kW	7.62 kW
SCOP	4.95	3.57
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	7.40 kW	6.74 kW
COP Tj = -7°C	3.10	2.29
Cdh Tj = -7 °C	0.994	0.995
Pdh Tj = +2°C	4.54 kW	4.22 kW
COP Tj = +2°C	4.80	3.51
Cdh Tj = +2 °C	0.986	0.989
Pdh Tj = +7°C	2.94 kW	2.74 kW
COP Tj = +7°C	6.61	4.36
Cdh Tj = +7 °C	0.969	0.978
Pdh Tj = 12°C	3.16 kW	3.28 kW
COP Tj = 12°C	8.15	6.50
Cdh Tj = +12 °C	0.965	0.973
Pdh Tj = Tbiv	7.40 kW	6.74 kW
COP Tj = Tbiv	3.10	2.29

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.51 kW	4.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.22	1.51
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.994	0.995
WTOL	60 °C	60 °C
Poff	14 W	14 W
PTO	14 W	14 W
PSB	14 W	14 W
PCK	14 W	14 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.86 kW	2.72 kW
Backup Heater	4.00 kW	4.00 kW
Annual energy consumption Qhe	3490 kWh	4405 kWh

Model: AEROTOP MONO 08.2 M-RL

Configure model	
Model name	AEROTOP MONO 08.2 M-RL
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	8.00 kW	5.80 kW
El input	1.67 kW	1.97 kW
COP	4.80	2.95

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

EN 14511-2

	+7°C/+12°C	+18°C/+23°C
El input	2.26 kW	1.49 kW
Cooling capacity	7	7.00
EER	3.10	4.70

EN 14825

	+7°C/+12°C
Pdesignc	7 kW
SEER	4.64
Pdc Tj = 35°C	7 kW
EER Tj = 35°C	3.1
Pdc Tj = 30°C	5.17 kW
EER Tj = 30°C	4.13
Cdc Tj = 30 °C	0.99
Pdc Tj = 25°C	3.32 kW
EER Tj = 25°C	4.89
Cdc Tj = 25 °C	0.98
Pdc Tj = 20°C	3.19 kW
EER Tj = 20°C	6.85
Cdc Tj = 20 °C	0.97
Poff	14 W
PTO	14 W
PSB	14 W
PCK	0 W
Annual energy consumption Qce	1381 kWh

Warmer Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	15 dB(A)	15 dB(A)
Sound power level outdoor	57 dB(A)	57 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
Pdesignh	4.93 kW	4.48 kW
η_s	242 %	151 %
Prated	4.93 kW	4.48 kW
SCOP	6.14	3.84
Tbiv	2 °C	2 °C
TOL	-20 °C	-20 °C
Pdh Tj = +2°C	4.93 kW	4.48 kW
COP Tj = +2°C	4.05	2.53
Cdh Tj = +2 °C	0.989	0.992
Pdh Tj = +7°C	3.10 kW	2.81 kW
COP Tj = +7°C	5.70	3.08
Cdh Tj = +7 °C	0.975	0.985
Pdh Tj = 12°C	3.28 kW	3.16 kW
COP Tj = 12°C	7.86	5.45

Cdh Tj = +12 °C	0.967	0.977
Pdh Tj = Tbiv	4.93 kW	4.48 kW
COP Tj = Tbiv	4.05	2.53
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.51 kW	4.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.22	1.51
WTOL	60 °C	60 °C
Poff	14 W	14 W
PTO	14 W	14 W
PSB	14 W	14 W
PCK	14 W	14 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Backup Heater	4.00 kW	4.00 kW
Annual energy consumption Qhe	1073 kWh	1557 kWh

Colder Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	15 dB(A)	15 dB(A)
Sound power level outdoor	57 dB(A)	57 dB(A)

EN 14825

	Low temperature	**Medium temperature**
Pdesignh	11.78 kW	11.53 kW
η_s	154 %	120 %
Prated	11.78 kW	11.53 kW
SCOP	3.93	3.08
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	7.13 kW	6.98 kW
COP Tj = -7°C	3.47	2.73
Cdh Tj = -7 °C	0.993	0.995
Pdh Tj = +2°C	4.51 kW	4.20 kW
COP Tj = +2°C	5.32	4.07
Cdh Tj = +2 °C	0.984	0.987
Pdh Tj = +7°C	3.06 kW	2.84 kW
COP Tj = +7°C	7.24	5.15
Cdh Tj = +7 °C	0.968	0.975
Pdh Tj = 12°C	3.18 kW	3.24 kW
COP Tj = 12°C	8.02	6.47
Cdh Tj = +12 °C	0.966	0.973
Pdh Tj = Tbiv	7.13 kW	6.98 kW

COP Tj = Tbiv	3.47	2.70
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.51 kW	4.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.22	1.51
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.993	0.995
WTOL	60 °C	60 °C
Poff	14 W	14 W
PTO	14 W	14 W
PSB	14 W	14 W
PCK	14 W	14 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	11.16 kW	10.93 kW
Backup Heater	4.00 kW	4.00 kW
Annual energy consumption Qhe	7398 kWh	9226 kWh

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	15 dB(A)	15 dB(A)
Sound power level outdoor	57 dB(A)	57 dB(A)

EN 14825

	Low temperature	**Medium temperature**
Pdesignh	8.37 kW	7.62 kW
η_s	195 %	140 %
Prated	8.37 kW	7.62 kW
SCOP	4.95	3.57
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	7.40 kW	6.74 kW
COP Tj = -7°C	3.10	2.29
Cdh Tj = -7 °C	0.994	0.995
Pdh Tj = +2°C	4.54 kW	4.22 kW
COP Tj = +2°C	4.80	3.51
Cdh Tj = +2 °C	0.986	0.989
Pdh Tj = +7°C	2.94 kW	2.74 kW
COP Tj = +7°C	6.61	4.36
Cdh Tj = +7 °C	0.969	0.978
Pdh Tj = 12°C	3.16 kW	3.28 kW
COP Tj = 12°C	8.15	6.50
Cdh Tj = +12 °C	0.965	0.973
Pdh Tj = Tbiv	7.40 kW	6.74 kW
COP Tj = Tbiv	3.10	2.29

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.51 kW	4.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.22	1.51
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.994	0.995
WTOL	60 °C	60 °C
Poff	14 W	14 W
PTO	14 W	14 W
PSB	14 W	14 W
PCK	14 W	14 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.86 kW	2.72 kW
Backup Heater	4.00 kW	4.00 kW
Annual energy consumption Qhe	3490 kWh	4405 kWh

Model: ENERGION M PLUS 80

Configure model	
Model name	ENERGION M PLUS 80
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	8.00 kW	5.80 kW
El input	1.67 kW	1.97 kW
COP	4.80	2.95

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

EN 14511-2

	+7°C/+12°C	+18°C/+23°C
El input	2.26 kW	1.49 kW
Cooling capacity	7	7.00
EER	3.10	4.70

EN 14825

	+7°C/+12°C
Pdesignc	7 kW
SEER	4.64
Pdc Tj = 35°C	7 kW
EER Tj = 35°C	3.1
Pdc Tj = 30°C	5.17 kW
EER Tj = 30°C	4.13
Cdc Tj = 30 °C	0.99
Pdc Tj = 25°C	3.32 kW
EER Tj = 25°C	4.89
Cdc Tj = 25 °C	0.98
Pdc Tj = 20°C	3.19 kW
EER Tj = 20°C	6.85
Cdc Tj = 20 °C	0.97
Poff	14 W
PTO	14 W
PSB	14 W
PCK	0 W
Annual energy consumption Qce	1381 kWh

Warmer Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	35 dB(A)	35 dB(A)
Sound power level outdoor	57 dB(A)	57 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
Pdesignh	4.93 kW	4.48 kW
η_s	242 %	151 %
Prated	4.93 kW	4.48 kW
SCOP	6.14	3.84
Tbiv	2 °C	2 °C
TOL	-20 °C	-20 °C
Pdh Tj = +2°C	4.93 kW	4.48 kW
COP Tj = +2°C	4.05	2.53
Cdh Tj = +2 °C	0.989	0.992
Pdh Tj = +7°C	3.10 kW	2.81 kW
COP Tj = +7°C	5.70	3.08
Cdh Tj = +7 °C	0.975	0.985
Pdh Tj = 12°C	3.28 kW	3.16 kW
COP Tj = 12°C	7.86	5.45

Cdh Tj = +12 °C	0.967	0.977
Pdh Tj = Tbiv	4.93 kW	4.48 kW
COP Tj = Tbiv	4.05	2.53
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.51 kW	4.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.22	1.51
WTOL	60 °C	60 °C
Poff	14 W	14 W
PTO	14 W	14 W
PSB	14 W	14 W
PCK	14 W	14 W
Supplementary Heater: Type of energy input	n/a	n/a
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Backup Heater	4.00 kW	4.00 kW
Annual energy consumption Qhe	1073 kWh	1557 kWh

Colder Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	35 dB(A)	35 dB(A)
Sound power level outdoor	57 dB(A)	57 dB(A)

EN 14825

	Low temperature	**Medium temperature**
Pdesignh	11.78 kW	11.53 kW
η_s	154 %	120 %
Prated	11.78 kW	11.53 kW
SCOP	3.93	3.08
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	7.13 kW	6.98 kW
COP Tj = -7°C	3.47	2.73
Cdh Tj = -7 °C	0.993	0.995
Pdh Tj = +2°C	4.51 kW	4.20 kW
COP Tj = +2°C	5.32	4.07
Cdh Tj = +2 °C	0.984	0.987
Pdh Tj = +7°C	3.06 kW	2.84 kW
COP Tj = +7°C	7.24	5.15
Cdh Tj = +7 °C	0.968	0.975
Pdh Tj = 12°C	3.18 kW	3.24 kW
COP Tj = 12°C	8.02	6.47
Cdh Tj = +12 °C	0.966	0.973
Pdh Tj = Tbiv	7.13 kW	6.98 kW

COP Tj = Tbiv	3.47	2.70
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.51 kW	4.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.22	1.51
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.993	0.995
WTOL	60 °C	60 °C
Poff	14 W	14 W
PTO	14 W	14 W
PSB	14 W	14 W
PCK	14 W	14 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	11.16 kW	10.93 kW
Backup Heater	4.00 kW	4.00 kW
Annual energy consumption Qhe	7398 kWh	9226 kWh

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	35 dB(A)	35 dB(A)
Sound power level outdoor	57 dB(A)	57 dB(A)

EN 14825

	Low temperature	**Medium temperature**
Pdesignh	8.37 kW	7.62 kW
η_s	195 %	140 %
Prated	8.37 kW	7.62 kW
SCOP	4.95	3.57
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	7.40 kW	6.74 kW
COP Tj = -7°C	3.10	2.29
Cdh Tj = -7 °C	0.994	0.995
Pdh Tj = +2°C	4.54 kW	4.22 kW
COP Tj = +2°C	4.80	3.51
Cdh Tj = +2 °C	0.986	0.989
Pdh Tj = +7°C	2.94 kW	2.74 kW
COP Tj = +7°C	6.61	4.36
Cdh Tj = +7 °C	0.969	0.978
Pdh Tj = 12°C	3.16 kW	3.28 kW
COP Tj = 12°C	8.15	6.50
Cdh Tj = +12 °C	0.965	0.973
Pdh Tj = Tbiv	7.40 kW	6.74 kW
COP Tj = Tbiv	3.10	2.29

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.51 kW	4.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.22	1.51
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.994	0.995
WTOL	60 °C	60 °C
Poff	14 W	14 W
PTO	14 W	14 W
PSB	14 W	14 W
PCK	14 W	14 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.86 kW	2.72 kW
Backup Heater	4.00 kW	4.00 kW
Annual energy consumption Qhe	3490 kWh	4405 kWh

Model: ENERGION M PLUS 80T

Configure model	
Model name	ENERGION M PLUS 80T
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	8.00 kW	5.80 kW
El input	1.67 kW	1.97 kW
COP	4.80	2.95

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

EN 14511-2

	+7°C/+12°C	+18°C/+23°C
El input	2.26 kW	1.49 kW
Cooling capacity	7	7.00
EER	3.10	4.70

EN 14825

	+7°C/+12°C
Pdesignc	7 kW
SEER	4.64
Pdc Tj = 35°C	7 kW
EER Tj = 35°C	3.1
Pdc Tj = 30°C	5.17 kW
EER Tj = 30°C	4.13
Cdc Tj = 30 °C	0.99
Pdc Tj = 25°C	3.32 kW
EER Tj = 25°C	4.89
Cdc Tj = 25 °C	0.98
Pdc Tj = 20°C	3.19 kW
EER Tj = 20°C	6.85
Cdc Tj = 20 °C	0.97
Poff	14 W
PTO	14 W
PSB	14 W
PCK	0 W
Annual energy consumption Qce	1381 kWh

Warmer Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	35 dB(A)	35 dB(A)
Sound power level outdoor	57 dB(A)	57 dB(A)

EN 14825

	Low temperature	Medium temperature
Pdesignh	4.93 kW	4.48 kW
η_s	242 %	151 %
Prated	4.93 kW	4.48 kW
SCOP	6.14	3.84
Tbiv	2 °C	2 °C
TOL	-20 °C	-20 °C
Pdh Tj = +2°C	4.93 kW	4.48 kW
COP Tj = +2°C	4.05	2.53
Cdh Tj = +2 °C	0.989	0.992
Pdh Tj = +7°C	3.10 kW	2.81 kW
COP Tj = +7°C	5.70	3.08
Cdh Tj = +7 °C	0.975	0.985
Pdh Tj = 12°C	3.28 kW	3.16 kW
COP Tj = 12°C	7.86	5.45

Cdh Tj = +12 °C	0.967	0.977
Pdh Tj = Tbiv	4.93 kW	4.48 kW
COP Tj = Tbiv	4.05	2.53
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.51 kW	4.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.22	1.51
WTOL	60 °C	60 °C
Poff	14 W	14 W
PTO	14 W	14 W
PSB	14 W	14 W
PCK	14 W	14 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Backup Heater	4.00 kW	4.00 kW
Annual energy consumption Qhe	1073 kWh	1557 kWh

Colder Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	35 dB(A)	35 dB(A)
Sound power level outdoor	57 dB(A)	57 dB(A)

EN 14825

	Low temperature	**Medium temperature**
Pdesignh	11.78 kW	11.53 kW
η_s	154 %	120 %
Prated	11.78 kW	11.53 kW
SCOP	3.93	3.08
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	7.13 kW	6.98 kW
COP Tj = -7°C	3.47	2.73
Cdh Tj = -7 °C	0.993	0.995
Pdh Tj = +2°C	4.51 kW	4.20 kW
COP Tj = +2°C	5.32	4.07
Cdh Tj = +2 °C	0.984	0.987
Pdh Tj = +7°C	3.06 kW	2.84 kW
COP Tj = +7°C	7.24	5.15
Cdh Tj = +7 °C	0.968	0.975
Pdh Tj = 12°C	3.18 kW	3.24 kW
COP Tj = 12°C	8.02	6.47
Cdh Tj = +12 °C	0.966	0.973
Pdh Tj = Tbiv	7.13 kW	6.98 kW

COP Tj = Tbiv	3.47	2.70
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.51 kW	4.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.22	1.51
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.993	0.995
WTOL	60 °C	60 °C
Poff	14 W	14 W
PTO	14 W	14 W
PSB	14 W	14 W
PCK	14 W	14 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	11.16 kW	10.93 kW
Backup Heater	4.00 kW	4.00 kW
Annual energy consumption Qhe	7398 kWh	9226 kWh

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	35 dB(A)	35 dB(A)
Sound power level outdoor	57 dB(A)	57 dB(A)

EN 14825

	Low temperature	**Medium temperature**
Pdesignh	8.37 kW	7.62 kW
η_s	195 %	140 %
Prated	8.37 kW	7.62 kW
SCOP	4.95	3.57
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	7.40 kW	6.74 kW
COP Tj = -7°C	3.10	2.29
Cdh Tj = -7 °C	0.994	0.995
Pdh Tj = +2°C	4.54 kW	4.22 kW
COP Tj = +2°C	4.80	3.51
Cdh Tj = +2 °C	0.986	0.989
Pdh Tj = +7°C	2.94 kW	2.74 kW
COP Tj = +7°C	6.61	4.36
Cdh Tj = +7 °C	0.969	0.978
Pdh Tj = 12°C	3.16 kW	3.28 kW
COP Tj = 12°C	8.15	6.50
Cdh Tj = +12 °C	0.965	0.973
Pdh Tj = Tbiv	7.40 kW	6.74 kW
COP Tj = Tbiv	3.10	2.29

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.51 kW	4.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.22	1.51
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.994	0.995
WTOL	60 °C	60 °C
Poff	14 W	14 W
PTO	14 W	14 W
PSB	14 W	14 W
PCK	14 W	14 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.86 kW	2.72 kW
Backup Heater	4.00 kW	4.00 kW
Annual energy consumption Qhe	3490 kWh	4405 kWh

Model: ENERGION M LIGHT 80

Configure model	
Model name	ENERGION M LIGHT 80
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	8.00 kW	5.80 kW
El input	1.67 kW	1.97 kW
COP	4.80	2.95

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

EN 14511-2

	+7°C/+12°C	+18°C/+23°C
El input	2.26 kW	1.49 kW
Cooling capacity	7	7.00
EER	3.10	4.70

EN 14825

	+7°C/+12°C
Pdesignc	7 kW
SEER	4.64
Pdc Tj = 35°C	7 kW
EER Tj = 35°C	3.1
Pdc Tj = 30°C	5.17 kW
EER Tj = 30°C	4.13
Cdc Tj = 30 °C	0.99
Pdc Tj = 25°C	3.32 kW
EER Tj = 25°C	4.89
Cdc Tj = 25 °C	0.98
Pdc Tj = 20°C	3.19 kW
EER Tj = 20°C	6.85
Cdc Tj = 20 °C	0.97
Poff	14 W
PTO	14 W
PSB	14 W
PCK	0 W
Annual energy consumption Qce	1381 kWh

Warmer Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	15 dB(A)	15 dB(A)
Sound power level outdoor	57 dB(A)	57 dB(A)

EN 14825

	Low temperature	Medium temperature
Pdesignh	4.93 kW	4.48 kW
η_s	242 %	151 %
Prated	4.93 kW	4.48 kW
SCOP	6.14	3.84
Tbiv	2 °C	2 °C
TOL	-20 °C	-20 °C
Pdh Tj = +2°C	4.93 kW	4.48 kW
COP Tj = +2°C	4.05	2.53
Cdh Tj = +2 °C	0.989	0.992
Pdh Tj = +7°C	3.10 kW	2.81 kW
COP Tj = +7°C	5.70	3.08
Cdh Tj = +7 °C	0.975	0.985
Pdh Tj = 12°C	3.28 kW	3.16 kW
COP Tj = 12°C	7.86	5.45

Cdh Tj = +12 °C	0.967	0.977
Pdh Tj = Tbiv	4.93 kW	4.48 kW
COP Tj = Tbiv	4.05	2.53
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.51 kW	4.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.22	1.51
WTOL	60 °C	60 °C
Poff	14 W	14 W
PTO	14 W	14 W
PSB	14 W	14 W
PCK	14 W	14 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Backup Heater	4.00 kW	4.00 kW
Annual energy consumption Qhe	1073 kWh	1557 kWh

Colder Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	15 dB(A)	15 dB(A)
Sound power level outdoor	57 dB(A)	57 dB(A)

EN 14825

	Low temperature	**Medium temperature**
Pdesignh	11.78 kW	11.53 kW
η_s	154 %	120 %
Prated	11.78 kW	11.53 kW
SCOP	3.93	3.08
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	7.13 kW	6.98 kW
COP Tj = -7°C	3.47	2.73
Cdh Tj = -7 °C	0.993	0.995
Pdh Tj = +2°C	4.51 kW	4.20 kW
COP Tj = +2°C	5.32	4.07
Cdh Tj = +2 °C	0.984	0.987
Pdh Tj = +7°C	3.06 kW	2.84 kW
COP Tj = +7°C	7.24	5.15
Cdh Tj = +7 °C	0.968	0.975
Pdh Tj = 12°C	3.18 kW	3.24 kW
COP Tj = 12°C	8.02	6.47
Cdh Tj = +12 °C	0.966	0.973
Pdh Tj = Tbiv	7.13 kW	6.98 kW

COP Tj = Tbiv	3.47	2.70
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.51 kW	4.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.22	1.51
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.993	0.995
WTOL	60 °C	60 °C
Poff	14 W	14 W
PTO	14 W	14 W
PSB	14 W	14 W
PCK	14 W	14 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	11.16 kW	10.93 kW
Backup Heater	4.00 kW	4.00 kW
Annual energy consumption Qhe	7398 kWh	9226 kWh

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	15 dB(A)	15 dB(A)
Sound power level outdoor	57 dB(A)	57 dB(A)

EN 14825

	Low temperature	**Medium temperature**
Pdesignh	8.37 kW	7.62 kW
η_s	195 %	140 %
Prated	8.37 kW	7.62 kW
SCOP	4.95	3.57
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	7.40 kW	6.74 kW
COP Tj = -7°C	3.10	2.29
Cdh Tj = -7 °C	0.994	0.995
Pdh Tj = +2°C	4.54 kW	4.22 kW
COP Tj = +2°C	4.80	3.51
Cdh Tj = +2 °C	0.986	0.989
Pdh Tj = +7°C	2.94 kW	2.74 kW
COP Tj = +7°C	6.61	4.36
Cdh Tj = +7 °C	0.969	0.978
Pdh Tj = 12°C	3.16 kW	3.28 kW
COP Tj = 12°C	8.15	6.50
Cdh Tj = +12 °C	0.965	0.973
Pdh Tj = Tbiv	7.40 kW	6.74 kW
COP Tj = Tbiv	3.10	2.29

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.51 kW	4.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.22	1.51
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.994	0.995
WTOL	60 °C	60 °C
Poff	14 W	14 W
PTO	14 W	14 W
PSB	14 W	14 W
PCK	14 W	14 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.86 kW	2.72 kW
Backup Heater	4.00 kW	4.00 kW
Annual energy consumption Qhe	3490 kWh	4405 kWh

Model: ENERGION M LIGHT 80T

Configure model	
Model name	ENERGION M LIGHT 80T
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	8.00 kW	5.80 kW
El input	1.67 kW	1.97 kW
COP	4.80	2.95

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

EN 14511-2

	+7°C/+12°C	+18°C/+23°C
El input	2.26 kW	1.49 kW
Cooling capacity	7	7.00
EER	3.10	4.70

EN 14825

	+7°C/+12°C
Pdesignc	7 kW
SEER	4.64
Pdc Tj = 35°C	7 kW
EER Tj = 35°C	3.1
Pdc Tj = 30°C	5.17 kW
EER Tj = 30°C	4.13
Cdc Tj = 30 °C	0.99
Pdc Tj = 25°C	3.32 kW
EER Tj = 25°C	4.89
Cdc Tj = 25 °C	0.98
Pdc Tj = 20°C	3.19 kW
EER Tj = 20°C	6.85
Cdc Tj = 20 °C	0.97
Poff	14 W
PTO	14 W
PSB	14 W
PCK	0 W
Annual energy consumption Qce	1381 kWh

Warmer Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	15 dB(A)	15 dB(A)
Sound power level outdoor	57 dB(A)	57 dB(A)

EN 14825

	Low temperature	Medium temperature
Pdesignh	4.93 kW	4.48 kW
η_s	242 %	151 %
Prated	4.93 kW	4.48 kW
SCOP	6.14	3.84
Tbiv	2 °C	2 °C
TOL	-20 °C	-20 °C
Pdh Tj = +2°C	4.93 kW	4.48 kW
COP Tj = +2°C	4.05	2.53
Cdh Tj = +2 °C	0.989	0.992
Pdh Tj = +7°C	3.10 kW	2.81 kW
COP Tj = +7°C	5.70	3.08
Cdh Tj = +7 °C	0.975	0.985
Pdh Tj = 12°C	3.28 kW	3.16 kW
COP Tj = 12°C	7.86	5.45

Cdh Tj = +12 °C	0.967	0.977
Pdh Tj = Tbiv	4.93 kW	4.48 kW
COP Tj = Tbiv	4.05	2.53
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.51 kW	4.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.22	1.51
WTOL	60 °C	60 °C
Poff	14 W	14 W
PTO	14 W	14 W
PSB	14 W	14 W
PCK	14 W	14 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Backup Heater	4.00 kW	4.00 kW
Annual energy consumption Qhe	1073 kWh	1557 kWh

Colder Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	15 dB(A)	15 dB(A)
Sound power level outdoor	57 dB(A)	57 dB(A)

EN 14825

	Low temperature	**Medium temperature**
Pdesignh	11.78 kW	11.53 kW
η_s	154 %	120 %
Prated	11.78 kW	11.53 kW
SCOP	3.93	3.08
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	7.13 kW	6.98 kW
COP Tj = -7°C	3.47	2.73
Cdh Tj = -7 °C	0.993	0.995
Pdh Tj = +2°C	4.51 kW	4.20 kW
COP Tj = +2°C	5.32	4.07
Cdh Tj = +2 °C	0.984	0.987
Pdh Tj = +7°C	3.06 kW	2.84 kW
COP Tj = +7°C	7.24	5.15
Cdh Tj = +7 °C	0.968	0.975
Pdh Tj = 12°C	3.18 kW	3.24 kW
COP Tj = 12°C	8.02	6.47
Cdh Tj = +12 °C	0.966	0.973
Pdh Tj = Tbiv	7.13 kW	6.98 kW

COP Tj = Tbiv	3.47	2.70
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.51 kW	4.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.22	1.51
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.993	0.995
WTOL	60 °C	60 °C
Poff	14 W	14 W
PTO	14 W	14 W
PSB	14 W	14 W
PCK	14 W	14 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	11.16 kW	10.93 kW
Backup Heater	4.00 kW	4.00 kW
Annual energy consumption Qhe	7398 kWh	9226 kWh

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	15 dB(A)	15 dB(A)
Sound power level outdoor	57 dB(A)	57 dB(A)

EN 14825

	Low temperature	**Medium temperature**
Pdesignh	8.37 kW	7.62 kW
η_s	195 %	140 %
Prated	8.37 kW	7.62 kW
SCOP	4.95	3.57
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	7.40 kW	6.74 kW
COP Tj = -7°C	3.10	2.29
Cdh Tj = -7 °C	0.994	0.995
Pdh Tj = +2°C	4.54 kW	4.22 kW
COP Tj = +2°C	4.80	3.51
Cdh Tj = +2 °C	0.986	0.989
Pdh Tj = +7°C	2.94 kW	2.74 kW
COP Tj = +7°C	6.61	4.36
Cdh Tj = +7 °C	0.969	0.978
Pdh Tj = 12°C	3.16 kW	3.28 kW
COP Tj = 12°C	8.15	6.50
Cdh Tj = +12 °C	0.965	0.973
Pdh Tj = Tbiv	7.40 kW	6.74 kW
COP Tj = Tbiv	3.10	2.29

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.51 kW	4.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.22	1.51
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.994	0.995
WTOL	60 °C	60 °C
Poff	14 W	14 W
PTO	14 W	14 W
PSB	14 W	14 W
PCK	14 W	14 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.86 kW	2.72 kW
Backup Heater	4.00 kW	4.00 kW
Annual energy consumption Qhe	3490 kWh	4405 kWh