

Page 1 of 4

This information was generated by the HP KEYMARK database on 21 Jun 2022

١.	$\overline{}$	\sim	ın	
	u	u		

Summary of	ACV Alféa Excellia Tri 16 BS	Reg. No.	012-C700005	
Certificate Holder				
Name	Groupe Atlantic	Groupe Atlantic		
Address	44 boulevard des Etats-Unis	Zip	85000	
City	La Roche Sur Yon	Country	France	
Certification Body	RISE CERT	RISE CERT		
Subtype title	ACV Alféa Excellia Tri 16 BS	ACV Alféa Excellia Tri 16 BS		
Heat Pump Type	Outdoor Air/Water	Outdoor Air/Water		
Refrigerant	R410A	R410A		
Mass of Refrigerant	2.5 kg			
Certification Date	19.12.2019	19.12.2019		
Testing basis	EN 14511:2013; EN 14825:2013; EN 12102:2013			



This information was generated by the HP KEYMARK database on 21 Jun 2022

Model: ACV Alféa Excellia Tri 16 BS

Configure model			
Model name	ACV Alféa Excellia Tri 16 BS		
Application	Heating (medium temp)		
Units	Indoor + Outdoor		
Climate Zone	n/a		
Reversibility	No		
Cooling mode application (optional)	n/a		

General Data		
Power supply	3x400V 50Hz	

Heating

EN 14511-4			
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed		
Operacing range outdoor exchanger/indoor exchanger lower inflictiower infliction	passed		
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed		
Shutting off the heat transfer medium flow	passed		
Complete power supply failure	passed		
Defrost test	passed		

EN 14511-2			
	Low temperature	Medium temperature	
Heat output	15.17 kW	12.24 kW	
El input	3.70 kW	4.93 kW	
СОР	4.10	2.48	

Average Climate

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



This information was generated by the HP KEYMARK database on 21 Jun 2022

EN 12102-1			
	Low temperature	Medium temperature	
Sound power level indoor	46 dB(A)	46 dB(A)	
Sound power level outdoor	69 dB(A)	69 dB(A)	

EN 14825			
	Low temperature	Medium temperature	
η_{s}	149 %	117 %	
Prated	14.00 kW	13.00 kW	
SCOP	3.80	3.00	
Tbiv	-7 °C	-7 °C	
TOL	-10 °C	-10 °C	
Pdh Tj = -7°C	12.00 kW	11.50 kW	
COP Tj = -7°C	2.40	1.80	
Pdh Tj = +2°C	7.30 kW	7.00 kW	
COP Tj = +2°C	3.60	2.90	
Pdh Tj = $+7^{\circ}$ C	6.30 kW	5.80 kW	
COP Tj = +7°C	5.50	4.10	
Pdh Tj = 12°C	7.40 kW	7.10 kW	
COP Tj = 12°C	7.20	5.50	
Pdh Tj = Tbiv	12.00 kW	11.50 kW	

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



Page 4 of 4 This information was generated by the HP KEYMARK database on 21 Jun 2022

COP Tj = Tbiv	2.40	1.80
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.70 kW	10.30 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.30	1.60
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	14 W	14 W
РТО	88 W	32 W
PSB	17 W	17 W
PCK	o w	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.90 kW	2.70 kW
Annual energy consumption Qhe	7408 kWh	9062 kWh