

This information was generated by the HP KEYMARK database on 18 Mar 2022

[Login](#)

Summary of	LW 251	Reg. No.	041-K001-40
Certificate Holder			
Name	ait-deutschland GmbH		
Address	Industriestr. 3	Zip	95359
City	Kasendorf	Country	Germany
Certification Body	BRE Global Limited		
Subtype title	LW 251		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R407c		
Mass of Refrigerant	9.8 kg		
Certification Date	08.10.2019		

Model: LW 251 (L)

Configure model	
Model name	LW 251 (L)
Application	Heating (medium temp)
Units	Indoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Starting and operating test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	15.47 kW	15.28 kW
El input	3.77 kW	5.21 kW
COP	4.11	2.93

Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	63 dB(A)	63 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	155 %	122 %
Prated	25.31 kW	25.01 kW
SCOP	3.95	3.13
Tbiv	-5 °C	-5 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	19.36 kW	19.18 kW
COP Tj = -7°C	2.96	2.07
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	24.23 kW	23.93 kW
COP Tj = +2°C	3.77	3.02
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	14.34 kW	14.29 kW
COP Tj = +7°C	5.06	4.13
Cdh Tj = +7 °C	1.00	1.00
Pdh Tj = 12°C	16.85 kW	16.82 kW

This information was generated by the HP KEYMARK database on 18 Mar 2022

COP Tj = 12°C	5.90	5.44
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	20.44 kW	20.20 kW
COP Tj = Tbiv	3.18	2.24
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	17.75 kW	17.70 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.66	1.83
WTOL	70 °C	70 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	7.56 kW	7.31 kW
Annual energy consumption Qhe	13252 kWh	16517 kWh

Warmer Climate

EN 14825		
	Low temperature	Medium temperature
η_s	198 %	152 %
Prated	24.15 kW	23.51 kW
SCOP	5.02	3.87

This information was generated by the HP KEYMARK database on 18 Mar 2022

Tbiv	4 °C	4 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	24.15 kW	23.51 kW
COP Tj = +2°C	3.55	2.35
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	14.33 kW	14.23 kW
COP Tj = +7°C	4.74	3.33
Cdh Tj = +7 °C	1.00	1.00
Pdh Tj = 12°C	16.84 kW	16.77 kW
COP Tj = 12°C	5.71	4.90
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	20.25 kW	19.85 kW
COP Tj = Tbiv	3.88	2.63
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	24.15 kW	23.51 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.55	2.35
WTOL	70 °C	70 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity

This information was generated by the HP KEYMARK database on 18 Mar 2022

Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Q _{he}	6424 kWh	8123 kWh

Colder Climate

EN 14825		
	Low temperature	Medium temperature
η_s	134 %	110 %
Prated	22.63 kW	22.68 kW
SCOP	3.43	2.83
T _{biv}	-12 °C	-12 °C
TOL	-20 °C	-20 °C
P _{d,h} T _j = -7°C	19.39 kW	19.68 kW
COP T _j = -7°C	3.15	2.39
C _{d,h} T _j = -7 °C	1.00	1.00
P _{d,h} T _j = +2°C	24.28 kW	24.09 kW
COP T _j = +2°C	3.93	3.37
C _{d,h} T _j = +2 °C	1.00	1.00
P _{d,h} T _j = +7°C	14.35 kW	14.32 kW
COP T _j = +7°C	5.22	4.56
C _{d,h} T _j = +7 °C	1.00	1.00
P _{d,h} T _j = 12°C	16.85 kW	16.85 kW

This information was generated by the HP KEYMARK database on 18 Mar 2022

COP Tj = 12°C	5.78	5.71
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	16.68 kW	16.71 kW
COP Tj = Tbiv	2.71	1.96
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.40 kW	13.77 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	1.92	1.53
WTOL	70 °C	70 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	22.63 kW	22.68 kW
Annual energy consumption Qhe	16286 kWh	19754 kWh
Pdh Tj = -15°C (if TOL<-20°C)	15.06	15.23
COP Tj = -15°C (if TOL<-20°C)	2.40	1.74
Cdh Tj = -15 °C	1.00	1.00

Model: LW 251A

Configure model	
Model name	LW 251A
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Starting and operating test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	15.47 kW	15.28 kW
El input	3.77 kW	5.21 kW
COP	4.11	2.93

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	63 dB(A)	63 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	155 %	122 %
Prated	25.31 kW	25.01 kW
SCOP	3.95	3.13
Tbiv	-5 °C	-5 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	19.36 kW	19.18 kW
COP Tj = -7°C	2.96	2.07
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	24.23 kW	23.93 kW
COP Tj = +2°C	3.77	3.02
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	14.34 kW	14.29 kW
COP Tj = +7°C	5.06	4.13
Cdh Tj = +7 °C	1.00	1.00

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = 12°C	16.85 kW	16.82 kW
COP Tj = 12°C	5.90	5.44
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	20.44 kW	20.20 kW
COP Tj = Tbiv	3.18	2.24
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	17.75 kW	17.70 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.66	1.83
WTOL	70 °C	70 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	7.56 kW	7.31 kW
Annual energy consumption Qhe	13252 kWh	16517 kWh

Warmer Climate

EN 14825		
	Low temperature	Medium temperature
η_s	198 %	152 %
Prated	24.15 kW	23.51 kW

This information was generated by the HP KEYMARK database on 18 Mar 2022

SCOP	5.02	3.87
Tbiv	4 °C	4 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	24.15 kW	23.51 kW
COP Tj = +2°C	3.55	2.35
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	14.33 kW	14.23 kW
COP Tj = +7°C	4.74	3.33
Cdh Tj = +7 °C	1.00	1.00
Pdh Tj = 12°C	16.84 kW	16.77 kW
COP Tj = 12°C	5.71	4.90
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	20.25 kW	19.85 kW
COP Tj = Tbiv	3.88	2.63
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	24.15 kW	23.51 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.55	2.35
WTOL	70 °C	70 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W

This information was generated by the HP KEYMARK database on 18 Mar 2022

Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Q _{he}	6424 kWh	8123 kWh

Colder Climate

EN 14825		
	Low temperature	Medium temperature
η_s	134 %	110 %
Prated	22.63 kW	22.68 kW
SCOP	3.43	2.83
T _{biv}	-12 °C	-12 °C
TOL	-20 °C	-20 °C
P _{dh} T _j = -7°C	19.39 kW	19.68 kW
COP T _j = -7°C	3.15	2.39
C _{dh} T _j = -7 °C	1.00	1.00
P _{dh} T _j = +2°C	24.28 kW	24.09 kW
COP T _j = +2°C	3.93	3.37
C _{dh} T _j = +2 °C	1.00	1.00
P _{dh} T _j = +7°C	14.35 kW	14.32 kW
COP T _j = +7°C	5.22	4.56
C _{dh} T _j = +7 °C	1.00	1.00

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = 12°C	16.85 kW	16.85 kW
COP Tj = 12°C	5.78	5.71
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	16.68 kW	16.71 kW
COP Tj = Tbiv	2.71	1.96
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.40 kW	13.77 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	1.92	1.53
WTOL	70 °C	70 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	22.63 kW	22.68 kW
Annual energy consumption Qhe	16286 kWh	19754 kWh
Pdh Tj = -15°C (if TOL<-20°C)	15.06	15.23
COP Tj = -15°C (if TOL<-20°C)	2.40	1.74
Cdh Tj = -15 °C	1.00	1.00