

Page 1 of 21

This information was generated by the HP KEYMARK database on 18 Mar 2022

<u>Login</u>

Summary of	Aquarea Monobloc 9-12 kW T-CAP (J Series) + TD30	Reg. No.	011-1W0464
Certificate Holder			
Name	Panasonic Marketing Europe GmbH		
Address	Hagenauer Strasse 43, Wiesbaden	Zip	65203
City	Wiesbaden	Country	Germany
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Subtype title	Aquarea Monobloc 9-12 kW T-CAP (J Series) + TD30		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R32		
Mass of Refrigerant	1.6 kg		
Certification Date	10.11.2021		
Testing basis	Festing basis HP KEYMARK certification scheme rules rev. 8		



Model: WH-MXC09J3E5 + PAW-TD30C1E5-HI

Configure model		
Model name WH-MXC09J3E5 + PAW-TD30C1E5-HI		
Application	Heating + DHW + low temp	
Units	Outdoor	
Climate Zone n/a		
Reversibility Yes		
Cooling mode application (optional)	+7°C/12°C	

General Data		
Power supply	1x230V 50Hz	

Heating

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	9.00 kW	9.00 kW
El input	1.77 kW	2.92 kW
СОР	5.08	3.08



EN 12102-1		
Low temperature Medium temperature		Medium temperature
Sound power level outdoor	65 dB(A)	65 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_{s}	195 %	140 %
Prated	9.00 kW	9.00 kW
SCOP	4.96	3.57
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	8.00 kW	8.00 kW
COP Tj = -7°C	3.04	2.33
Cdh Tj = -7 °C	1.000	1.000
Pdh Tj = +2°C	4.90 kW	4.90 kW
COP Tj = +2°C	4.93	3.46
Cdh Tj = +2 °C	0.990	0.990
Pdh Tj = +7°C	5.40 kW	5.10 kW
COP Tj = +7°C	6.26	4.48
Cdh Tj = +7 °C	0.990	0.990
Pdh Tj = 12°C	6.30 kW	6.10 kW

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com





COP Tj = 12°C 8.19 6.02 Cdh Tj = +12 °C 0.990 0.990 Pdh Tj = Tbiv 9.00 kW 9.00 kW COP Tj = Tbiv 2.90 2.04 Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh 9.00 kW 9.00 kW COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh 2.90 2.04 WTOL 55 °C 55 °C Poff 9 W 9 W PTO 10 W 10 W PSB 9 W 9 W PCK 0 W 0 W Supplementary Heater: Type of energy input Electricity Electricity Supplementary Heater: PSUP 0.00 kW 0.00 kW Annual energy consumption Qhe 3747 kWh 5208 kWh			
Pdh Tj = Tbiv 9.00 kW 9.00 kW COP Tj = Tbiv 2.90 2.04 Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	COP Tj = 12°C	8.19	6.02
COP Tj = Tbiv 2.90 2.04 Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	Cdh Tj = +12 °C	0.990	0.990
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	Pdh Tj = Tbiv	9.00 kW	9.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	COP Tj = Tbiv	2.90	2.04
WTOL 55 °C 55 °C Poff 9 W 9 W PTO 10 W 10 W PSB 9 W 9 W PCK 0 W 0 W Supplementary Heater: Type of energy input Electricity Electricity Supplementary Heater: PSUP 0.00 kW 0.00 kW	Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.00 kW	9.00 kW
Poff 9 W 9 W PTO 10 W 10 W PSB 9 W 9 W PCK 0 W 0 W Supplementary Heater: Type of energy input Electricity Electricity Supplementary Heater: PSUP 0.00 kW 0.00 kW	COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.90	2.04
PTO 10 W 10 W PSB 9 W 9 W PCK 0 W Supplementary Heater: Type of energy input Electricity Electricity Supplementary Heater: PSUP 0.00 kW	WTOL	55 °C	55 °C
PSB 9 W 9 W PCK 0 W 0 W Supplementary Heater: Type of energy input Electricity Electricity Supplementary Heater: PSUP 0.00 kW 0.00 kW	Poff	9 W	9 W
PCK 0 W 0 W Supplementary Heater: Type of energy input Electricity Electricity Supplementary Heater: PSUP 0.00 kW 0.00 kW	РТО	10 W	10 W
Supplementary Heater: Type of energy input Electricity Electricity Supplementary Heater: PSUP 0.00 kW 0.00 kW	PSB	9 W	9 W
Supplementary Heater: PSUP 0.00 kW 0.00 kW	РСК	o w	o w
	Supplementary Heater: Type of energy input	Electricity	Electricity
Annual energy consumption Qhe 3747 kWh 5208 kWh	Supplementary Heater: PSUP	0.00 kW	0.00 kW
	Annual energy consumption Qhe	3747 kWh	5208 kWh

Cooling

EN 14511-2	
	+7°C/+12°C
El input	2.83 kW
Cooling capacity	9.00
EER	3.18



EN 14825	
	+7°C/+12°C
Pdesignc	9.00 kW
SEER	4.80
Pdc Tj = 35°C	9.00 kW
EER Tj = 35°C	3.18
Pdc Tj = 30°C	6.63 kW
EER Tj = 30°C	4.20
Cdc	0.9
Pdc Tj = 25°C	4.60 kW
EER Tj = 25°C	5.32
Cdc	0.9
Pdc Tj = 20°C	4.80 kW
EER Tj = 20°C	6.16
Cdc	0.9
Poff	9 W
РТО	1 W
PSB	9 W
РСК	o w
Annual energy consumption Qce	656 kWh

Domestic Hot Water (DHW)



EN 16147		
Declared load profile	XL	XL
Efficiency ηDHW	128 %	128 %
COP	3.07	3.07
Heating up time	1:05 h:min	1:05 h:min
Standby power input	50.0 W	50.0 W
Reference hot water temperature	52.0 °C	52.0 °C
Mixed water at 40°C	384 I	384 I



Model: WH-MXC12J6E5 + PAW-TD30C1E5-HI


Configure model		
Model name	WH-MXC12J6E5 + PAW-TD30C1E5-HI	
Application	Heating + DHW + low temp	
Units	Outdoor	
Climate Zone	n/a	
Reversibility Yes		
Cooling mode application (optional)	+7°C/12°C	


General Data		
Power supply	1x230V 50Hz	

Heating

EN 14511-2		
Low temperature Medium temperature		
Heat output	12.00 kW	12.00 kW
El input	2.50 kW	3.94 kW
СОР	4.80	3.05

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed





CEN heat pump

EN 14825		
	Low temperature	Medium temperature
η_{s}	195 %	140 %
Prated	9.00 kW	9.00 kW
SCOP	4.96	3.57
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	8.00 kW	8.00 kW
COP Tj = -7°C	3.04	2.33
Cdh Tj = -7 °C	1.000	1.000
Pdh Tj = +2°C	4.90 kW	4.90 kW
COP Tj = +2°C	4.93	3.46
Cdh Tj = +2 °C	0.990	0.990
Pdh Tj = +7°C	5.40 kW	5.10 kW
COP Tj = +7°C	6.26	4.48
Cdh Tj = +7 °C	0.990	0.990
Pdh Tj = 12°C	6.30 kW	6.10 kW

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com






COP Tj = 12°C	8.19	6.02
Cdh Tj = +12 °C	0.990	0.990
Pdh Tj = Tbiv	9.00 kW	9.00 kW
COP Tj = Tbiv	2.90	2.04
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.00 kW	9.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.90	2.04
WTOL	55 °C	55 °C
Poff	9 W	9 W
РТО	10 W	10 W
PSB	9 W	9 W
PCK	o w	o w
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	3747 kWh	5208 kWh

Cooling

EN 14825





This information was generated by the HP KE	+7°C/+12°C
Pdesignc	12.00 kW
SEER	4.79
Pdc Tj = 35°C	12.00 kW
EER Tj = 35°C	2.90
Pdc Tj = 30°C	8.84 kW
EER Tj = 30°C	4.02
Cdc	0.9
Pdc Tj = 25°C	5.68 kW
EER Tj = 25°C	5.40
Cdc	0.9
Pdc Tj = 20°C	4.90 kW
EER Tj = 20°C	6.30
Cdc	0.9
Poff	9 W
РТО	1 W
PSB	9 W
PCK	o w
Annual energy consumption Qce	878 kWh



EN 14511-2		
+7°C/+12°C		
El input	4.14 kW	
Cooling capacity	12.00	
EER	2.90	

Domestic Hot Water (DHW)

EN 16147		
Declared load profile	XL	
Efficiency ηDHW	128 %	
СОР	3.07	
Heating up time	1:05 h:min	
Standby power input	50.0 W	
Reference hot water temperature	52.0 °C	
Mixed water at 40°C	384 I	



Model: WH-MXC09J3E8 + PAW-TD30C1E5-HI

Configure model		
Model name WH-MXC09J3E8 + PAW-TD30C1E5-HI		
Application Heating + DHW + low temp		
Units	Outdoor	
Climate Zone n/a		
Reversibility	Yes	
Cooling mode application (optional)	+7°C/12°C	

General Data		
Power supply	3x400V 50Hz	

Heating

EN 14511-4		
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	
Defrost test	passed	
Starting and operating test	passed	


EN 14511-2		
	Low temperature	Medium temperature
Heat output	9.00 kW	9.00 kW
El input	1.77 kW	2.92 kW
СОР	5.08	3.08



EN 12102-1		
	Low temperature	Medium temperature
Sound power level outdoor	65 dB(A)	65 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_{s}	195 %	140 %
Prated	9.00 kW	9.00 kW
SCOP	4.96	3.57
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	8.00 kW	8.00 kW
COP Tj = -7°C	3.04	2.33
Cdh Tj = -7 °C	1.000	1.000
Pdh Tj = +2°C	4.90 kW	4.90 kW
COP Tj = +2°C	4.93	3.46
Cdh Tj = +2 °C	0.990	0.990
Pdh Tj = +7°C	5.40 kW	5.10 kW
COP Tj = +7°C	6.26	4.48
Cdh Tj = +7 °C	0.990	0.990
Pdh Tj = 12°C	6.30 kW	6.10 kW

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com





COP Tj = 12°C 8.19 6.02 Cdh Tj = +12 °C 0.990 0.990 Pdh Tj = Tbiv 9.00 kW 9.00 kW COP Tj = Tbiv 2.90 2.04 Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh 9.00 kW 9.00 kW COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh 2.90 2.04 WTOL 55 °C 55 °C Poff 9 W 9 W PTO 10 W 10 W PSB 9 W 9 W PCK 0 W 0 W Supplementary Heater: Type of energy input Electricity Electricity Supplementary Heater: PSUP 0.00 kW 0.00 kW Annual energy consumption Qhe 3747 kWh 5208 kWh			
Pdh Tj = Tbiv 9.00 kW 9.00 kW COP Tj = Tbiv 2.90 2.04 Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	COP Tj = 12°C	8.19	6.02
COP Tj = Tbiv 2.90 2.04 Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	Cdh Tj = +12 °C	0.990	0.990
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	Pdh Tj = Tbiv	9.00 kW	9.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	COP Tj = Tbiv	2.90	2.04
WTOL 55 °C 55 °C Poff 9 W 9 W PTO 10 W 10 W PSB 9 W 9 W PCK 0 W 0 W Supplementary Heater: Type of energy input Electricity Electricity Supplementary Heater: PSUP 0.00 kW 0.00 kW	Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.00 kW	9.00 kW
Poff 9 W 9 W PTO 10 W 10 W PSB 9 W 9 W PCK 0 W 0 W Supplementary Heater: Type of energy input Electricity Electricity Supplementary Heater: PSUP 0.00 kW 0.00 kW	COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.90	2.04
PTO 10 W 10 W PSB 9 W 9 W PCK 0 W Supplementary Heater: Type of energy input Electricity Electricity Supplementary Heater: PSUP 0.00 kW	WTOL	55 °C	55 °C
PSB 9 W 9 W PCK 0 W 0 W Supplementary Heater: Type of energy input Electricity Electricity Supplementary Heater: PSUP 0.00 kW 0.00 kW	Poff	9 W	9 W
PCK 0 W 0 W Supplementary Heater: Type of energy input Electricity Electricity Supplementary Heater: PSUP 0.00 kW 0.00 kW	РТО	10 W	10 W
Supplementary Heater: Type of energy input Electricity Electricity Supplementary Heater: PSUP 0.00 kW 0.00 kW	PSB	9 W	9 W
Supplementary Heater: PSUP 0.00 kW 0.00 kW	РСК	o w	o w
	Supplementary Heater: Type of energy input	Electricity	Electricity
Annual energy consumption Qhe 3747 kWh 5208 kWh	Supplementary Heater: PSUP	0.00 kW	0.00 kW
	Annual energy consumption Qhe	3747 kWh	5208 kWh

Cooling

EN 14511-2	
	+7°C/+12°C
El input	2.83 kW
Cooling capacity	9.00
EER	3.18



EN 14825		
	+7°C/+12°C	
Pdesignc	9.00 kW	
SEER	4.80	
Pdc Tj = 35°C	9.00 kW	
EER Tj = 35°C	3.18	
Pdc Tj = 30°C	6.63 kW	
EER Tj = 30°C	4.20	
Cdc	0.9	
Pdc Tj = 25°C	4.60 kW	
EER Tj = 25°C	5.32	
Cdc	0.9	
Pdc Tj = 20°C	4.80 kW	
EER Tj = 20°C	6.16	
Cdc	0.9	
Poff	9 W	
РТО	1 W	
PSB	9 W	
PCK	o w	
Annual energy consumption Qce	656 kWh	

Domestic Hot Water (DHW)



EN 16147		
Declared load profile	XL	XL
Efficiency ηDHW	128 %	128 %
СОР	3.07	3.07
Heating up time	1:05 h:min	1:05 h:min
Standby power input	50.0 W	50.0 W
Reference hot water temperature	52.0 °C	52.0 °C
Mixed water at 40°C	384 I	384 I



Model: WH-MXC12J9E8 + PAW-TD30C1E5-HI

Configure model	
Model name WH-MXC12J9E8 + PAW-TD30C1E5-HI	
Application Heating + DHW + low temp	
Units	Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data		
Power supply	3x400V 50Hz	

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	12.00 kW	12.00 kW
El input	2.50 kW	3.94 kW
СОР	4.80	3.05

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed






EN 12102-1		
	Low temperature	Medium temperature
Sound power level outdoor	65 dB(A)	65 dB(A)

	EN 14825	
	Low temperature	Medium temperature
η_{s}	195 %	140 %
Prated	9.00 kW	9.00 kW
SCOP	4.96	3.57
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	8.00 kW	8.00 kW
COP Tj = -7°C	3.04	2.33
Cdh Tj = -7 °C	1.000	1.000
Pdh Tj = +2°C	4.90 kW	4.90 kW
COP Tj = +2°C	4.93	3.46
Cdh Tj = +2 °C	0.990	0.990
Pdh Tj = +7°C	5.40 kW	5.10 kW
$COP Tj = +7^{\circ}C$	6.26	4.48
Cdh Tj = +7 °C	0.990	0.990
Pdh Tj = 12°C	6.30 kW	6.10 kW

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com





COP Tj = 12°C	8.19	6.02
Cdh Tj = +12 °C	0.990	0.990
Pdh Tj = Tbiv	9.00 kW	9.00 kW
COP Tj = Tbiv	2.90	2.04
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.00 kW	9.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.90	2.04
WTOL	55 °C	55 °C
Poff	9 W	9 W
РТО	10 W	10 W
PSB	9 W	9 W
PCK	o w	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	3747 kWh	5208 kWh

Cooling

EN 14825





This information was generated by the HP KE	+7°C/+12°C
Pdesignc	12.00 kW
SEER	4.79
Pdc Tj = 35°C	12.00 kW
EER Tj = 35°C	2.90
Pdc Tj = 30°C	8.84 kW
EER Tj = 30°C	4.02
Cdc	0.9
Pdc Tj = 25°C	5.68 kW
EER Tj = 25°C	5.40
Cdc	0.9
Pdc Tj = 20°C	4.90 kW
EER Tj = 20°C	6.30
Cdc	0.9
Poff	9 W
РТО	1 W
PSB	9 W
PCK	0 W
Annual energy consumption Qce	878 kWh



EN 14511-2		
	+7°C/+12°C	
El input	4.14 kW	
Cooling capacity	12.00	
EER	2.90	

Domestic Hot Water (DHW)

EN 16147		
Declared load profile	XL	
Efficiency ηDHW	128 %	
СОР	3.07	
Heating up time	1:05 h:min	
Standby power input	50.0 W	
Reference hot water temperature	52.0 °C	
Mixed water at 40°C	384 I	