

Page 1 of 7 This information was generated by the HP KEYMARK database on 17 Dec 2020

Summary of	WWC 130 H/X	Reg. No.	041-K001-32	
Certificate Holder				
Name	ait-deutschland Gm	nbH		
Address	Industriestr. 3	Zip	95359	
City	Kasendorf	Country	Germany	
Certification Body	BRE Energy & Communications Division			
Name of testing laboratory	WPZ			
Subtype title	WWC 130 H/X			
Heat Pump Type	Water/Water			
Refrigerant	R407c			
Mass Of Refrigerant	3.5 kg			
Certification Date	06.09.2019			



This information was generated by the HP KEYMARK database on 17 Dec 2020

Model: WWC 130H/X

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Starting and operating test	passed

EN 14511-2			
	Low temperature	Medium temperature	
Heat output	12.90 kW	11.70 kW	
El input	2.35 kW	3.43 kW	
СОР	5.50	3.23	
Indoor water flow rate	2.60 m³/h	2.60 m³/h	

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	53 dB(A)	53 dB(A)





This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 14825

	Low temperature	Medium temperature
η_{s}	227 %	176 %
Prated	12.90 kW	11.70 kW
SCOP	5.88	4.60
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	12.92 kW	11.88 kW
COP Tj = -7°C	5.55	3.63
Cdh	1.00	1.00
Pdh Tj = +2°C	13.06 kW	12.48 kW
COP Tj = +2°C	5.89	4.56
Cdh	1.00	1.00
Pdh Tj = +7°C	13.18 kW	12.84 kW
COP Tj = +7°C	6.22	5.29
Cdh	1.00	1.00
Pdh Tj = 12°C	13.30 kW	13.20 kW
COP Tj = 12°C	6.49	6.16
Cdh	1.00	1.00
Pdh Tj = Tbiv	12.90 kW	11.70 kW
COP Tj = Tbiv	5.49	3.41

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com





This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = TOL	12.90 kW	11.70 kW
COP Tj = TOL	5.49	3.41
WTOL	65 °C	65 °C
Poff	10 W	10 W
РТО	10 W	10 W
PSB	10 W	10 W
PCK	o w	o w
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	4535 kWh	5250 kWh

Warmer Climate

EN 14825		
	Low temperature	Medium temperature
η_{s}	228 %	177 %
Prated	12.90 kW	11.70 kW
SCOP	5.90	4.63
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	12.90 kW	11.70 kW
COP Tj = +2°C	5.49	3.41





Cdh	1.00	1.00
Pdh Tj = $+7^{\circ}$ C	13.03 kW	12.24 kW
$COP Tj = +7^{\circ}C$	5.82	4.15
Cdh	1.00	1.00
Pdh Tj = 12°C	13.22 kW	12.96 kW
COP Tj = 12°C	6.33	5.57
Cdh	1.00	1.00
Pdh Tj = Tbiv	12.90 kW	11.70 kW
COP Tj = Tbiv	5.49	3.41
Pdh Tj = TOL	12.90 kW	11.70 kW
COP Tj = TOL	5.49	3.41
WTOL	65 °C	65 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	2920 kWh	3373 kWh

Colder Climate





$$\operatorname{\textit{Page}}$ 6 of 7 This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 14825

		<u> </u>
	Low temperature	Medium temperature
η_{s}	233 %	183 %
Prated	12.90 kW	11.70 kW
SCOP	6.04	4.77
Tbiv	-22 °C	-22 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	13.08 kW	12.36 kW
COP Tj = -7°C	5.95	4.35
Cdh	1.00	1.00
Pdh Tj = +2°C	13.08 kW	12.78 kW
COP Tj = +2°C	6.24	5.16
Cdh	1.00	1.00
Pdh Tj = +7°C	13.26 kW	13.08 kW
$COP Tj = +7^{\circ}C$	6.45	5.88
Cdh	1.00	1.00
Pdh Tj = 12°C	13.28 kW	13.32 kW
COP Tj = 12°C	6.35	6.43
Cdh	1.00	1.00
Pdh Tj = Tbiv	12.90 kW	11.70 kW
COP Tj = Tbiv	5.49	3.41

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



 $$\operatorname{\textit{Page}}\ 7$$ of 7 This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = TOL	12.90 kW	11.70 kW
COP Tj = TOL	5.49	3.41
WTOL	65 °C	65 °C
Poff	10 W	10 W
РТО	10 W	10 W
PSB	10 W	10 W
PCK	o w	o w
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	5269 kWh	6049 kWh
Pdh Tj = -15°C (if TOL<-20°C)	0.01	0.01
COP Tj = -15 °C (if TOL< -20 °C)	0.01	0.01
Cdh	1.00	1.00