

This information was generated by the HP KEYMARK database on 23 Jun 2022

[Login](#)

Summary of	BLW Split D 6/8	Reg. No.	21HK0032/00
Certificate Holder			
Name	August Brötje GmbH		
Address	August-Brötje-Str. 17	Zip	26180
City	Rastede	Country	Germany
Certification Body	Kiwa Nederland B.V.		
Subtype title	BLW Split D 6/8		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R32		
Mass of Refrigerant	1.2 kg		
Certification Date	03.12.2021		
Testing basis	European KEYMARK Scheme for Heat Pumps (v9)		

Model: AWHPR 6 MR + BLWSI48MHD

Configure model	
Model name	AWHPR 6 MR + BLWSI48MHD
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C and +18°C/+23°C

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	6.40 kW	5.70 kW
El input	1.28 kW	1.97 kW
COP	5.00	2.90

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

This information was generated by the HP KEYMARK database on 23 Jun 2022

EN 14511-2		
	+7°C/+12°C	+18°C/+23°C
El input	2.10 kW	1.36 kW
Cooling capacity	6.50	7.00
EER	3.09	5.14

EN 14825		
	+7°C/+12°C	+18°C/+23°C
P _{designc}	6.50 kW	7.00 kW
SEER	4.01	6.49
P _{dc} T _j = 35°C	6.50 kW	7.00 kW
EER T _j = 35°C	3.09	5.14
P _{dc} T _j = 30°C	4.90 kW	5.39 kW
EER T _j = 30°C	3.99	6.65
P _{dc} T _j = 25°C	3.10 kW	3.32 kW
EER T _j = 25°C	4.55	4.93
P _{dc} T _j = 20°C	1.37 kW	1.78 kW
EER T _j = 20°C	3.96	12.82
P _{off}	12 W	12 W
PTO	12 W	12 W
PSB	12 W	12 W
PCK	0 W	0 W
Annual energy consumption Q _{ce}	973 kWh	647 kWh

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	33 dB(A)	33 dB(A)
Sound power level outdoor	58 dB(A)	58 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	178 %	132 %
Prated	6.50 kW	6.00 kW
SCOP	4.52	3.38
Tbiv	-10 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.90 kW	5.50 kW
COP Tj = -7°C	3.16	2.22
Cdh Tj = -7 °C	0.990	0.990
Pdh Tj = +2°C	3.50 kW	3.40 kW
COP Tj = +2°C	4.48	3.37
Cdh Tj = +2 °C	0.980	0.980
Pdh Tj = +7°C	2.25 kW	2.10 kW
COP Tj = +7°C	5.61	4.07
Cdh Tj = +7 °C	0.960	0.970

This information was generated by the HP KEYMARK database on 23 Jun 2022

Pdh Tj = 12°C	2.50 kW	2.50 kW
COP Tj = 12°C	6.92	6.58
Cdh Tj = +12 °C	0.960	0.970
Pdh Tj = Tbiv	6.60 kW	5.50 kW
COP Tj = Tbiv	2.68	2.22
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.60 kW	5.30 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.68	1.82
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.990	0.990
WTOL	60 °C	60 °C
Poff	12 W	12 W
PTO	12 W	12 W
PSB	12 W	12 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	n/a	n/a
Supplementary Heater: PSUP	0.00 kW	0.70 kW
Annual energy consumption Qhe	2974 kWh	3667 kWh

Model: AWHPR 6 MR + BLWSI48OHD

Configure model	
Model name	AWHPR 6 MR + BLWSI48OHD
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C and +18°C/+23°C

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	6.40 kW	5.70 kW
El input	1.28 kW	1.97 kW
COP	5.00	2.90

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

This information was generated by the HP KEYMARK database on 23 Jun 2022

EN 14511-2		
	+7°C/+12°C	+18°C/+23°C
El input	2.10 kW	1.36 kW
Cooling capacity	6.50	7.00
EER	3.09	5.14

EN 14825		
	+7°C/+12°C	+18°C/+23°C
P _{designc}	6.50 kW	7.00 kW
SEER	4.01	6.49
P _{dc} T _j = 35°C	6.50 kW	7.00 kW
EER T _j = 35°C	3.09	5.14
P _{dc} T _j = 30°C	4.90 kW	5.39 kW
EER T _j = 30°C	3.99	6.65
P _{dc} T _j = 25°C	3.10 kW	3.32 kW
EER T _j = 25°C	4.55	4.93
P _{dc} T _j = 20°C	1.37 kW	1.78 kW
EER T _j = 20°C	3.96	12.82
P _{off}	12 W	12 W
PTO	12 W	12 W
PSB	12 W	12 W
PCK	0 W	0 W
Annual energy consumption Q _{ce}	973 kWh	647 kWh

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	33 dB(A)	33 dB(A)
Sound power level outdoor	58 dB(A)	58 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	178 %	132 %
Prated	6.50 kW	6.00 kW
SCOP	4.52	3.38
Tbiv	-10 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.90 kW	5.50 kW
COP Tj = -7°C	3.16	2.22
Cdh Tj = -7 °C	0.990	0.990
Pdh Tj = +2°C	3.50 kW	3.40 kW
COP Tj = +2°C	4.48	3.37
Cdh Tj = +2 °C	0.980	0.980
Pdh Tj = +7°C	2.25 kW	2.10 kW
COP Tj = +7°C	5.61	4.07
Cdh Tj = +7 °C	0.960	0.970

This information was generated by the HP KEYMARK database on 23 Jun 2022

Pdh Tj = 12°C	2.50 kW	2.50 kW
COP Tj = 12°C	6.92	6.58
Cdh Tj = +12 °C	0.960	0.970
Pdh Tj = Tbiv	6.60 kW	5.50 kW
COP Tj = Tbiv	2.68	2.22
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.60 kW	5.30 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.68	1.82
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.990	0.990
WTOL	60 °C	60 °C
Poff	12 W	12 W
PTO	12 W	12 W
PSB	12 W	12 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	n/a	n/a
Supplementary Heater: PSUP	0.00 kW	0.70 kW
Annual energy consumption Qhe	2974 kWh	3667 kWh

Model: AWHPR 8 MR + BLWSI48MHD

Configure model	
Model name	AWHPR 8 MR + BLWSI48MHD
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C and +18°C/+23°C

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	7.60 kW	8.00 kW
El input	1.59 kW	2.91 kW
COP	4.77	2.75

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

EN 14511-2		
	+7°C/+12°C	+18°C/+23°C
El input	2.15 kW	1.45 kW
Cooling capacity	6.50	7.10
EER	3.02	4.88

EN 14825		
	+7°C/+12°C	+18°C/+23°C
P _{designc}	6.50 kW	7.10 kW
SEER	4.43	5.89
P _{dc} T _j = 35°C	6.50 kW	7.10 kW
EER T _j = 35°C	3.02	4.88
P _{dc} T _j = 30°C	4.97 kW	5.65 kW
EER T _j = 30°C	4.12	6.81
P _{dc} T _j = 25°C	3.35 kW	3.18 kW
EER T _j = 25°C	4.74	5.26
P _{dc} T _j = 20°C	1.55 kW	1.67 kW
EER T _j = 20°C	5.50	7.40
P _{off}	12 W	12 W
PTO	12 W	12 W
PSB	12 W	12 W
PCK	0 W	0 W
Annual energy consumption Q _{ce}	881 kWh	723 kWh

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	33 dB(A)	33 dB(A)
Sound power level outdoor	59 dB(A)	59 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	177 %	131 %
Prated	7.00 kW	7.00 kW
SCOP	4.50	3.34
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	6.19 kW	6.19 kW
COP Tj = -7°C	2.97	2.09
Cdh Tj = -7 °C	0.990	0.990
Pdh Tj = +2°C	4.12 kW	3.79 kW
COP Tj = +2°C	4.46	3.24
Cdh Tj = +2 °C	0.980	0.990
Pdh Tj = +7°C	2.78 kW	2.49 kW
COP Tj = +7°C	5.70	4.57
Cdh Tj = +7 °C	0.970	0.970

This information was generated by the HP KEYMARK database on 23 Jun 2022

Pdh Tj = 12°C	2.67 kW	2.55 kW
COP Tj = 12°C	7.80	6.10
Cdh Tj = +12 °C	0.960	0.960
Pdh Tj = Tbiv	6.19 kW	6.19 kW
COP Tj = Tbiv	2.97	2.09
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.64 kW	4.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.58	1.66
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.990	0.990
WTOL	60 °C	60 °C
Poff	12 W	12 W
PTO	12 W	12 W
PSB	12 W	12 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	n/a	n/a
Supplementary Heater: PSUP	0.36 kW	2.10 kW
Annual energy consumption Qhe	3213 kWh	4334 kWh

Model: AWHPR 8 MR + BLWSI48OHD

Configure model	
Model name	AWHPR 8 MR + BLWSI48OHD
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C and +18°C/+23°C

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	7.60 kW	8.00 kW
El input	1.59 kW	2.91 kW
COP	4.77	2.75

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

EN 14511-2		
	+7°C/+12°C	+18°C/+23°C
El input	2.15 kW	1.45 kW
Cooling capacity	6.50	7.10
EER	3.02	4.88

EN 14825		
	+7°C/+12°C	+18°C/+23°C
P _{designc}	6.50 kW	7.10 kW
SEER	4.43	5.89
P _{dc} T _j = 35°C	6.50 kW	7.10 kW
EER T _j = 35°C	3.02	4.88
P _{dc} T _j = 30°C	4.97 kW	5.65 kW
EER T _j = 30°C	4.12	6.81
P _{dc} T _j = 25°C	3.35 kW	3.18 kW
EER T _j = 25°C	4.74	5.26
P _{dc} T _j = 20°C	1.55 kW	1.67 kW
EER T _j = 20°C	5.50	7.40
P _{off}	12 W	12 W
PTO	12 W	12 W
PSB	12 W	12 W
PCK	0 W	0 W
Annual energy consumption Q _{ce}	881 kWh	723 kWh

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	33 dB(A)	33 dB(A)
Sound power level outdoor	59 dB(A)	59 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	177 %	131 %
Prated	7.00 kW	7.00 kW
SCOP	4.50	3.34
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	6.19 kW	6.19 kW
COP Tj = -7°C	2.97	2.09
Cdh Tj = -7 °C	0.990	0.990
Pdh Tj = +2°C	4.12 kW	3.79 kW
COP Tj = +2°C	4.46	3.24
Cdh Tj = +2 °C	0.980	0.990
Pdh Tj = +7°C	2.78 kW	2.49 kW
COP Tj = +7°C	5.70	4.57
Cdh Tj = +7 °C	0.970	0.970

This information was generated by the HP KEYMARK database on 23 Jun 2022

Pdh Tj = 12°C	2.67 kW	2.55 kW
COP Tj = 12°C	7.80	6.10
Cdh Tj = +12 °C	0.960	0.960
Pdh Tj = Tbiv	6.19 kW	6.19 kW
COP Tj = Tbiv	2.97	2.09
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.64 kW	4.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.58	1.66
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.990	0.990
WTOL	60 °C	60 °C
Poff	12 W	12 W
PTO	12 W	12 W
PSB	12 W	12 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	n/a	n/a
Supplementary Heater: PSUP	0.36 kW	2.10 kW
Annual energy consumption Qhe	3213 kWh	4334 kWh