

Summary of	ELFOEnergy SHEEN EVO 16.2, 18.2, 22.2	Reg. No.	ICIM-PDC-000061-00
Certificate Holder	!		!
Name	Clivet s.p.a.		
Address	Via camp lonc 25 c.ap.	Zip	I-32032
City	z.i. Villapaiera - Feltre (BL)	Country	Italy
Certification Body	ICIM S.p.A.		
Name of testing laboratory	ReLab Politecnico Milano		
Subtype title	ELFOEnergy SHEEN EVO 16.2, 18.2, 22.2		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R32		
Mass Of Refrigerant	14 kg		
Certification Date	20.01.2020		
Testing basis	HP KEYMARK certification scheme rules rev. no. 7		



Model: ELFOEnergy SHEEN EVO 16.2

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-4		
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed	
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed	
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	
Defrost test	passed	

EN 14511-2			
	Low temperature	Medium temperature	
Heat output	48.60 kW	4.80 kW	
El input	12.12 kW	1.90 kW	
СОР	4.01	2.53	
Indoor water flow rate	8.36 m³/h	0.52 m³/h	

Average Climate



EN 12102-1		
	Low temperature	Medium temperature
Sound power level outdoor	84 dB(A)	64 dB(A)

EN 14825			
	Low temperature	Medium temperature	
η_{s}	154 %	129 %	
Prated	31.00 kW	7.00 kW	
SCOP	3.91	3.30	
Tbiv	-10 °C	-7 °C	
TOL	-10 °C	-10 °C	
Pdh Tj = -7°C	27.80 kW	5.90 kW	
COP Tj = -7°C	2.72	2.00	
Cdh	0.90		
Pdh Tj = +2°C	16.90 kW	3.70 kW	
COP Tj = +2°C	3.85	3.18	
Cdh	0.90		
Pdh Tj = +7°C	10.90 kW	2.50 kW	
COP Tj = +7°C	4.90	4.52	
Cdh	0.90		
Pdh Tj = 12°C	14.20 kW	1.10 kW	

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



COP Tj = 12°C	6.02	5.09
Cdh	0.90	
Pdh Tj = Tbiv	31.40 kW	5.90 kW
COP Tj = Tbiv	2.42	2.00
Pdh Tj = TOL	31.40 kW	6.60 kW
COP Tj = TOL	2.42	1.80
Cdh	0.90	0.90
WTOL	54 °C	49 °C
Poff	30 W	16 W
РТО	404 W	16 W
PSB	30 W	16 W
РСК	o w	34 W
Supplementary Heater: Type of energy input	electric	electric
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	16591 kWh	4202 kWh



Model: ELFOEnergy SHEEN EVO 18.2

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-4		
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed	
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed	
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	
Defrost test	passed	

EN 14511-2		
	Low temperature	Medium temperature
Heat output	54.00 kW	6.20 kW
El input	13.47 kW	2.38 kW
СОР	4.01	2.61
Indoor water flow rate	9.29 m³/h	0.68 m³/h

Average Climate

EN 14825





	Low temperature	Medium temperature
η_{s}	153 %	129 %
Prated	34.00 kW	7.00 kW
SCOP	3.90	3.30
Tbiv	-10 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	29.80 kW	5.90 kW
COP Tj = -7°C	2.67	2.00
Cdh	0.90	
Pdh Tj = +2°C	18.10 kW	3.70 kW
COP Tj = +2°C	3.83	3.18
Cdh	0.90	
Pdh Tj = +7°C	11.70 kW	2.50 kW
$COP Tj = +7^{\circ}C$	4.95	4.52
Cdh	0.90	
Pdh Tj = 12°C	14.20 kW	1.10 kW
COP Tj = 12°C	6.02	5.09
Cdh	0.90	
Pdh Tj = Tbiv	33.70 kW	5.90 kW
COP Tj = Tbiv	2.35	2.00
Pdh Tj = TOL	33.70 kW	6.60 kW

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com





$$\operatorname{\textit{Page}}\ 7$$ of 10 This information was generated by the HP KEYMARK database on 17 Dec 2020

COP Tj = TOL	2.35	1.80
Cdh	0.90	0.90
WTOL	54 °C	49 °C
Poff	30 W	16 W
РТО	404 W	16 W
PSB	30 W	16 W
PCK	0 W	34 W
Supplementary Heater: Type of energy input	electric	electric
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	17826 kWh	4202 kWh

EN 12102-1		
	Low temperature	Medium temperature
Sound power level outdoor	85 dB(A)	64 dB(A)



Model: ELFOEnergy SHEEN EVO 22.2

General Data		
Power supply	3x400V 50Hz	

Heating

EN 14511-4		
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed	
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed	
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	
Defrost test	passed	

EN 14511-2		
	Low temperature	Medium temperature
Heat output	62.00 kW	9.40 kW
El input	15.90 kW	3.30 kW
СОР	3.90	2.85
Indoor water flow rate	10.66 m³/h	1.01 m³/h

Average Climate


EN 14825





	Low temperature	Medium temperature
η_{s}	152 %	127 %
Prated	37.00 kW	9.00 kW
SCOP	3.87	3.26
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	32.30 kW	7.70 kW
COP Tj = -7°C	2.59	1.98
Cdh	0.90	
Pdh Tj = +2°C	19.70 kW	4.90 kW
COP Tj = +2°C	3.76	3.02
Cdh	0.90	
Pdh Tj = +7°C	12.70 kW	3.20 kW
COP Tj = +7°C	5.04	4.67
Cdh	0.90	
Pdh Tj = 12°C	14.20 kW	1.40 kW
COP Tj = 12°C	6.02	6.16
Cdh	0.90	
Pdh Tj = Tbiv	32.30 kW	7.70 kW
COP Tj = Tbiv	2.59	1.98
Pdh Tj = TOL	35.40 kW	7.00 kW

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com





$$\operatorname{\textit{Page}}\ 10$$ of 10 This information was generated by the HP KEYMARK database on 17 Dec 2020

COP Tj = TOL	2.28	1.78
Cdh	0.90	0.90
WTOL	54 °C	49 °C
Poff	30 W	16 W
РТО	404 W	16 W
PSB	30 W	16 W
PCK	0 W	34 W
Supplementary Heater: Type of energy input	electric	electric
Supplementary Heater: PSUP	4.20 kW	0.00 kW
Annual energy consumption Qhe	19512 kWh	5558 kWh

EN 12102-1		
	Low temperature	Medium temperature
Sound power level outdoor	86 dB(A)	67 dB(A)