

Page 1 of 16

## This information was generated by the HP KEYMARK database on 23 Jun 2022

#### **Login**

Summary of	TTL 3.5 ACS	Reg. No.	011-1W0116
Certificate Holder	Certificate Holder		
Name	tecalor GmbH		
Address	Fürstenbergerstr. 77	Zip	37603
City	Holzminden	Country	Germany
Certification Body	DIN CERTCO Gesellschaft für	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH	
Subtype title	TTL 3.5 ACS	TTL 3.5 ACS	
Heat Pump Type	Outdoor Air/Water	Outdoor Air/Water	
Refrigerant	R410A	R410A	
Mass of Refrigerant	1.1 kg	1.1 kg	
Certification Date	19.01.2017	19.01.2017	



# Model: TTL 3.5 ACS + HSBB 200 classic, HSBB 200 S classic

Configure model		
Model name	TTL 3.5 ACS + HSBB 200 classic, HSBB 200 S classic	
Application	Heating + DHW + low temp	
Units	Indoor + Outdoor	
Climate Zone	n/a	
Reversibility	Yes	
Cooling mode application (optional) n/a		

General Data		
Power supply	1x230V 50Hz	

# Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	2.27 kW	1.92 kW
El input	0.50 kW	0.74 kW
СОР	4.54	2.59

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

## **Average Climate**



EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	33 dB(A)	33 dB(A)
Sound power level outdoor	52 dB(A)	52 dB(A)


EN 14825		
	Low temperature	Medium temperature
$\eta_{s}$	166 %	116 %
Prated	3.62 kW	3.83 kW
SCOP	4.22	2.96
Tbiv	-7 °C	-5 °C
TOL	-10 °C	-7 °C
Pdh Tj = -7°C	3.20 kW	2.79 kW
COP Tj = $-7^{\circ}$ C	2.88	2.01
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = $+2$ °C	1.95 kW	2.01 kW
COP Tj = +2°C	4.11	2.94
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = $+7^{\circ}$ C	1.59 kW	1.25 kW
COP Tj = +7°C	5.81	4.13
Cdh Tj = +7 °C	0.900	0.900





	<u> </u>	
Pdh Tj = 12°C	1.66 kW	1.54 kW
COP Tj = 12°C	6.34	5.13
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	3.20 kW	3.09 kW
COP Tj = Tbiv	2.88	2.20
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.04 kW	2.79 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.51	2.01
Rated airflow rate	0 m³/h	0 m³/h
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	60 °C	60 °C
Poff	17 W	17 W
РТО	30 W	30 W
PSB	17 W	17 W
PCK	5 W	5 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.58 kW	3.83 kW
Annual energy consumption Qhe	1771 kWh	2672 kWh

Domestic Hot Water (DHW)





EN 16147		
Declared load profile	L	
Efficiency ηDHW	113 %	
СОР	2.70	
Heating up time	1:50 h:min	
Standby power input	35.0 W	
Reference hot water temperature	52.5 °C	
Mixed water at 40°C	245 I	



# **Model: TTL 3.5 ACS**

Configure model		
Model name	TTL 3.5 ACS	
Application	Heating (low temp)	
Units	Outdoor	
Climate Zone	Colder Climate + Warmer Climate	
Reversibility	Yes	
Cooling mode application (optional)	n/a	

General Data		
Power supply	1x230V 50Hz	

# Heating

EN 14511-2	
Low temperature	
Heat output	2.27 kW
El input	0.50 kW
СОР	4.54

EN 14511-4	
Shutting off the heat transfer medium flow	naccod
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

## Warmer Climate



EN 12102-1	
	Low temperature
Sound power level indoor	0 dB(A)
Sound power level outdoor	52 dB(A)

EN 14825	
	Low temperature
$\eta_s$	200 %
Prated	3.00 kW
SCOP	5.07
Tbiv	2 °C
TOL	2 °C
Pdh Tj = -7°C	0.00 kW
COP Tj = -7°C	0.00
Pdh Tj = +2°C	3.04 kW
COP Tj = +2°C	3.39
Cdh Tj = +2 °C	0.900
Pdh Tj = $+7^{\circ}$ C	1.95 kW
$COP Tj = +7^{\circ}C$	5.18
Cdh Tj = +7 °C	0.900
Pdh Tj = 12°C	1.63 kW






Thirt database on 25 jun 202
6.14
0.900
3.04 kW
3.39
3.04 kW
3.39
0 m³/h
0.900
60 °C
17 W
30 W
17 W
5 W
Electricity
0.00 kW
791 kWh

# Colder Climate



EN 12102-1	
	Low temperature
Sound power level indoor	0 dB(A)
Sound power level outdoor	52 dB(A)

EN 14825	
	Low temperature
$\eta_s$	148 %
Prated	3.38 kW
SCOP	3.77
Tbiv	-15 °C
TOL	-20 °C
Pdh Tj = -7°C	2.05 kW
COP Tj = -7°C	3.20
Cdh Tj = -7 °C	0.900
Pdh Tj = +2°C	1.25 kW
$COP Tj = +2^{\circ}C$	4.55
Cdh Tj = +2 °C	0.900
Pdh Tj = +7°C	1.39 kW
$COP Tj = +7^{\circ}C$	6.03
Cdh Tj = +7 °C	0.900





Pdh Tj = 12°C	1.64 kW
COP Tj = 12°C	6.22
Cdh Tj = +12 °C	0.900
Pdh Tj = Tbiv	2.76 kW
COP Tj = Tbiv	2.56
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	2.33 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.13
Rated airflow rate	0 m³/h
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900
WTOL	60 °C
Poff	17 W
PTO	30 W
PSB	17 W
PCK	5 W
Supplementary Heater: Type of energy input	Electricity
Supplementary Heater: PSUP	3.38 kW
Annual energy consumption Qhe	2208 kWh
Pdh Tj = -15°C (if TOL<-20°C)	
COP Tj = -15°C (if TOL $<$ -20°C)	
Cdh Tj = -15 °C	



EN 12102-1	
	Low temperature
Sound power level indoor	0 dB(A)
Sound power level outdoor	52 dB(A)

EN 14825	
	Low temperature
$\eta_s$	166 %
Prated	3.62 kW
SCOP	4.22
Tbiv	-7 °C
TOL	-10 °C
Pdh Tj = -7°C	3.20 kW
COP Tj = -7°C	2.88
Cdh Tj = -7 °C	0.900
Pdh Tj = +2°C	1.95 kW
$COP Tj = +2^{\circ}C$	4.11
Cdh Tj = +2 °C	0.900
Pdh Tj = +7°C	1.59 kW
$COP Tj = +7^{\circ}C$	5.81
Cdh Tj = +7 °C	0.900
	·



Page 12 of 16

## This information was generated by the HP KEYMARK database on 23 Jun 2022

Pdh Tj = 12°C	1.66 kW
COP Tj = 12°C	6.34
Cdh Tj = +12 °C	0.900
Pdh Tj = Tbiv	3.20 kW
COP Tj = Tbiv	2.88
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.05 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.07
Rated airflow rate	0 m³/h
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900
WTOL	60 °C
Poff	17 W
РТО	30 W
PSB	17 W
PCK	5 W
Supplementary Heater: Type of energy input	Electricity
Supplementary Heater: PSUP	0.58 kW
Annual energy consumption Qhe	1771 kWh



# Model: TTL 3.5 ACS + HSBC 200, HSBC 200 S

Configure model		
Model name	TTL 3.5 ACS + HSBC 200, HSBC 200 S	
Application	Heating + DHW + low temp	
Units	Indoor + Outdoor	
Climate Zone	n/a	
Reversibility	Yes	
Cooling mode application (optional)	n/a	

General Data	
Power supply	1x230V 50Hz

# Heating


EN 14511-2				
	Low temperature	Medium temperature		
Heat output	2.27 kW	1.92 kW		
El input	0.50 kW	0.74 kW		
СОР	4.54	2.59		

EN 14511-4		
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	
Defrost test	passed	
Starting and operating test	passed	



EN 12102-1				
	Low temperature	Medium temperature		
Sound power level indoor	33 dB(A)	33 dB(A)		
Sound power level outdoor	52 dB(A)	52 dB(A)		


EN 14825				
	Low temperature	Medium temperature		
$\eta_{s}$	166 %	116 %		
Prated	3.62 kW	3.83 kW		
SCOP	4.22	2.96		
Tbiv	-7 °C	-5 °C		
TOL	-10 °C	-7 °C		
Pdh Tj = -7°C	3.20 kW	2.79 kW		
COP Tj = $-7$ °C	2.88	2.01		
Cdh Tj = -7 °C	0.900	0.900		
Pdh Tj = $+2$ °C	1.95 kW	2.01 kW		
COP Tj = +2°C	4.11	2.94		
Cdh Tj = +2 °C	0.900	0.900		
Pdh Tj = $+7^{\circ}$ C	1.59 kW	1.25 kW		
COP Tj = +7°C	5.81	4.13		
Cdh Tj = +7 °C	0.900	0.900		





	· · · · · · · · · · · · · · · · · · ·	,
Pdh Tj = 12°C	1.66 kW	1.54 kW
COP Tj = 12°C	6.34	5.13
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	3.20 kW	3.09 kW
COP Tj = Tbiv	2.88	2.20
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.20 kW	3.09 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.88	2.20
Rated airflow rate	0 m³/h	0 m³/h
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	60 °C	60 °C
Poff	17 W	17 W
РТО	30 W	30 W
PSB	17 W	17 W
PCK	5 W	5 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.58 kW	3.83 kW
Annual energy consumption Qhe	1771 kWh	2672 kWh

Domestic Hot Water (DHW)





EN 16147		
Declared load profile	L	
Efficiency ηDHW	113 %	
СОР	2.70	
Heating up time	1:50 h:min	
Standby power input	35.0 W	
Reference hot water temperature	52.5 °C	
Mixed water at 40°C	245 I	