

This information was generated by the HP KEYMARK database on 21 Jun 2022

[Login](#)

[Login](#)

Summary of	HPA-O 7 S Premium, HPA-O 7 CS Premium		Reg. No.	011-1W0229
Certificate Holder				
Name	STIEBEL ELTRON GmbH & Co KG			
Address	Dr. Stiebel Straße 33	Zip	37603	
City	Holzminden	Country	Germany	
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH			
Subtype title	HPA-O 7 S Premium, HPA-O 7 CS Premium			
Heat Pump Type	Outdoor Air/Water			
Refrigerant	R410A			
Mass of Refrigerant	4.2 kg			
Certification Date	08.01.2018			

Model: HPA-O 7 S Premium

Configure model	
Model name	HPA-O 7 S Premium
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	4.68 kW	3.74 kW
El input	1.11 kW	1.37 kW
COP	4.23	2.73

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 21 Jun 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level outdoor	50 dB(A)	50 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	151 %	122 %
Prated	8.00 kW	8.00 kW
SCOP	3.84	3.20
Tbiv	-8 °C	-8 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	6.80 kW	7.10 kW
COP Tj = -7°C	2.49	2.18
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	4.30 kW	4.20 kW
COP Tj = +2°C	4.04	3.30
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	4.50 kW	4.20 kW
COP Tj = +7°C	5.08	4.07
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	4.40 kW	4.00 kW

This information was generated by the HP KEYMARK database on 21 Jun 2022

COP Tj = 12°C	6.30	5.14
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	7.10 kW	7.40 kW
COP Tj = Tbiv	2.42	2.13
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.60 kW	7.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.71	1.97
WTOL	65 °C	65 °C
Poff	16 W	16 W
PTO	16 W	16 W
PSB	16 W	16 W
PCK	43 W	43 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	4303 kWh	5300 kWh

Warmer Climate

EN 14825		
	Low temperature	Medium temperature
η_s	153 %	120 %
Prated	4.00 kW	4.00 kW
SCOP	3.91	2.99

This information was generated by the HP KEYMARK database on 21 Jun 2022

Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	4.20 kW	4.00 kW
COP Tj = +2°C	3.48	2.50
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	4.30 kW	3.90 kW
COP Tj = +7°C	4.46	3.16
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	4.30 kW	3.80 kW
COP Tj = 12°C	5.89	4.57
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	4.20 kW	4.00 kW
COP Tj = Tbiv	3.48	2.50
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.20 kW	9.80 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.15	1.98
WTOL	65 °C	65 °C
Poff	16 W	16 W
PTO	16 W	16 W
PSB	16 W	16 W
PCK	43 W	43 W
Supplementary Heater: Type of energy input	Electricity	Electricity

This information was generated by the HP KEYMARK database on 21 Jun 2022

Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Q _{he}	1367 kWh	1750 kWh

Colder Climate

EN 14825		
	Low temperature	Medium temperature
η_s	137 %	118 %
Prated	11.00 kW	12.00 kW
SCOP	3.51	3.05
T _{biv}	-10 °C	-10 °C
TOL	-20 °C	-20 °C
P _{dh} T _j = -7°C	6.80 kW	7.00 kW
COP T _j = -7°C	2.72	2.45
C _{dh} T _j = -7 °C	0.90	0.90
P _{dh} T _j = +2°C	4.30 kW	4.20 kW
COP T _j = +2°C	4.45	3.70
C _{dh} T _j = +2 °C	0.90	0.90
P _{dh} T _j = +7°C	4.50 kW	4.30 kW
COP T _j = +7°C	5.44	4.53
C _{dh} T _j = +7 °C	0.90	0.90
P _{dh} T _j = 12°C	4.40 kW	4.10 kW

This information was generated by the HP KEYMARK database on 21 Jun 2022

COP Tj = 12°C	6.30	5.44
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	7.70 kW	7.90 kW
COP Tj = Tbiv	2.50	2.28
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.10 kW	9.70 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.25	2.10
WTOL	65 °C	65 °C
Poff	16 W	16 W
PTO	16 W	16 W
PSB	16 W	16 W
PCK	43 W	43 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	11.20 kW	11.61 kW
Annual energy consumption Qhe	7727 kWh	9481 kWh
Pdh Tj = -15°C (if TOL<-20°C)	9.10	9.70
COP Tj = -15°C (if TOL<-20°C)	2.25	2.10
Cdh Tj = -15 °C	0.90	0.90

Model: HPA-O 7 CS Premium

Configure model	
Model name	HPA-O 7 CS Premium
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	4.68 kW	3.74 kW
El input	1.11 kW	1.37 kW
COP	4.23	2.73

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 21 Jun 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level outdoor	50 dB(A)	50 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	159 %	127 %
Prated	8.00 kW	8.00 kW
SCOP	4.04	3.34
Tbiv	-8 °C	-8 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	6.80 kW	7.10 kW
COP Tj = -7°C	2.49	2.18
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	4.30 kW	4.20 kW
COP Tj = +2°C	4.04	3.30
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	4.50 kW	4.20 kW
COP Tj = +7°C	5.08	4.07
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	4.40 kW	4.00 kW

This information was generated by the HP KEYMARK database on 21 Jun 2022

COP Tj = 12°C	6.30	5.14
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	7.10 kW	7.40 kW
COP Tj = Tbiv	2.42	2.13
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.60 kW	7.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.71	1.97
WTOL	65 °C	65 °C
Poff	16 W	16 W
PTO	16 W	16 W
PSB	16 W	16 W
PCK	43 W	43 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	4086 kWh	5084 kWh

Warmer Climate

EN 14825		
	Low temperature	Medium temperature
η_s	190 %	142 %
Prated	4.00 kW	4.00 kW
SCOP	4.83	3.50

This information was generated by the HP KEYMARK database on 21 Jun 2022

Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	4.20 kW	4.00 kW
COP Tj = +2°C	3.48	2.50
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	4.30 kW	3.90 kW
COP Tj = +7°C	4.46	3.16
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	4.30 kW	3.80 kW
COP Tj = 12°C	5.89	4.57
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	4.20 kW	4.00 kW
COP Tj = Tbiv	3.48	2.50
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.20 kW	9.80 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.15	1.98
WTOL	65 °C	65 °C
Poff	16 W	16 W
PTO	16 W	16 W
PSB	16 W	16 W
PCK	43 W	43 W
Supplementary Heater: Type of energy input	Electricity	Electricity

This information was generated by the HP KEYMARK database on 21 Jun 2022

Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Q _{he}	1106 kWh	1489 kWh

Colder Climate

EN 14825		
	Low temperature	Medium temperature
η_s	140 %	119 %
Prated	11.00 kW	12.00 kW
SCOP	3.57	3.09
T _{biv}	-10 °C	-10 °C
TOL	-20 °C	-20 °C
P _{dh} T _j = -7°C	6.80 kW	7.00 kW
COP T _j = -7°C	2.72	2.45
C _{dh} T _j = -7 °C	0.90	0.90
P _{dh} T _j = +2°C	4.30 kW	4.20 kW
COP T _j = +2°C	4.45	3.70
C _{dh} T _j = +2 °C	0.90	0.90
P _{dh} T _j = +7°C	4.50 kW	4.30 kW
COP T _j = +7°C	5.44	4.53
C _{dh} T _j = +7 °C	0.90	0.90
P _{dh} T _j = 12°C	4.40 kW	4.10 kW

This information was generated by the HP KEYMARK database on 21 Jun 2022

COP Tj = 12°C	6.30	5.44
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	7.70 kW	7.90 kW
COP Tj = Tbiv	2.50	2.28
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.10 kW	9.70 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.25	2.10
WTOL	65 °C	65 °C
Poff	16 W	16 W
PTO	16 W	16 W
PSB	16 W	16 W
PCK	43 W	43 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	11.20 kW	11.61 kW
Annual energy consumption Qhe	7597 kWh	9351 kWh
Pdh Tj = -15°C (if TOL<-20°C)	9.10	9.70
COP Tj = -15°C (if TOL<-20°C)	2.25	2.10
Cdh Tj = -15 °C	0.90	0.90