

Page 1 of 4 This information was generated by the HP KEYMARK database on 17 Dec 2020

	3			
Summary of	ACV Alféa Excellia Tri 14 BS	Reg. No.	012-C700004	
Certificate Holder				
Name	Groupe Atlantic			
Address	44 boulevard des Etats-Unis	Zip	85000	
City	La Roche Sur Yon	Country	France	
Certification Body	RISE CERT			
Name of testing laboratory	SP			
Subtype title	ACV Alféa Excellia Tri 14 BS	ACV Alféa Excellia Tri 14 BS		
Heat Pump Type	Outdoor Air/Water	Outdoor Air/Water		
Refrigerant	R410a	R410a		
Mass Of Refrigerant	2.5 kg	2.5 kg		
Certification Date	19.12.2019	19.12.2019		
Testing basis	EN 14511:2013; EN 14825:2013;	EN 14511:2013; EN 14825:2013; EN 12102:2013		



This information was generated by the HP KEYMARK database on 17 Dec 2020

Model: ACV Alféa Excellia Tri 14 BS

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	13.00 kW	10.60 kW
El input	3.11 kW	4.40 kW
СОР	4.18	2.41
Indoor water flow rate	2.30 m³/h	1.25 m³/h

EN 14511-4		
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed	
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed	
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	
Defrost test	passed	

Average Climate



 $$\operatorname{\textit{Page}}\xspace$ 3 of 4 This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	46 dB(A)	46 dB(A)
Sound power level outdoor	69 dB(A)	69 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_{s}	150 %	117 %
Prated	13.00 kW	11.00 kW
SCOP	3.82	3.00
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	11.10 kW	10.00 kW
COP Tj = -7°C	2.50	2.00
Pdh Tj = +2°C	6.70 kW	6.10 kW
COP Tj = +2°C	3.70	2.90
Pdh Tj = +7°C	6.20 kW	5.90 kW
COP Tj = +7°C	5.40	4.10
Pdh Tj = 12°C	7.30 kW	7.10 kW
COP Tj = 12°C	7.00	5.40
Pdh Tj = Tbiv	11.10 kW	10.00 kW

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



 $$\operatorname{\textit{Page}}4 of 4$ This information was generated by the HP KEYMARK database on 17 Dec 2020$

COP Tj = Tbiv	2.50	2.00
Pdh Tj = TOL	10.80 kW	9.30 kW
COP Tj = TOL	2.40	1.60
Cdh	0.90	0.90
WTOL	60 °C	60 °C
Poff	14 W	14 W
РТО	66 W	43 W
PSB	17 W	17 W
PCK	o w	o w
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	1.70 kW	2.00 kW
Annual energy consumption Qhe	6738 kWh	7803 kWh