

This information was generated by the HP KEYMARK database on 18 Mar 2022

[Login](#)

Summary of	CTC GS 6	Reg. No.	012-SC1212-17
Certificate Holder			
Name	Enertech CTC AB		
Address	Box 309, Näsvägen	Zip	SE-381 26
City	Ljungby	Country	Sweden
Certification Body	RISE CERT		
Subtype title	CTC GS 6		
Heat Pump Type	Brine/Water		
Refrigerant	R407c		
Mass of Refrigerant	1.9 kg		

Model: CTC GS 6

Configure model	
Model name	CTC GS 6
Application	Heating + DHW
Units	Indoor
Climate Zone	Colder Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz
Off-peak product	No
Phase-out Date	25.10.2023

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed

EN 14511-2	
	Medium temperature
Heat output	5.18 kW
El input	1.78 kW
COP	2.91

Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 12102-1

	Medium temperature
Sound power level indoor	41 dB(A)

EN 14825

	Medium temperature
η_s	140 %
Prated	6.41 kW
SCOP	3.69
Tbiv	-6 °C
TOL	-10 °C
Pdh Tj = -7°C	5.30 kW
COP Tj = -7°C	3.18
Pdh Tj = +2°C	5.60 kW
COP Tj = +2°C	3.80
Pdh Tj = +7°C	5.70 kW
COP Tj = +7°C	4.19
Pdh Tj = 12°C	5.80 kW
COP Tj = 12°C	4.62
Pdh Tj = Tbiv	5.37 kW
COP Tj = Tbiv	3.30

This information was generated by the HP KEYMARK database on 18 Mar 2022

$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	5.18 kW
$COP T_j = TOL$ or $COP T_j = T_{designh}$ if $TOL < T_{designh}$	2.91
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	0.99
WTOL	65 °C
Poff	18 W
PTO	106 W
PSB	18 W
PCK	0 W
Supplementary Heater: Type of energy input	Electricity
Supplementary Heater: PSUP	1.10 kW
Annual energy consumption Q_{he}	1685 kWh

Colder Climate

EN 12102-1	
	Medium temperature
Sound power level indoor	41 dB(A)

EN 14825	
	Medium temperature
η_s	143 %
Prated	6.03 kW

This information was generated by the HP KEYMARK database on 18 Mar 2022

SCOP	3.78
Tbiv	-18 °C
TOL	-22 °C
Pdh Tj = -7°C	5.50 kW
COP Tj = -7°C	3.65
Pdh Tj = +2°C	5.70 kW
COP Tj = +2°C	4.12
Pdh Tj = +7°C	5.80 kW
COP Tj = +7°C	4.47
Pdh Tj = 12°C	5.90 kW
COP Tj = 12°C	4.75
Pdh Tj = Tbiv	5.30 kW
COP Tj = Tbiv	3.18
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.18 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.91
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.99
WTOL	65 °C
Poff	18 W
PTO	3 W
PSB	18 W
PCK	0 W

Supplementary Heater: Type of energy input	Electricity
Supplementary Heater: PSUP	0.90 kW
Annual energy consumption Q_{he}	1685 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	XL
Efficiency η_{DHW}	100 %
Heating up time	2:14 h:min
Mixed water at 40°C	239 l
COP	2.50
Standby power input	57.0 W
Reference hot water temperature	49.7 °C

Colder Climate

EN 16147	
Declared load profile	XL
Efficiency η_{DHW}	100 %
Heating up time	2:14 h:min
Mixed water at 40°C	239 l
COP	2.50
Standby power input	57.0 W
Reference hot water temperature	49.7 °C